



NOTES:

1. TANK VOLUME TO BE DETERMINED BY GRU UPON APPLICATION BY OWNER, STRUCTURAL DESIGN SHALL BE THE RESPONSIBILITY OF THE TANK MANUFACTURER.
2. ONLY KITCHEN WASTE SHALL BE DISCHARGED INTO THE GREASE TRAP. ALL DOMESTIC WASTE (i.e. RESTROOMS) SHALL BE CONNECTED DOWNSTREAM OF THE GREASE TRAP.
3. MANHOLES WHICH ARE NOT INSTALLED UNDER PAVEMENT SHALL HAVE A RIM ELEVATION AT LEAST 6" ABOVE FINISHED GRADE, AND A 10:1 SLOPE TO FINISHED GRADE.
4. GREASE TRAP ASSEMBLY TO BE H-20 TRAFFIC LOAD RATED - INCLUDING TANK, TANK LID, CHIMNEYS AND MANHOLE RING & COVER.
5. NO CAPPED TEES.

Revision Date:
8/22/2016



Gainesville Regional Utilities
Wastewater Construction Details

GREASE TRAP