



525 Stevens St.
 Jacksonville, Fl. 32254
 Phone : 904-634-7100

FIRE HYDRANT REPORT

Owner: GAINESVILLE RENEWABLE ENERGY PAGE 1 Phone Number : 386.315.8013

Owner's Address: 11201 NW 13TH ST. GAINESVILLE, FL.

Property:: _____

Date: 2017-01-27 Time: _____ Inspector: J. SCHULL

BLD#	LOCATION	STATIC	RESIDUAL	PITOT	DISCHARGE SIZE	GPM
	SOUTH END OF BOILER	180		53	2-1/2"	1220
	SOUTH END OF COOLING TOWERS	180		52	2-1/2"	1210
	MIDDLE OF COOLING TOWERS	180		53	2-1/2"	1220
	NORTH END OF COOLING TOWERS	180		54	2-1/2"	1230
	EAST SIDE OF BOILER NEXT TO RISER ROOM	180		52	2-1/2"	1210
	SOUTH END OF LUBRICATION BLDG.	180		52	2-1/2"	1210
	N.E. END OF PROPERTY	180		53	2-1/2"	1220
	EAST END OF TRANSFORMERS	180		53	2-1/2"	1220
	N.E. END OF WAREHOUSE	180		54	2-1/2"	1230
	NORTH END OF BOILER	180		53	2-1/2"	1220
	EAST SIDE OF WATER TREATMENT BLDG.	180		53	2-1/2"	1220
	EAST END OF ADMIN BLDG.	180		54	2-1/2"	1230
	WEST END OF WAREHOUSE	180		52	2-1/2"	1210
	N.E. END OF WOOD YARD	180		53	2-1/2"	1220
	NORTH MIDDLE END OF WOOD YARD	180		53	2-1/2"	1220
	N.W. END OF WOOD YARD	180		53	2-1/2"	1220
	WEST END OF WOOD YARD	180		50	2-1/2"	1190
	EAST END OF TRUCK RECEIVING			NO FLOW	2-1/2"	
	SOUTH MIDDLE END OF WOOD YARD	180		55	2-1/2"	1240