

525 Stevens St. Jacksonville, Fl. 32254 Phone: 904-634-7100

## **FIRE HYDRANT REPORT**

Owner:	ner: GAINESVILLE RENEWABLE EN		PAGE 2	Phone Number :	er: 386.315.8013		
Owner's Address:		11201 NW 13TH ST. GAINESVILLE,	FL.				
Property::		HYDRANTS FLOWED WITH GRAV	TY PRESSURE BAC	CKED BY JOCKEY PUMP TO R	EDUSE CHANCE OF DAMAGE	TO PIPING	
Date: 2	2017-01-2	27 Time:		Inspecto	JASON SCHULL		

BLD#	LOCATION	STATIC	RESIDUAL	PITOT	DISCHARGE SIZE	GPM
	EAST END OF HOG SCREEN	180		53	2-1/2"	1220
	N.E. END OF SCALE HOUSE	180		52	2-1/2"	1210
	S.E. END OF WOOD YARD	180		54	2-1/2"	1230