

Air Emissions Compliance Test Report

Completed for:

***Gainesville Renewable Energy Center
Woody Biomass Power Plant
Biomass-fueled BFB Boiler (EU-002)***

Test Report Number: 20-11542-02-001

Test Completed: March 22 - 24, 2017



**Air Emissions Compliance
Test Report**

**Gainesville Renewable Energy Center
Woody Biomass Power Plant
Woody Biomass-fueled BFB Boiler (EU-002)
Gainesville, Florida**

C.E.M. Solutions Project No.: 11542


Testing Completed: March 22 - 24, 2017

C.E.M. Solutions, Inc. Report Number: 20-11542-01-001

C.E.M. Solutions, Inc.
1183 E. Overdrive Circle
Hernando, Florida 34442
Phone: 352-489-4337

Declaration of Conformance to ASTM D 7036-04: Standard Practice for Competence of Air Emission Testing Bodies


C.E.M. Solutions operates in conformance with the requirements of ASTM D 7036-04: Standard Practice for Competence of Air Emission Testing Bodies through the use of a quality system which incorporates a quality manual, internal audit system, systematic training of personnel and rigorous review of test methods and operating procedures. C.E.M. Solutions Inc. collects performance data related to the quality system and this data is available upon request.



Joe Conti
Quality Assurance Manager
C.E.M. Solutions

Statement of Validity

I hereby certify the information and data provided in this emissions test report for tests performed at the Gainesville Renewable Energy Center's Woody Biomass Power Plant conducted on March 22 through 24, 2017 are complete and accurate to the best of my knowledge.

A handwritten signature in black ink, appearing to read 'Joe Conti', is written over a horizontal line.

Joe Conti
Quality Assurance Manager,
C.E.M. Solutions, Inc.

Project Background

Name of Source Owner: Gainesville Renewable Energy Center

Address of Owner: 11201 NW Hwy 441
Gainesville, FL 32653

Source Identification: Facility ID: 0010131
Woody Biomass-fueled BFB Boiler
Emissions Unit: 002

Location of Source: Alachua County, Florida

Type of Operation: SIC Code 4911

Tests Performed: Method 1 – Traverse Points
Method 2 – Stack Gas Volumetric Flow and Velocity
Method 3A – Determination of O₂ and CO₂
Method 3B – Determination of O₂ and CO₂
Method 4 – Stack Gas Moisture Content
Method 5 – Particulate Matter
Conditional Test Method 013– Sulfuric Acid Mist
Method 9 – Determination of Opacity of Emissions
Method 19 – Determination of Emission Rates
Method 25A - Determination of VOC
Method 26A - Determination of HCl and HF
Conditional Test Method 027 –Ammonia Slip Determination
Method 30B – Determination of Mercury
Method 201A – Determination of Particulate Matter 2.5

Test Supervisor (QSTI): Charles Horton

Test Technicians: Matthew Brock
Thomas Cawiezell
Alexander Lagunas

Date(s) Tests Conducted: March 22 through 24, 2017:

Site Test Coordinator: Ali Leaphart, Plant Engineer

County Regulatory Observers: Bill Barnard and Justin Knoll of AMEC on behalf of Alachua
County Environmental Protection Department (ACEPD)

Table of Contents

1.0	Introduction	1
1.1	Test Deviations or Anomalies	1
2.0	Facility Description	3
2.1	Process Equipment	3
2.2	Regulatory Requirements	3
3.0	Test Program/Operating Conditions	4
4.0	Test Methods	5
4.1	Sample and Velocity Traverse Points	5
4.1.1	Gaseous Traverse Points and Run Durations	6
4.1.2	Wet Chemistry Traverse Points and Run Durations	6
4.2	Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tubes)	6
4.2.1	Method 2 Quality Assurance/Quality Control Procedures	6
4.3	Moisture Content Determination	7
4.3.1	Method 4 Quality Assurance/Quality Control Procedures	7
4.4	Particulate Matter Determination	7
4.4.1	Sample Recovery and Analysis	8
4.4.2	Quality Assurance/Quality Control Procedures	8
4.5	Sulfuric Acid Mist (CTM-013)	8
4.5.1	Sample Recovery and Analysis	9
4.5.2	Quality Assurance/Quality Control Procedures	9
4.6	Hydrogen chloride (HCl) and Hydrogen Fluoride (HF)	9
4.6.1	Quality Assurance/Quality Control Procedures	10
4.7	Ammonia Slip Test	10
4.7.1	Quality Assurance/Quality Control Procedures	11
4.8	Mercury Determination	11
4.8.1	Sample Recovery and Analysis	12
4.8.2	Sample Recovery and Analysis	12
4.8.2	Sample Recovery and Analysis	12
4.9	Determination of PCDD's and PCDF's	13
4.9.1	Method 23 Quality Assurance/Quality Control Procedures	13
4.10	VOC Determination	14
4.11	Visible Emission Determination	15
5.0	Test Results	16

List of Tables

Table 1: Summary of Test Results.....	2
Table 2: Emissions Limitations and Standards	3
Table 3: Test Dates and Unit Load	4
Table 4: Summary of EPA Reference Methods	5
Table 5: Compliance Test Summary.....	16

Appendices

Appendix A: Facility Operating Data	
Appendix B: Mathematical Equations	
Appendix C: Sample Location Diagram/Traverse Points	
Appendix D: Reference Method QA/QC	
Appendix D-1: Instrumental Method QA/QC	
Appendix D-2: Wet Chemistry Method QA/QC	
Appendix E: Reference Method Data	
Appendix E-1: Instrumental Methods Test Data	
Appendix E-2: Particulate Matter Test Data	
Appendix E-3: Sulfuric Acid Mist Test Data	
Appendix E-4: Ammonia Slip Test Data	
Appendix E-5: HCl and HF Test Data	
Appendix E-7: Mercury Test Data	
Appendix E-8: Dioxins and Furans Test Data	
Appendix E-9 Method 9	
Appendix F: Laboratory Reports	
Appendix G: Accreditations and Certifications	

1.0 Introduction

Gainesville Renewable Energy Center (GREC) retained C.E.M. Solutions, Inc. to conduct air emissions tests at the Gainesville Renewable Energy Center's Woody Biomass-fueled BFB Boiler (EU-002) located in Gainesville, Florida.

The test program was used to determine the compliance status of Woody Biomass-fueled BFB Boiler in regards to its emissions limitations and standards outlined in Air Construction Permit 0010131-006-AV and IB MACT standards, 40CFR63, Subpart DDDDD.

The test program and results are presented and discussed in this report. Table 1 summarizes the target pollutants, test methods used and the permit and/or performance criteria for each pollutant. Test results are detailed and discussed in Section 5.0 of this report.

Ali Leaphart of GREC coordinated plant operations throughout the test program. Bill Barnard and Justin Knoll of the Alachua County Environmental Protection Department was present during portions of the test program. All testing was conducted in accordance with test methods promulgated by the USEPA and approved by the Florida DEP.

A Stationary Source Audit Sample (SSAS) was ordered from the ERA laboratory and included with the samples delivered to Enthalpy Analytical for analysis. Results of the audit were within the SSAS criteria and the audit sample report is included in Appendix E with the HCl/HF laboratory analysis results report.

1.1 Test Deviations or Anomalies

Due to the low level of analytes encountered during the test program, a universal protocol was developed for reporting laboratory analysis values. If the laboratory reported a value to be under the minimum detection level (MDL) or as a "non detect", the value was reported at the MDL for calculations of emissions. When a value is reported to be above the MDL but below the Limit of Quantification (LOQ, which means the presence of the compound is detected but it could not be accurately determined) the LOQ or reporting limit of the analytical method was used for calculation of emissions. Reported emissions impacted by this reporting protocol include the HCl and HF (Method 26A) and SAM (CTM-013). Analytical reports provided by the laboratories detail which analytes were not detected and those below the LOQ.

**Table 1: Summary of Test Results
Woody Biomass Power Plant Energy Complex
Woody Biomass-fueled BFB Boiler**

Parameter	3 Run Average Emission	Permitted Emissions Rate
Sulfuric acid mist	0.1 lb/hr	1.4 lb/hr
HCl	0.11 lb/hr 0.00009 lb/mmBtu	2.22 lb/hr 0.002 lb/mmBtu
HF	0.05 lb/hr	2.22 lb/hr
Total Filterable Particulate Matter	0.0010 lb/mmBtu	0.0098 lb/mmBtu
< 2.5 micrometer Particulate Matter	0.0020 lb/mmBtu	No set limit.
Visible Emissions	0.0 %	10% Opacity
Total Hydrocarbons (VOC)	0.000 lb/mmBtu	0.009 lb/mmBtu
Ammonia slip	0.3 ppmvd @ 7% O ₂	10 ppmvd @ 7% O ₂
Mercury	3.89 x10 ⁻⁷ lb/mmBtu	8.0 X 10 ⁻⁷ lb/mmBtu (40CFR63, Subpart DDDDD for Hg)
Dioxins & Furans	0.02 ng TEQ/dscm @ 7% O ₂	0.15 ng TEQ/dscm @ 7% O ₂

2.0 Facility Description

The Biomass-fueled Bubbling Fluidized Bed Boiler (EU-002) consists of a 100 MW steam turbine electric power generator. The Woody Biomass-fueled BFB Boiler burns clean wood and is rated for a maximum heat input of 1,358 mmbtu/hr.

2.1 Process Equipment

Emission controls consist of the following:

- Nitrogen oxides (NO_x) emissions are controlled by a selective catalytic reduction (SCR) system (via injection of ammonia solution into combustion flue gas).
- Sulfur dioxide (SO₂), acid gases (HCl and HF) and organic compound emissions from the Woody Biomass-fueled BFB Boiler are controlled by an in-duct sorbent injection system.
- PM, NO_x, CO and VOC emissions are controlled by efficient combustion
- Particulate matter (PM) emissions are controlled by a fabric filter (baghouse).

2.2 Regulatory Requirements

The facility was required to conduct emissions testing to determine compliance with Florida Air Permit No. 0010131-006-AV and 40CFR63, Subpart DDDDD. The source of each parameter's emissions limitations and standards are summarized in Table 2.

**Table 2: Emissions Limitations and Standards
Woody Biomass Power Plant Energy Complex
Woody Biomass-fueled BFB Boiler**

Parameter	Performance/Emissions Limit	Performance or Permit condition
VOC	0.009 lb/MMBtu	Subsection B, PC 9
HCl & HF	2.22 lb/hr 2.2 X 10 ⁻² lb/MMBtu	Subsection B, PC 9 40CFR63, Subpart DDDDD
PM (total filterable)	0.015 lb/MMBtu 0.0098 lb/MMBtu	Subsection B, PC 9 40CFR63, Subpart DDDDD
PM (≤ 2.5µm)	Informational purposes only	Consent decree
SAM/flow CTM-013/M2	1.4 lb/hr	Subsection B, PC 9
VE (Boiler)	Boiler: 10%/20% once/hr	Subsection B, PC 9
NH ₃ Slip	10 ppmvd @ 7% O ₂	Subsection B, PC 9
Mercury	8.0 X 10 ⁻⁷ lb/MMBtu	40CFR63, Subpart DDDDD
Dioxins and Furans	0.15ng TEQ/dscm @ 7% O ₂	Consent decree

3.0 Test Program/Operating Conditions

Air emissions testing to determine the compliance status of the Woody Biomass-fueled BFB Boiler was conducted on March 22 through March 24, 2017.

Table 3 summarizes the dates on which portions of the compliance test were conducted and the average heat input at which the unit was operating during each day.

**Table 3: Test Dates and Unit Load
Gainesville Renewable Energy Center
Woody Biomass-fueled BFB Boiler**

Date	Test Conducted	Unit Steam Flow (lb/hr)
March 22, 2017	Methods 5, 23, 26A, 30B	882,090 lb/hr
March 23, 2017	Methods 5, 23, 25A, 26A, 201A	855,100 lb/hr
March 24, 2017	Methods 30B, CTM-013, CTM-027	853,220 lb/hr

During the compliance test program, the Woody Biomass-fueled BFB Boiler steam flow averaged 863470 lb/hr while operating on 100 percent solid fuel, which correlates to 93 percent of the maximum steam flow (930,000 lb/hr).

4.0 Test Methods

All testing was performed in accordance with methods approved by the USEPA and FDEP. The following discusses the methods, as well as quality assurance and sample handling procedures.

Table 4 summarizes the EPA test methods utilized to complete the test program.

**Table 4: Summary of EPA Reference Methods
Woody Biomass Power Plant Energy Complex
Woody Biomass-fueled BFB Boiler**

EPA Method	Description
1	Sample and Velocity Traverses for Stationary Sources
2	Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot)
3A	Determination of O ₂ and CO ₂
3B	Determination of O ₂ and CO ₂
4	Moisture Content in Stack Gases
5	Particulate Emissions from Stationary Sources
9	Opacity (Visible Emissions)
CTM-013	Determination of Sulfuric Acid Mist
23	Determination of Dioxins and Furans
25A	Determination of VOC
26A	Determination of HCl and HF
CTM-027	Determination of Ammonia Slip
30B	Determination of Mercury
201A	Determination of Particulate Matter 2.5

4.1 Sample and Velocity Traverse Points

Sample and velocity traverse points were determined utilizing EPA Method 1. The circular boiler exhaust stack has an inner diameter of 143.5 inches at the sample location. The Sample location is approximately 110.5 feet (1326 inches) downstream from the nearest flow disturbance and 68.5 feet (822 inches) upstream from the stack exhaust muffler. The sample location is approximately 9.24 diameters downstream from the nearest disturbance and approximately 5.73 diameters upstream from the exhaust muffler.

The stack contains four (4) 6 inch diameter test ports, located at 20°, 110°, 200° and 290°. An additional single test port is located at 315°. A diagram of the sample location can be viewed in Appendix C.

4.1.1 Gaseous Traverse Points and Run Durations

VOC samples were extracted from a single point at the centroid of the stack. VOC test runs were 60 minutes in duration. The test port located at 315° was utilized for gas sampling. A total of three test runs were completed.

4.1.2 Wet Chemistry Traverse Points and Run Durations

Isokinetic, wet chemistry method traverse points were determined in accordance with EPA Method 1. A total of 12 traverse points (3 points per port, 4 ports were used) were used to complete each test run. Points were located at 6.31, 20.95 and 42.48 inches from the inner wall of the stack. Each method varied in sample run duration.

CTM-013 was sampled at a constant rate and were located at a single point greater than 1 meter from the inner stack wall.

4.2 Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tubes)

Method 2 was used to determine the volumetric flow rate of the stack effluent gas and was used on each isokinetic test method train.

Differential pressure and stack temperature readings were taken with an S type pitot tube and Type K temperature sensor at each sample traverse point.

4.2.1 Method 2 Quality Assurance/Quality Control Procedures

The S type pitot tube was inspected visually and measured to meet the design specifications of EPA Method 2, for a pitot coefficient of 0.84.

The incline manometer and each leg of the pitot tube was leak checked before and immediately after each test run. The incline manometer was leveled and zeroed before each test run.

Thermocouple sensors were calibrated prior to the test program and a post test check was performed after testing completion.

Appendix D contains the completed QA/QC forms.

4.3 Moisture Content Determination

Moisture content of the stack gas was determined by Method 4 with each wet chemistry method.

Stack gas was sampled at each traverse point, passed through pre-weighed impingers and then through a calibrated dry gas meter. Moisture is removed from the sample gas in the pre-weighed impingers, which are submerged in an ice bath, and later analyzed for moisture weight gain. Moisture is determined based upon the amount of moisture weight gain and sample gas collected.

Field moisture data sheets are also located in Appendix E.

4.3.1 Method 4 Quality Assurance/Quality Control Procedures

The moisture sampling train was leak checked prior to each test run at approximately 15" Hg and immediately after each run at a vacuum higher than the highest vacuum recorded during the respective test run. Results are recorded on the moisture field data sheets.

Weighing to determine moisture content was conducted with a balance having an accuracy of 0.1 grams. The scale used to weigh the moisture impingers was checked daily with a 500g class II calibration weight to verify an accuracy of ± 0.5 g.

Gas temperature at the exit of the impingers was maintained at less than 68 degrees Fahrenheit.

4.4 Particulate Matter Determination

USEPA Method 5 was used to determine filterable particulate emissions. Stack gas was extracted isokinetically from the gas stream; particulate emissions are measured gravimetrically by determining the amount of particulate matter collected on the glass nozzle and quartz fiber filter. The probe liner and filter holder were maintained at $320^{\circ}\text{F} \pm 20^{\circ}\text{F}$ during each run.

Sample volume was measured by passing the gas through a set of weighed impingers used for moisture content, then passed through a calibrated dry gas meter. An S type pitot tube is attached to the probe to measure stack gas velocity and to maintain sampling conditions between 90% and 110% isokinetics. A type K temperature sensor is also attached to the probe to measure the stack gas temperature.

Isokinetic conditions were maintained throughout each test run of the test program as demonstrated in Table 5. A minimum of 120 dscf of sample was taken each test run over a sampling period of approximately 240 minutes. Method 5 field data sheets are located in Appendix E.

4.4.1 Sample Recovery and Analysis

After each sample run, the nozzle and filter holder ahead of the filter were brushed and rinsed with acetone. Contents were stored in a leak free container for transport to the laboratory. The impingers were weighed for increase, to the nearest 0.1 gram, to determine moisture gain.

Particulate matter was determined by drying each filter to a constant weight and recorded to the nearest 0.1 mg. Sample from the probe nozzle and filter holder were evaporated in a tared beaker at ambient temperature and dried further in a desiccator then weighed to a constant weight, and recorded to the nearest 0.1 mg.

Appendix E contains the analytical results for each run.

4.4.2 Quality Assurance/Quality Control Procedures

The probe nozzles were inspected and measured across three different diameters to determine the appropriate nozzle diameter.

Before and after each test run, the manometer was leveled and zeroed. Leak checks of the sampling train were conducted before and immediately after each test run.

The dry gas meter was fully calibrated within six months prior to the test program using a set of EPA critical orifices. Post test program dry meter checks were completed to verify the accuracy of the meter's Y_i . Reagent and sample train blanks were collected and analyzed. Completed Method 5/202 QA/QC forms are located in Appendix D.

4.5 Sulfuric Acid Mist (CTM-013)

CTM-013 was used to determine the volume of sulfuric acid mist (SAM) present in the flue gas. Each gas stream was sampled for one hour at a constant sample rate of approximately 10 lpm¹.

¹CTM-013 testing cannot be performed isokinetically since the sample flow rates are too high. This will not allow for enough time for the thermal drop in the sample gas through the condenser.

GREC Biomass Power Plant	Page 8 of 16	C.E.M. Solutions, Inc.
Biomass-fueled BFB Boiler		Report 20-11542-01-001
Compliance Test		Last Updated: 5/1/2017
March 22 - 24, 2017		

The CTM-013 sample train consisting of a quartz glass probe, heated to $600^{\circ}\text{F} \pm 25^{\circ}\text{F}$, a heated quartz filter ($600^{\circ}\text{F} \pm 25^{\circ}\text{F}$) used to filter particulate, a condenser (set to a temperature of $150^{\circ}\text{F} \pm 10^{\circ}\text{F}$) used to condense and capture H_2SO_4 , and a quartz fiber filter used to capture H_2SO_4 . An impinger train, composed of the following impingers, following the condenser. The first two impingers contained 100 ml of deionized water, the third impinger was empty and the final impinger contained a pre-weighed amount of indicating silica gel.

4.5.1 Sample Recovery and Analysis

A 15 minute post-run purge with clean dry ambient air was conducted at the average sampling rate used during the sample run. After the purge, the H_2SO_4 condenser was rinsed multiple times with deionized water. The condenser wash was collected in a laboratory prepared polyethylene sample bottle. The probe and the quartz filter holder were rinsed with DI water and the rinse was discarded.

Appendix E contains the analytical results for each run. The analysis was conducted by Enthalpy Analytical of Durham, North Carolina.

4.5.2 Quality Assurance/Quality Control Procedures

Before and after each test run, the manometer was leveled and zeroed. Leak checks of the sampling train were conducted before and immediately after each test run.

The dry gas meter was fully calibrated within six months prior to the test program using a set of EPA critical orifices. Post test program dry meter checks were completed to verify the accuracy of the meter's Y_i . Reagent and sample train blanks were collected and analyzed. Completed QA/QC forms are located in Appendix D.

4.6 Hydrogen chloride (HCl) and Hydrogen Fluoride (HF)

Hydrogen chloride (HCl) and Hydrogen Fluoride (HF) was determined utilizing a USEPA Modified Method 26 sample train.

Gaseous samples were withdrawn at a constant rate from the duct and collected in absorbing solutions. The particulate matter collected on the filter is recovered to determine the amount of particulate collected during the test run. Acidic absorbing solutions collect the gaseous hydrogen halides (HCl and HF). The hydrogen halides are solubilized in the acidic solution and form chloride. The halide solutions are measured by ion chromatography.

The optional cyclone was not utilized during the test program because liquid droplets in the flue gas stream are not expected.

The sample train consisted of 4 impingers. Impinger 1 and 2 contained 100ml of 0.1N sulfuric acid (H_2SO_4) solution, impingers 3 was empty and impinger 4 contained a pre-weighed amount of silica gel.

The entire sampling train was glass. Temperature requirements of Method 26 were met. Sample analysis was performed by Enthalpy Analytical of Durham, North Carolina. Laboratory results are located in Appendix F.

4.6.1 Quality Assurance/Quality Control Procedures

The probe nozzles were inspected and measured across three different diameters to determine the appropriate nozzle diameter.

Before and after each test run, the manometer was leveled and zeroed. Leak checks of the sampling train were conducted before and immediately after each test run.

The dry gas meter was fully calibrated within six months prior to the test program using a set of EPA critical orifices. Post test program dry meter checks were completed to verify the accuracy of the meter's Y_i . Reagent and sample train blanks were collected and analyzed. Completed QA/QC forms are located in Appendix D.

4.7 Ammonia Slip Test

Ammonia concentrations were determined using EPA Conditional Test Method 27 (CTM-027).

Stack gas-samples were extracted isokinetically, for a period of 60 minutes. Gas samples were pulled from the stack through a glass nozzle and glass lined probe into a heated filter box containing a quartz filter. The gas was then transported, via an unheated Teflon line, to an impinger train. The impinger train consisted of two Greenburg-Smith (G-S) impingers (impingers 1 and 2) and two modified G-S impingers with the tips removed (impingers 3 and 4) all connected in series in an ice bath. Impingers 1 and 2 were charged with 100ml of 0.1N sulfuric acid (H_2SO_4) solution. The third was left empty and the fourth impinger was loaded with a pre-weighed amount of silica gel.

The volume of the liquid (catch) in each of the first three impingers was recorded for future use. Each impinger catch was transferred into individual, clean 500-ml HDPE containers. Each container was then labeled and stored on ice for

shipment to the laboratory, where the samples were analyzed within 2 weeks after their collection.

An ion chromatograph equipped with a conductivity detector was used for ammonium ion separation and quantitation to analyze the samples. At a minimum, the first two impingers were analyzed for ammonia breakthrough. The analysis was conducted by Enthalpy Analytical of Durham, North Carolina.

Pre- and post-impinger weights, field data collection, and lab analysis results are presented in Appendix D.

4.7.1 Quality Assurance/Quality Control Procedures

The sample train was leak checked prior to and following each test run at or above the highest vacuum recorded during the test run in accordance with the test method.

Prior to conducting each test run, the impinger train was chilled in ice for at least 10 minutes as specified in the test method.

All sample train glassware was cleaned prior to each test run with deionized (DI) water.

Following each test run, the back half of the filter housing was rinsed with DI water and stored in the same storage container as the catch from impinger 1. Impingers 1 and 2 were rinsed with DI water after recovery and stored with the impinger catch from its respective impinger as well. Reagent and sample train blanks were collected and analyzed. QA/QC forms can be viewed in Appendix D.

4.8 Mercury Determination

Mercury reference method (RM) data was determined using Method 30B. Data collected by the reference method is compared to the CEMS data when available. Mathematical equations used to determine calculated emissions standards and RATA accuracy are located in Appendix A.

30B sorbent traps were analyzed using a Ohio Lumex Model RA-915+ cold vapor analyzer. All reference method analyzers used meet or exceed applicable performance specifications detailed in the appropriate method.

Mercury emissions were tested using two sample trains simultaneously using a common, dual train sample probe. Gas samples were continuously extracted from the stack through a dry gas meter at a constant rate.

Method 30B field data sheets are located in Appendix D. Approximately 100 liters of sample was collected each test run over a sampling period of approximately 60 minutes.

4.8.1 Sample Recovery and Analysis

After each sample run, the sorbent traps are removed from the probe and transported to a mobile laboratory located at the base of the stack for analysis. The sorbent trap is opened and the contents are analyzed for Mercury concentration. Sorbent traps were analyzed using an Ohio Lumex Mercury RA 915+ analyzer.

The RA-915+ mercury analyzer employs differential atomic absorption spectrometry technique. A glow discharge mercury lamp is placed in a permanent magnetic field, whereby the 254-nm mercury resonance line is split into three polarized components. After passing through a polarization modulator, radiation passes through a multi-path cell equipped with narrow-band high reflectivity mirrors that isolates the 254-nm resonance line. A logarithm of the intensity, which is proportional to the mercury atom concentration in the cell, is determined upon detecting the radiation by a photodetector and subsequent analog-digital conversion of its electric signal by a built-in microprocessor. Outputs are transmitted to a computer for further processing or data storage. Appendix E contains the analytical results for each run.

4.8.2 Sample Recovery and Analysis

All sampling, analytical, and Quality Assurance/Quality Control (QA/QC) procedures outlined in EPA method 30B were followed. The analyzer specific Minimum Detection Limit (MDL) was determined from replicate low level measurements. Mercury (Hg^0) bias tests were conducted at two distinct sorbent trap loads prior to running sample analysis. The minimum sample mass, minimum calibration concentration and target sample volume was determined prior to testing as well. Mercury Analyzer QA/QC sheets are located in Appendix E.

All field test equipment was calibrated before or during use in the field. Leak checks of the sampling train were conducted before and immediately after each test run.

The dry gas meter was fully calibrated within six months prior to the test program using critical orifices. Post test program dry meter checks were completed to verify the accuracy of the meter's Y_i .

Completed QA/QC forms are located in Appendix D.

4.9 Determination of PCDD's and PCDF's

Method 23 was used to determine PCDD/PCDF emissions. Stack gas was extracted isokinetically from the gas stream and collected in the glass nozzle, glass probe liner, glass fiber filter, and on a packed column of absorbent material. The PCDD's and PCDF's are extracted from the sample, separated by high resolution gas chromatography, and measured by high resolution mass spectrometry.

The probe liner and filter heater box temperatures were maintained at 248 ± 25 degrees Fahrenheit throughout each test run. The XAD absorbent module and upstream condenser coil was cooled to below 20°C (68°F) to ensure efficient capture of the PCDD's and PCDF's during each test run by a water recirculating pump.

Sample volume was measured by passing the gas through a set of pre-weighed impingers used for moisture content, then passed through a calibrated dry gas meter. An S type pitot tube is attached to the probe to measure stack gas velocity and to maintain sampling conditions between 90% and 110% isokinetic. A type K temperature sensor is also attached to the probe to measure the stack gas temperature. Isokinetic conditions were maintained throughout each test run of the test program. Appendix D contains completed Method 23 field data sheets.

A minimum of 90.0 dscf of sample was taken each test run over a sampling period of 180 minutes.

After each sample run, the nozzle, probe liner, filter holder, and condenser ahead of the XAD absorbent trap were rinsed and brushed three times with pesticide grade acetone, and toluene. Contents were stored in pre-treated amber leak free containers and environmentally controlled for transport to the laboratory. The impingers were weighed for increase, to the nearest 0.5 gram, to determine moisture gain.

Laboratory analysis was conducted by SGS Analytical of Wilmington, North Carolina.

Appendix F contains the analytical results for each run.

4.9.1 Method 23 Quality Assurance/Quality Control Procedures

All sample glassware in the sampling train upstream and including the XAD resin trap were soaked for several hours in a heated Alconox cleaning solution, rinsed

three times with DI water, Soaked in a heated Chem-Solv cleaning solution, rinsed with tap water, rinsed three times with type-II de-ionized water, rinsed three times with pesticide grade acetone and sealed with Teflon tape and high density aluminum foil treated with pesticide grade hexane. Before initial use in the field, all sample train components upstream of the XAD module were rinsed three times with pesticide grade acetone.

The probe nozzles were inspected and measured across three different diameters to determine the appropriate nozzle diameter.

Before and after each test run, the manometer was leveled and zeroed.

Leak checks of the sampling train were conducted before and immediately after each test run.

The dry gas meter was fully calibrated, within six months prior to the test program, using a set of EPA critical orifices. Post test program dry meter checks were completed to verify the accuracy of the meter's Y_i .

Completed QA/QC forms are located in Appendix C.

4.10 VOC Determination

VOC reference method (RM) data was determined using instrument analyzer procedures. Mathematical equations used to determine calculated emissions standards are located in Appendix B. Table 4 summarizes the EPA methods and instrumentation:

All reference method analyzers used meet or exceed applicable performance specifications detailed in the appropriate method.

VOC and diluent (O_2) gas samples were continuously extracted from the stack by a full extractive gas sample probe (dry basis). Samples were then transported to a gas sample conditioner via a heated sample line operating at 250°F or above. The gas sample conditioner lowers the dew point of the sample gas to approximately 5°C through minimum interference heat exchangers. The dry, cool sample is then sent to the gas analyzers, located in the environmentally controlled test trailer for analysis by the reference method analyzers.

Instrument outputs were recorded continuously with a Windows compatible personal computer, compiled into 15 second averages, and stored in a database for future reference.

Instrument ranges and calibration gases were chosen in accordance with each pollutant's applicable EPA method. Calibration gas Certificates of Analysis can be found in Appendix B.

4.11 Visible Emission Determination

USEPA Method 9 was utilized to determine visible emissions.

Visible emissions observations were performed by a FDEP certified visible emissions reader. Readings were taken at 15 second intervals and reduced into six minute averages as required by the applicable EPA standard. One-sixty minute visible emissions test run was performed while the unit was operating at maximum capacity.

Method 9 data summary, field data and VE reader's certification are located in Appendix E.

5.0 Test Results

The following presents the results of the test program. Supporting calculations and field data summaries are presented in Appendix B and E, respectively. Table 5 summarizes the results of the test program.

**Table 5: Compliance Test Summary
Woody Biomass Power Plant Energy Complex
Woody Biomass-fueled BFB Boiler**

Parameter	Run 1	Run 2	Run 3	Average	Permitted Emissions Rate
FPM	0.0009	0.0009	0.0011	0.0010	0.0098 lb/mmbtu
PM _{2.5}	0.0014	0.0020	0.0028	0.0020	-
VE	0.0	-	-	0.0	10% Opacity
Hg	4.39 x10 ⁻⁷	3.54 x10 ⁻⁷	3.75 x10 ⁻⁷	3.89 x10 ⁻⁷	8.0 X 10 ⁻⁷ lb/mmbtu
SAM	0.1 J	0.1 J	0.1	0.1	1.4 lb/hr
HCl	0.10 J 0.00008 J	0.13 J 0.00011 J	0.11 J 0.00009 J	0.11 0.00009	2.22 lb/hr 0.022 lb/mmbtu
HF	0.05 ND	0.04 ND	0.05 ND	0.05	2.22 lb/hr
VOC	0.000	0.001	0.000	0.000	0.009 lb/mmbtu
NH ₃	0.3	0.3	0.3	0.3	10 ppmvd @ 7% O ₂
D&F	0.02	0.03	0.02	0.02	0.15ng TEQ/dscm @ 7% O ₂

Appendix A: Facility Operating Data

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/22/2017 12:35	9,240	3.49	18,744,000.00	884.32
3/22/2017 12:36	9,240	3.47	18,696,000.00	884.11
3/22/2017 12:37	9,240	3.28	18,468,000.00	883.23
3/22/2017 12:38	9,240	3.44	18,576,000.00	884.96
3/22/2017 12:39	9,240	3.4	18,582,000.00	884.96
3/22/2017 12:40	9,240	3.23	18,354,000.00	885.15
3/22/2017 12:41	9,240	3.15	18,714,000.00	883.64
3/22/2017 12:42	9,240	3.24	18,738,000.00	882.42
3/22/2017 12:43	9,240	3.3	18,744,000.00	882.32
3/22/2017 12:44	9,240	3.17	18,372,000.00	882.4
3/22/2017 12:45	9,240	3.37	18,456,000.00	882.26
3/22/2017 12:46	9,240	3.48	18,588,000.00	882.95
3/22/2017 12:47	9,240	3.5	18,324,000.00	884.41
3/22/2017 12:48	9,240	3.43	18,378,000.00	885.4
3/22/2017 12:49	9,240	3.3	18,282,000.00	885.2
3/22/2017 12:50	9,240	3.26	18,528,000.00	883.67
3/22/2017 12:51	9,240	3.08	18,690,000.00	883.32
3/22/2017 12:52	9,240	3.13	18,942,000.00	882.72
3/22/2017 12:53	9,240	3.36	18,822,000.00	882.02
3/22/2017 12:54	9,240	3.56	19,008,000.00	882.81
3/22/2017 12:55	9,240	3.58	18,972,000.00	883.55
3/22/2017 12:56	9,240	3.52	18,540,000.00	884.27
3/22/2017 12:57	9,240	3.63	18,912,000.00	884.77
3/22/2017 12:58	9,240	3.5	18,852,000.00	884.08
3/22/2017 12:59	9,240	3.61	18,786,000.00	883.34
3/22/2017 13:00	9,240	3.7	18,636,000.00	883.9
3/22/2017 13:01	9,240	3.78	18,858,000.00	884.86
3/22/2017 13:02	9,240	3.74	18,102,000.00	885.26
3/22/2017 13:03	9,240	3.68	18,804,000.00	885.5
3/22/2017 13:04	9,240	3.45	18,576,000.00	885.67
3/22/2017 13:05	9,240	3.4	18,834,000.00	885.11
3/22/2017 13:06	9,240	3.2	19,008,000.00	884.04
3/22/2017 13:07	9,240	3.38	18,666,000.00	881.36
3/22/2017 13:08	9,240	3.52	18,744,000.00	882.46
3/22/2017 13:09	9,240	3.6	18,984,000.00	882.33
3/22/2017 13:10	9,240	3.58	18,480,000.00	881.93
3/22/2017 13:11	9,240	3.68	18,828,000.00	882.95
3/22/2017 13:12	9,240	3.8	19,002,000.00	882.92
3/22/2017 13:13	9,240	3.68	18,720,000.00	882.9
3/22/2017 13:14	9,240	3.51	18,408,000.00	884.21
3/22/2017 13:15	9,240	3.33	18,498,000.00	884.39
3/22/2017 13:16	9,240	3.42	18,258,000.00	884.26
3/22/2017 13:17	9,240	3.45	18,192,000.00	883.8
3/22/2017 13:18	9,240	3.56	18,120,000.00	884.59
3/22/2017 13:19	9,240	3.23	18,294,000.00	884.75
3/22/2017 13:20	9,240	3.15	18,612,000.00	884.48
3/22/2017 13:21	9,240	3.23	18,720,000.00	884.39
3/22/2017 13:22	9,240	3.36	18,258,000.00	883.77
3/22/2017 13:23	9,240	3.42	18,630,000.00	884.4
3/22/2017 13:24	9,240	3.44	19,086,000.00	883.85
3/22/2017 13:25	9,240	3.52	18,510,000.00	883.87
3/22/2017 13:26	9,240	3.52	18,978,000.00	884.21
3/22/2017 13:27	9,240	3.68	18,462,000.00	884.77
3/22/2017 13:28	9,240	3.46	18,474,000.00	884.19
3/22/2017 13:29	9,240	3.43	18,264,000.00	883.26
3/22/2017 13:30	9,240	3.54	18,768,000.00	882.77
3/22/2017 13:31	9,240	3.53	18,330,000.00	883.09
3/22/2017 13:32	9,240	3.6	18,420,000.00	882.94
3/22/2017 13:33	9,240	3.42	18,144,000.00	883.29
3/22/2017 13:34	9,240	3.4	18,198,000.00	882.92
3/22/2017 13:35	9,240	3.32	18,378,000.00	882.33
3/22/2017 13:36	9,240	3.3	17,964,000.00	882.51
3/22/2017 13:37	9,240	3.39	17,988,000.00	881.84
3/22/2017 13:38	9,240	3.3	17,922,000.00	882.27
3/22/2017 13:39	9,240	3.28	17,706,000.00	882.92
3/22/2017 13:40	9,240	3.32	17,700,000.00	883.23
3/22/2017 13:41	9,240	3.19	18,012,000.00	884.33
3/22/2017 13:42	9,240	3.25	18,144,000.00	884.66

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/22/2017 13:43	9,240	3.19	17,736,000.00	884.72
3/22/2017 13:44	9,240	3.44	18,366,000.00	884.86
3/22/2017 13:45	9,240	3.29	18,516,000.00	884.54
3/22/2017 13:46	9,240	3.28	18,408,000.00	884.85
3/22/2017 13:47	9,240	3.48	18,444,000.00	884.51
3/22/2017 13:48	9,240	3.47	18,582,000.00	884.53
3/22/2017 13:49	9,240	3.8	18,720,000.00	883.28
3/22/2017 13:50	9,240	3.88	18,660,000.00	883.59
3/22/2017 13:51	9,240	3.58	18,552,000.00	884.35
3/22/2017 13:52	9,240	3.54	18,870,000.00	884.38
3/22/2017 13:53	9,240	3.47	18,708,000.00	883.51
3/22/2017 13:54	9,240	3.56	18,480,000.00	883.18
3/22/2017 13:55	9,240	3.39	18,054,000.00	882.4
3/22/2017 13:56	9,240	3.44	18,240,000.00	881.96
3/22/2017 13:57	9,240	3.46	18,018,000.00	883
3/22/2017 13:58	9,240	3.47	17,694,000.00	883.61
3/22/2017 13:59	9,240	3.47	17,706,000.00	883.58
3/22/2017 14:00	9,240	3.42	17,994,000.00	884.86
3/22/2017 14:01	9,240	3.29	17,868,000.00	885.65
3/22/2017 14:02	9,240	3.28	17,904,000.00	886.53
3/22/2017 14:03	9,240	3.07	17,676,000.00	887.06
3/22/2017 14:04	9,240	2.93	17,748,000.00	885.69
3/22/2017 14:05	9,240	3.16	17,826,000.00	884.51
3/22/2017 14:06	9,240	3.01	18,390,000.00	885.33
3/22/2017 14:07	9,240	3.12	18,450,000.00	883.54
3/22/2017 14:08	9,240	3.13	18,624,000.00	882.36
3/22/2017 14:09	9,240	3.4	18,300,000.00	882.65
3/22/2017 14:10	9,240	3.59	18,240,000.00	882.92
3/22/2017 14:11	9,240	3.78	18,318,000.00	883.25
3/22/2017 14:12	9,240	3.49	18,048,000.00	883.27
3/22/2017 14:13	9,240	3.43	17,706,000.00	884.05
3/22/2017 14:14	9,240	3.49	17,886,000.00	884.02
3/22/2017 14:15	9,240	3.37	17,904,000.00	883.47
3/22/2017 14:16	9,240	3.26	17,634,000.00	883.05
3/22/2017 14:17	9,240	3.36	17,682,000.00	884.46
3/22/2017 14:18	9,240	3.3	17,898,000.00	883.86
3/22/2017 14:19	9,240	3.14	18,036,000.00	883.81
3/22/2017 14:20	9,240	3.27	17,988,000.00	884.21
3/22/2017 14:21	9,240	3.41	18,078,000.00	885.14
3/22/2017 14:22	9,240	3.51	17,634,000.00	885.07
3/22/2017 14:23	9,240	3.25	17,940,000.00	884.93
3/22/2017 14:24	9,240	3.32	18,000,000.00	885.01
3/22/2017 14:25	9,240	3.44	17,916,000.00	884.17
3/22/2017 14:26	9,240	3.49	18,042,000.00	883.42
3/22/2017 14:27	9,240	3.76	18,462,000.00	883.42
3/22/2017 14:28	9,240	3.73	18,408,000.00	883.07
3/22/2017 14:29	9,240	3.73	18,396,000.00	883.5
3/22/2017 14:30	9,240	3.54	18,564,000.00	883.58
3/22/2017 14:31	9,240	3.54	18,492,000.00	883
3/22/2017 14:32	9,240	3.54	18,132,000.00	883.38
3/22/2017 14:33	9,240	3.56	18,366,000.00	882.59
3/22/2017 14:34	9,240	3.52	18,198,000.00	882.39
3/22/2017 14:35	9,240	3.32	18,096,000.00	882.49
3/22/2017 14:36	9,240	3.44	17,628,000.00	882.81
3/22/2017 14:37	9,240	3.4	17,964,000.00	882.7
3/22/2017 14:38	9,240	3.19	17,754,000.00	883.71
3/22/2017 14:39	9,240	3.21	17,250,000.00	884.14
3/22/2017 14:40	9,240	3.15	17,850,000.00	884.17
3/22/2017 14:41	9,240	3.26	17,790,000.00	884.79
3/22/2017 14:42	9,240	3.22	18,198,000.00	884.6
3/22/2017 14:43	9,240	3.16	18,066,000.00	884.51
3/22/2017 14:44	9,240	3.24	18,096,000.00	884.31
3/22/2017 14:45	9,240	3.16	18,492,000.00	883.42
3/22/2017 14:46	9,240	3.4	18,018,000.00	882.7
3/22/2017 14:47	9,240	3.36	18,504,000.00	882.29
3/22/2017 14:48	9,240	3.52	18,258,000.00	881.21
3/22/2017 14:49	9,240	3.7	18,132,000.00	881.43
3/22/2017 14:50	9,240	3.66	18,090,000.00	881.77

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/22/2017 14:51	9,240	3.51	18,114,000.00	882.54
3/22/2017 14:52	9,240	3.29	18,258,000.00	882.59
3/22/2017 14:53	9,240	3.3	17,808,000.00	882.04
3/22/2017 14:54	9,240	3.44	17,364,000.00	882.3
3/22/2017 14:55	9,240	3.26	17,652,000.00	883.87
3/22/2017 14:56	9,240	3.11	17,736,000.00	884.11
3/22/2017 14:57	9,240	2.99	17,592,000.00	884.15
3/22/2017 14:58	9,240	3.05	17,268,000.00	884.74
3/22/2017 14:59	9,240	3.11	17,856,000.00	885.86
3/22/2017 15:00	9,240	3.17	17,826,000.00	884.14
3/22/2017 15:01	9,240	3.14	17,766,000.00	883.27
3/22/2017 15:02	9,240	3.19	18,414,000.00	883.16
3/22/2017 15:03	9,240	3.21	18,186,000.00	883.49
3/22/2017 15:04	9,240	3.36	18,546,000.00	882.43
3/22/2017 15:05	9,240	3.44	18,390,000.00	881.52
3/22/2017 15:06	9,240	3.43	18,600,000.00	881.86
3/22/2017 15:07	9,240	3.4	18,546,000.00	881.01
3/22/2017 15:08	9,240	3.64	17,982,000.00	881.32
3/22/2017 15:09	9,240	3.66	18,024,000.00	881.86
3/22/2017 15:10	9,240	3.51	17,706,000.00	881.64
3/22/2017 15:11	9,240	3.38	17,586,000.00	882.2
3/22/2017 15:12	9,240	3.38	17,754,000.00	883.2
3/22/2017 15:13	9,240	3.22	17,910,000.00	882.55
3/22/2017 15:14	9,240	3.13	17,916,000.00	883.28
3/22/2017 15:15	9,240	3.24	18,138,000.00	882.87
3/22/2017 15:16	9,240	3.02	18,330,000.00	882.16
3/22/2017 15:17	9,240	3.08	18,294,000.00	881.39
3/22/2017 15:18	9,240	3.38	18,276,000.00	881.73
3/22/2017 15:19	9,240	3.37	18,726,000.00	881.72
3/22/2017 15:20	9,240	3.39	18,588,000.00	880.95
3/22/2017 15:21	9,240	3.56	18,384,000.00	880.61
3/22/2017 15:22	9,240	3.64	18,138,000.00	881.2
3/22/2017 15:23	9,240	3.55	17,988,000.00	880.54
3/22/2017 15:24	9,240	3.38	17,664,000.00	880.78
3/22/2017 15:25	9,240	3.52	18,102,000.00	882.1
3/22/2017 15:26	9,240	3.26	17,886,000.00	881.38
3/22/2017 15:27	9,240	3.06	18,054,000.00	880.64
3/22/2017 15:28	9,240	3.09	17,868,000.00	880.69
3/22/2017 15:29	9,240	3.18	18,030,000.00	880.61
3/22/2017 15:30	9,240	3.3	18,210,000.00	880.86
3/22/2017 15:31	9,240	3.26	17,610,000.00	880.75
3/22/2017 15:32	9,240	3.22	17,814,000.00	882.13
3/22/2017 15:33	9,240	3.18	17,592,000.00	882.57
3/22/2017 15:34	9,240	3.3	17,994,000.00	882.95
3/22/2017 15:35	9,240	3.24	17,844,000.00	883.14
3/22/2017 15:36	9,240	3.27	17,910,000.00	882.7
3/22/2017 15:37	9,240	3.33	17,988,000.00	882.31
3/22/2017 15:38	9,240	3.5	17,766,000.00	880.55
3/22/2017 15:39	9,240	3.56	17,982,000.00	881.96
3/22/2017 15:40	9,240	3.58	18,468,000.00	882.81
3/22/2017 15:41	9,240	3.72	18,492,000.00	882.46
3/22/2017 15:42	9,240	3.66	18,678,000.00	881.69
3/22/2017 15:43	9,240	3.74	18,540,000.00	881.68
3/22/2017 15:44	9,240	3.63	18,600,000.00	881.92
3/22/2017 15:45	9,240	3.31	18,912,000.00	881.16
3/22/2017 15:46	9,240	3.46	18,474,000.00	879.27
3/22/2017 15:47	9,240	3.71	18,594,000.00	878.75
3/22/2017 15:48	9,240	3.65	18,474,000.00	880.08
3/22/2017 15:49	9,240	3.56	17,940,000.00	879.46
3/22/2017 15:50	9,240	3.39	17,466,000.00	880.05
3/22/2017 15:51	9,240	3.51	17,436,000.00	882.03
3/22/2017 15:52	9,240	3.26	17,328,000.00	882.39
3/22/2017 15:53	9,240	3.1	17,526,000.00	882.74
3/22/2017 15:54	9,240	2.92	17,412,000.00	882.74
3/22/2017 15:55	9,240	2.97	17,754,000.00	882.97
3/22/2017 15:56	9,240	3.17	17,922,000.00	881.64
3/22/2017 15:57	9,240	3.26	17,826,000.00	881.88
3/22/2017 15:58	9,240	3.3	17,892,000.00	882.98

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/22/2017 15:59	9,240	3.33	18,048,000.00	882.59
3/22/2017 16:00	9,240	3.51	17,994,000.00	882.91
3/22/2017 16:01	9,240	3.51	18,126,000.00	882.64
3/22/2017 16:02	9,240	3.48	18,300,000.00	881.95
3/22/2017 16:03	9,240	3.58	18,816,000.00	881.95
3/22/2017 16:04	9,240	3.5	18,234,000.00	881.36
3/22/2017 16:05	9,240	3.48	18,864,000.00	881.17
3/22/2017 16:06	9,240	3.58	18,396,000.00	880.6
3/22/2017 16:07	9,240	3.72	18,312,000.00	879.77
3/22/2017 16:08	9,240	3.7	18,204,000.00	880.39
3/22/2017 16:09	9,240	3.61	18,258,000.00	880.52
3/22/2017 16:10	9,240	3.51	18,210,000.00	881.13
3/22/2017 16:11	9,240	3.5	17,904,000.00	880.5
3/22/2017 16:12	9,240	3.31	18,180,000.00	880.33
3/22/2017 16:13	9,240	3.36	17,736,000.00	880.55
3/22/2017 16:14	9,240	3.39	17,688,000.00	880.85
3/22/2017 16:15	9,240	3.25	17,634,000.00	881.31
3/22/2017 16:16	9,240	3.34	17,646,000.00	882.78
3/22/2017 16:17	9,240	3.41	17,472,000.00	883.99
3/22/2017 16:18	9,240	3.19	17,424,000.00	884.84
3/22/2017 16:19	9,240	3.08	17,484,000.00	884.11
3/22/2017 16:20	9,240	3.09	17,646,000.00	883.64
3/22/2017 16:21	9,240	3.2	18,078,000.00	884.03
3/22/2017 16:22	9,240	3.31	18,258,000.00	881.79
3/22/2017 16:23	9,240	3.3	18,216,000.00	881.49
3/22/2017 16:24	9,240	3.38	18,378,000.00	883.36
3/22/2017 16:25	9,240	3.45	18,084,000.00	882.89
3/22/2017 16:26	9,240	3.52	18,552,000.00	881.99
3/22/2017 16:27	9,240	3.66	18,564,000.00	882.38
3/22/2017 16:28	9,240	3.57	18,180,000.00	883.81
3/22/2017 16:29	9,240	3.57	18,252,000.00	883.17
3/22/2017 16:30	9,240	3.6	18,294,000.00	882.46
3/22/2017 16:31	9,240	3.44	17,880,000.00	882.71
3/22/2017 16:32	9,240	3.52	18,306,000.00	883.53
3/22/2017 16:33	9,240	3.4	18,120,000.00	883.34
3/22/2017 16:34	9,240	3.18	18,072,000.00	882.23
3/22/2017 16:35	9,240	3.41	17,952,000.00	882.18
3/22/2017 16:36	9,240	3.55	17,844,000.00	883.68
3/22/2017 16:37	9,240	3.6	17,832,000.00	883.61
3/22/2017 16:38	9,240	3.36	17,748,000.00	882.58
3/22/2017 16:39	9,240	3.19	17,976,000.00	883.63
3/22/2017 16:40	9,240	3.38	17,952,000.00	883.91
3/22/2017 16:41	9,240	3.19	18,072,000.00	883.15
3/22/2017 16:42	9,240	3.1	18,258,000.00	882.33
3/22/2017 16:43	9,240	3.21	18,228,000.00	882.22
3/22/2017 16:44	9,240	3.45	17,988,000.00	881.68
3/22/2017 16:45	9,240	3.44	18,282,000.00	881.98
3/22/2017 16:46	9,240	3.46	17,952,000.00	881.65
3/22/2017 16:47	9,240	3.62	18,228,000.00	882.95
3/22/2017 16:48	9,240	3.51	17,874,000.00	883.95
3/22/2017 16:49	9,240	3.48	17,970,000.00	883.27
3/22/2017 16:50	9,240	3.36	17,982,000.00	882.74
3/22/2017 16:51	9,240	3.32	18,312,000.00	882.6
3/22/2017 16:52	9,240	3.41	18,108,000.00	881.93
3/22/2017 16:53	9,240	3.32	18,036,000.00	881.97
3/22/2017 16:54	9,240	3.47	18,132,000.00	882.08
3/22/2017 16:55	9,240	3.51	18,036,000.00	881.7
3/22/2017 16:56	9,240	3.34	18,300,000.00	882.58
3/22/2017 16:57	9,240	3.23	18,414,000.00	882.08
3/22/2017 16:58	9,240	3.19	17,922,000.00	882.04
3/22/2017 16:59	9,240	3.22	17,838,000.00	881.37
3/22/2017 17:00	9,240	3.47	17,538,000.00	881.54
3/22/2017 17:01	9,240	3.48	17,772,000.00	882.11
3/22/2017 17:02	9,240	3.51	17,934,000.00	883.06
3/22/2017 17:03	9,240	3.42	17,664,000.00	883.57
3/22/2017 17:04	9,240	3.27	17,838,000.00	883.38
3/22/2017 17:05	9,240	3.29	18,234,000.00	882.68
3/22/2017 17:06	9,240	3.13	18,138,000.00	882.35

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/22/2017 17:07	9,240	3.15	18,186,000.00	881.95
3/22/2017 17:08	9,240	3.17	18,192,000.00	881.14
3/22/2017 17:09	9,240	3.18	18,090,000.00	880.22
3/22/2017 17:10	9,240	3.32	18,168,000.00	879.76
3/22/2017 17:11	9,240	3.59	18,084,000.00	879.98
3/22/2017 17:12	9,240	3.72	18,030,000.00	880.93
3/22/2017 17:13	9,240	3.77	18,096,000.00	880.74
3/22/2017 17:14	9,240	3.6	17,880,000.00	881.39
3/22/2017 17:15	9,240	3.45	17,970,000.00	882.85
3/22/2017 17:16	9,240	3.45	17,886,000.00	882.83
3/22/2017 17:17	9,240	3.26	17,910,000.00	882.56
3/22/2017 17:18	9,240	3.12	17,694,000.00	881.27
3/22/2017 17:19	9,240	3.11	18,258,000.00	881.73
3/22/2017 17:20	9,240	3.15	17,526,000.00	880.43
3/22/2017 17:21	9,240	3.18	18,066,000.00	880.2
3/22/2017 17:22	9,240	3.17	18,060,000.00	879.68
3/22/2017 17:23	9,240	3.5	17,796,000.00	880.08
3/22/2017 17:24	9,240	3.67	17,868,000.00	881.6
3/22/2017 17:25	9,240	3.56	18,348,000.00	881.68
3/22/2017 17:26	9,240	3.49	17,994,000.00	881.73
3/22/2017 17:27	9,240	3.46	18,168,000.00	882.25
3/22/2017 17:28	9,240	3.44	17,562,000.00	882.09
3/22/2017 17:29	9,240	3.4	18,120,000.00	881.94
3/22/2017 17:30	9,240	3.38	18,126,000.00	882.18
3/22/2017 17:31	9,240	3.3	18,024,000.00	880.97
3/22/2017 17:32	9,240	3.43	18,510,000.00	881.09
3/22/2017 17:33	9,240	3.32	18,240,000.00	880.66
3/22/2017 17:34	9,240	3.36	18,084,000.00	880.69
3/22/2017 17:35	9,240	3.22	18,240,000.00	880.89
3/22/2017 17:36	9,240	3.31	18,288,000.00	879.54
3/22/2017 17:37	9,240	3.35	17,946,000.00	880.06
3/22/2017 17:38	9,240	3.39	18,120,000.00	880.3
3/22/2017 17:39	9,240	3.34	18,048,000.00	880.44
3/22/2017 17:40	9,240	3.32	18,336,000.00	879.98
3/22/2017 17:41	9,240	3.33	17,880,000.00	879.02
3/22/2017 17:42	9,240	3.32	17,844,000.00	879.92
3/22/2017 17:43	9,240	3.4	18,216,000.00	879.89
3/22/2017 17:44	9,240	3.34	17,808,000.00	879.41
3/22/2017 17:45	9,240	3.2	17,952,000.00	880.29
3/22/2017 17:46	9,240	3.09	18,036,000.00	880.25
3/22/2017 17:47	9,240	3.07	17,976,000.00	879.14
3/22/2017 17:48	9,240	3.03	18,246,000.00	878.18
3/22/2017 17:49	9,240	3.12	18,132,000.00	879.2
3/22/2017 17:50	9,240	3.28	18,312,000.00	879
3/22/2017 17:51	9,240	3.2	18,306,000.00	878.47
3/22/2017 17:52	9,240	3.31	18,210,000.00	878.9
3/22/2017 17:53	9,240	3.51	18,360,000.00	879.73
3/22/2017 17:54	9,240	3.37	18,258,000.00	880.17
3/22/2017 17:55	9,240	3.3	18,312,000.00	878.56
3/22/2017 17:56	9,240	3.49	18,132,000.00	878.38
3/22/2017 17:57	9,240	3.52	17,964,000.00	879.67
3/22/2017 17:58	9,240	3.37	18,054,000.00	879.22
3/22/2017 17:59	9,240	3.46	18,024,000.00	878.98
3/22/2017 18:00	9,240	3.58	18,216,000.00	880.08
3/22/2017 18:01	9,240	3.34	17,940,000.00	880.36
3/22/2017 18:02	9,240	3.32	18,354,000.00	879.93
3/22/2017 18:03	9,240	3.37	18,444,000.00	879.64
3/22/2017 18:04	9,240	3.22	18,342,000.00	880.15
3/22/2017 18:05	9,240	3.17	18,396,000.00	879.46
3/22/2017 18:06	9,240	3.13	18,270,000.00	878.99
3/22/2017 18:07	9,240	3.18	18,066,000.00	878.98
3/22/2017 18:08	9,240	3.27	18,234,000.00	879.73
3/22/2017 18:09	9,240	3.37	18,582,000.00	879.9
3/22/2017 18:10	9,240	3.38	18,144,000.00	879.29
3/22/2017 18:11	9,240	3.2	18,564,000.00	879.64
3/22/2017 18:12	9,240	3.23	18,504,000.00	880.07
3/22/2017 18:13	9,240	3.18	18,204,000.00	879.98
3/22/2017 18:14	9,240	3.36	18,348,000.00	879.16

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/22/2017 18:15	9,240	3.43	18,504,000.00	880.07
3/22/2017 18:16	9,240	3.39	18,192,000.00	880.57
3/22/2017 18:17	9,240	3.25	18,366,000.00	880.92
3/22/2017 18:18	9,240	3.4	18,432,000.00	881.95
3/22/2017 18:19	9,240	3.13	18,072,000.00	881.36
3/22/2017 18:20	9,240	3.1	18,462,000.00	880.81
3/22/2017 18:21	9,240	3.36	18,504,000.00	880.32
3/22/2017 18:22	9,240	3.42	18,474,000.00	881.27
3/22/2017 18:23	9,240	3.45	18,888,000.00	880.53
3/22/2017 18:24	9,240	3.41	18,510,000.00	880.2
3/22/2017 18:25	9,240	3.46	18,888,000.00	880.65
3/22/2017 18:26	9,240	3.4	18,528,000.00	881.39
3/22/2017 18:27	9,240	3.41	18,672,000.00	880.46
3/22/2017 18:28	9,240	3.54	19,032,000.00	879.23
3/22/2017 18:29	9,240	3.56	18,846,000.00	880.33
3/22/2017 18:30	9,240	3.7	19,278,000.00	880.8
3/22/2017 18:31	9,240	3.54	18,750,000.00	880.66
3/22/2017 18:32	9,240	3.43	18,744,000.00	879.83
3/22/2017 18:33	9,240	3.38	18,456,000.00	879.52
3/22/2017 18:34	9,240	3.38	18,546,000.00	878.2
3/22/2017 18:35	9,240	3.49	18,516,000.00	877.86
3/22/2017 18:36	9,240	3.38	18,054,000.00	879.32
3/22/2017 18:37	9,240	3.29	18,372,000.00	880.02
3/22/2017 18:38	9,240	3.21	17,934,000.00	879.49
3/22/2017 18:39	9,240	3.14	18,432,000.00	879.64
3/22/2017 18:40	9,240	3.25	17,826,000.00	880.91
3/22/2017 18:41	9,240	3.22	18,366,000.00	880.92
3/22/2017 18:42	9,240	3.29	17,988,000.00	880.76
3/22/2017 18:43	9,240	3.21	18,582,000.00	880.93
3/22/2017 18:44	9,240	3.34	18,234,000.00	881.78
3/22/2017 18:45	9,240	3.37	18,708,000.00	881.89
3/22/2017 18:46	9,240	3.33	18,990,000.00	880.5
3/22/2017 18:47	9,240	3.36	18,810,000.00	880.11
3/22/2017 18:48	9,240	3.37	18,774,000.00	880.05
3/22/2017 18:49	9,240	3.62	18,654,000.00	879.67
3/22/2017 18:50	9,240	3.7	19,284,000.00	879.77
3/22/2017 18:51	9,240	3.64	18,570,000.00	880.51
3/22/2017 18:52	9,240	3.64	18,528,000.00	880.63
3/22/2017 18:53	9,240	3.58	18,624,000.00	880.75
3/22/2017 18:54	9,240	3.57	18,654,000.00	880.78
3/22/2017 18:55	9,240	3.47	18,198,000.00	880.51
3/22/2017 18:56	9,240	3.34	18,594,000.00	880.41
3/22/2017 18:57	9,240	3.35	18,516,000.00	880.29
3/22/2017 18:58	9,240	3.45	18,690,000.00	880.78
3/22/2017 18:59	9,240	3.43	18,552,000.00	880.55
3/22/2017 19:00	9,240	3.56	18,372,000.00	880.55
3/22/2017 19:01	9,240	3.54	18,552,000.00	882.03
3/22/2017 19:02	9,240	3.43	18,426,000.00	882.44
3/22/2017 19:03	9,240	3.22	18,576,000.00	882
3/22/2017 19:04	9,240	3.17	18,306,000.00	880.3
3/22/2017 19:05	9,240	3.34	18,864,000.00	879.89
3/22/2017 19:06	9,240	3.32	18,486,000.00	879.64
3/22/2017 19:07	9,240	3.57	18,696,000.00	879.98
3/22/2017 19:08	9,240	3.52	18,984,000.00	879.33
3/22/2017 19:09	9,240	3.43	18,756,000.00	879.53
3/22/2017 19:10	9,240	3.59	18,906,000.00	880.21
3/22/2017 19:11	9,240	3.41	18,558,000.00	879.98
3/22/2017 19:12	9,240	3.48	18,192,000.00	879.54
3/22/2017 19:13	9,240	3.48	18,624,000.00	879.58
3/22/2017 19:14	9,240	3.39	18,486,000.00	879.37
3/22/2017 19:15	9,240	3.44	18,066,000.00	879.71
3/22/2017 19:16	9,240	3.45	18,366,000.00	879.15
3/22/2017 19:17	9,240	3.42	18,234,000.00	879.44
3/22/2017 19:18	9,240	3.35	18,216,000.00	880.26
				882.09
3/23/2017 7:23	9,240	3.52	18,204,000.00	859.79

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/23/2017 7:24	9,240	3.36	18,036,000.00	859.03
3/23/2017 7:25	9,240	3.36	17,970,000.00	857.53
3/23/2017 7:26	9,240	3.52	18,024,000.00	856.81
3/23/2017 7:27	9,240	3.79	18,474,000.00	857.23
3/23/2017 7:28	9,240	3.72	18,228,000.00	856.91
3/23/2017 7:29	9,240	3.84	18,018,000.00	857.54
3/23/2017 7:30	9,240	3.72	17,832,000.00	858.59
3/23/2017 7:31	9,240	3.48	18,060,000.00	858.12
3/23/2017 7:32	9,240	3.33	17,772,000.00	857.34
3/23/2017 7:33	9,240	3.25	17,532,000.00	857.08
3/23/2017 7:34	9,240	3.47	17,784,000.00	856.24
3/23/2017 7:35	9,240	3.45	17,724,000.00	856.37
3/23/2017 7:36	9,240	3.46	17,544,000.00	856.66
3/23/2017 7:37	9,240	3.43	17,622,000.00	856.76
3/23/2017 7:38	9,240	3.36	17,550,000.00	857.76
3/23/2017 7:39	9,240	3.04	17,706,000.00	857.4
3/23/2017 7:40	9,240	3.12	17,586,000.00	856.68
3/23/2017 7:41	9,240	3.29	17,322,000.00	856.14
3/23/2017 7:42	9,240	3.57	17,478,000.00	856.22
3/23/2017 7:43	9,240	3.42	17,544,000.00	856.39
3/23/2017 7:44	9,240	3.37	17,862,000.00	857.2
3/23/2017 7:45	9,240	3.25	17,694,000.00	857.35
3/23/2017 7:46	9,240	3.17	17,652,000.00	855.75
3/23/2017 7:47	9,240	3.4	17,496,000.00	855.02
3/23/2017 7:48	9,240	3.49	18,294,000.00	855.29
3/23/2017 7:49	9,240	3.43	18,042,000.00	854.55
3/23/2017 7:50	9,240	3.32	17,742,000.00	853.9
3/23/2017 7:51	9,240	3.44	17,574,000.00	853.69
3/23/2017 7:52	9,240	3.63	17,760,000.00	853.9
3/23/2017 7:53	9,240	3.57	18,060,000.00	853.71
3/23/2017 7:54	9,240	3.52	18,162,000.00	853.13
3/23/2017 7:55	9,240	3.38	17,922,000.00	852.55
3/23/2017 7:56	9,240	3.54	17,760,000.00	851.61
3/23/2017 7:57	9,240	3.5	17,526,000.00	852.42
3/23/2017 7:58	9,240	3.42	17,556,000.00	853.39
3/23/2017 7:59	9,240	3.13	17,274,000.00	853.07
3/23/2017 8:00	9,240	3.25	17,010,000.00	853.33
3/23/2017 8:01	9,240	3.3	17,298,000.00	853.95
3/23/2017 8:02	9,240	3.23	17,448,000.00	854.12
3/23/2017 8:03	9,240	3.35	16,998,000.00	853.84
3/23/2017 8:04	9,240	3.24	17,112,000.00	853.76
3/23/2017 8:05	9,240	3.38	17,814,000.00	853.44
3/23/2017 8:06	9,240	3.46	17,922,000.00	854.47
3/23/2017 8:07	9,240	3.36	17,832,000.00	854.66
3/23/2017 8:08	9,240	3.25	17,814,000.00	853.54
3/23/2017 8:09	9,240	3.64	17,850,000.00	852.4
3/23/2017 8:10	9,240	3.62	17,808,000.00	852.53
3/23/2017 8:11	9,240	3.83	17,886,000.00	853.04
3/23/2017 8:12	9,240	3.85	17,994,000.00	853.85
3/23/2017 8:13	9,240	3.68	18,114,000.00	853.89
3/23/2017 8:14	9,240	3.54	17,592,000.00	853.4
3/23/2017 8:15	9,240	3.39	17,694,000.00	852.91
3/23/2017 8:16	9,240	3.52	17,724,000.00	853.01
3/23/2017 8:17	9,240	3.62	17,382,000.00	853.69
3/23/2017 8:18	9,240	3.51	17,910,000.00	853.25
3/23/2017 8:19	9,240	3.19	17,742,000.00	853.07
3/23/2017 8:20	9,240	3.19	17,256,000.00	853.47
3/23/2017 8:21	9,240	3.2	17,148,000.00	851.56
3/23/2017 8:22	9,240	3.38	17,118,000.00	850.87
3/23/2017 8:23	9,240	3.54	17,706,000.00	853.01
3/23/2017 8:24	9,240	3.3	17,436,000.00	856.32
3/23/2017 8:25	9,240	3.25	17,718,000.00	856.01
3/23/2017 8:26	9,240	3	17,574,000.00	855.32
3/23/2017 8:27	9,240	3.04	17,574,000.00	855.59
3/23/2017 8:28	9,240	3.13	17,484,000.00	855.61
3/23/2017 8:29	9,240	3.29	17,610,000.00	854.13
3/23/2017 8:30	9,240	3.48	18,420,000.00	854.3
3/23/2017 8:31	9,240	3.42	17,940,000.00	854.47

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/23/2017 8:32	9,240	3.68	17,826,000.00	855.35
3/23/2017 8:33	9,240	3.53	18,156,000.00	854.19
3/23/2017 8:34	9,240	3.42	18,204,000.00	854.41
3/23/2017 8:35	9,240	3.59	18,204,000.00	854.81
3/23/2017 8:36	9,240	3.64	17,748,000.00	853.35
3/23/2017 8:37	9,240	3.46	18,144,000.00	851.55
3/23/2017 8:38	9,240	3.54	17,970,000.00	852.38
3/23/2017 8:39	9,240	3.38	17,760,000.00	853.58
3/23/2017 8:40	9,240	3.3	17,628,000.00	853.08
3/23/2017 8:41	9,240	3.37	17,676,000.00	852.52
3/23/2017 8:42	9,240	3.38	17,796,000.00	852.82
3/23/2017 8:43	9,240	3.31	17,250,000.00	854.41
3/23/2017 8:44	9,240	3.12	16,872,000.00	854.45
3/23/2017 8:45	9,240	3.18	16,878,000.00	854.39
3/23/2017 8:46	9,240	3.12	17,268,000.00	855.05
3/23/2017 8:47	9,240	3.19	17,526,000.00	855.67
3/23/2017 8:48	9,240	3.06	17,292,000.00	855.57
3/23/2017 8:49	9,240	2.94	17,382,000.00	854.4
3/23/2017 8:50	9,240	3	17,460,000.00	854.19
3/23/2017 8:51	9,240	3.38	17,532,000.00	854.03
3/23/2017 8:52	9,240	3.51	17,754,000.00	854.07
3/23/2017 8:53	9,240	3.46	17,568,000.00	854.56
3/23/2017 8:54	9,240	3.53	17,742,000.00	855.7
3/23/2017 8:55	9,240	3.38	17,748,000.00	855.5
3/23/2017 8:56	9,240	3.35	17,922,000.00	854.52
3/23/2017 8:57	9,240	3.23	17,988,000.00	853.87
3/23/2017 8:58	9,240	3.58	17,640,000.00	853.36
3/23/2017 8:59	9,240	3.69	18,078,000.00	852.74
3/23/2017 9:00	9,240	3.72	17,760,000.00	853.25
3/23/2017 9:01	9,240	3.56	18,042,000.00	854.45
3/23/2017 9:02	9,240	3.28	18,114,000.00	854.02
3/23/2017 9:03	9,240	3.22	18,204,000.00	852.03
3/23/2017 9:04	9,240	3.45	18,222,000.00	852.41
3/23/2017 9:05	9,240	3.2	17,976,000.00	852.36
3/23/2017 9:06	9,240	3.38	17,694,000.00	852.22
3/23/2017 9:07	9,240	3.65	17,208,000.00	851.82
3/23/2017 9:08	9,240	3.6	17,472,000.00	853.21
3/23/2017 9:09	9,240	3.41	17,106,000.00	854.7
3/23/2017 9:10	9,240	3.38	17,124,000.00	855.14
3/23/2017 9:11	9,240	3.24	17,526,000.00	855.89
3/23/2017 9:12	9,240	2.92	17,622,000.00	856.36
3/23/2017 9:13	9,240	2.92	17,532,000.00	856.92
3/23/2017 9:14	9,240	2.9	17,382,000.00	854.33
3/23/2017 9:15	9,240	3.08	17,322,000.00	853.88
3/23/2017 9:16	9,240	3.13	17,880,000.00	855.25
3/23/2017 9:17	9,240	3.23	18,318,000.00	854.43
3/23/2017 9:18	9,240	3.32	18,156,000.00	854.04
3/23/2017 9:19	9,240	3.56	17,916,000.00	854.74
3/23/2017 9:20	9,240	3.54	17,742,000.00	855.41
3/23/2017 9:21	9,240	3.4	18,138,000.00	855
3/23/2017 9:22	9,240	3.27	17,922,000.00	854.85
3/23/2017 9:23	9,240	3.31	18,054,000.00	853.53
3/23/2017 9:24	9,240	3.26	18,036,000.00	853.24
3/23/2017 9:25	9,240	3.42	17,874,000.00	853.6
3/23/2017 9:26	9,240	3.25	17,676,000.00	853.78
3/23/2017 9:27	9,240	3.16	17,760,000.00	853.34
3/23/2017 9:28	9,240	3.25	17,382,000.00	853.45
3/23/2017 9:29	9,240	3.29	17,352,000.00	855.06
3/23/2017 9:30	9,240	3.18	17,556,000.00	854.24
3/23/2017 9:31	9,240	2.98	17,340,000.00	854.16
3/23/2017 9:32	9,240	3.1	17,568,000.00	854.74
3/23/2017 9:33	9,240	3.41	17,802,000.00	854.89
3/23/2017 9:34	9,240	3.12	17,508,000.00	855.32
3/23/2017 9:35	9,240	3.28	17,082,000.00	855.99
3/23/2017 9:36	9,240	3.22	17,832,000.00	855.43
3/23/2017 9:37	9,240	3.31	18,000,000.00	856.54
3/23/2017 9:38	9,240	3.38	18,378,000.00	856.54
3/23/2017 9:39	9,240	3.42	18,108,000.00	855.57

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/23/2017 9:40	9,240	3.58	18,444,000.00	855.29
3/23/2017 9:41	9,240	3.53	18,390,000.00	855.41
3/23/2017 9:42	9,240	3.73	18,120,000.00	854.83
3/23/2017 9:43	9,240	3.71	18,384,000.00	854.18
3/23/2017 9:44	9,240	3.72	18,444,000.00	854.28
3/23/2017 9:45	9,240	3.61	18,354,000.00	854.53
3/23/2017 9:46	9,240	3.58	18,276,000.00	855.29
3/23/2017 9:47	9,240	3.45	17,778,000.00	854.62
3/23/2017 9:48	9,240	3.36	18,156,000.00	853.96
3/23/2017 9:49	9,240	3.36	18,054,000.00	854.54
3/23/2017 9:50	9,240	3.38	17,808,000.00	854.51
3/23/2017 9:51	9,240	3.34	17,838,000.00	855.13
3/23/2017 9:52	9,240	3.33	17,568,000.00	856.18
3/23/2017 9:53	9,240	3.14	17,664,000.00	856.48
3/23/2017 9:54	9,240	3.07	17,808,000.00	856.03
3/23/2017 9:55	9,240	3.26	17,472,000.00	856.24
3/23/2017 9:56	9,240	3.15	17,976,000.00	855.58
3/23/2017 9:57	9,240	3.06	17,874,000.00	855.08
3/23/2017 9:58	9,240	3.37	17,802,000.00	855.15
3/23/2017 9:59	9,240	3.54	17,694,000.00	856.61
3/23/2017 10:00	9,240	3.54	18,024,000.00	855.95
3/23/2017 10:01	9,240	3.46	17,748,000.00	856.33
3/23/2017 10:02	9,240	3.14	17,736,000.00	855.71
3/23/2017 10:03	9,240	3.28	17,796,000.00	854.51
3/23/2017 10:04	9,240	3.57	17,832,000.00	854.49
3/23/2017 10:05	9,240	3.54	17,808,000.00	854.34
3/23/2017 10:06	9,240	3.38	17,820,000.00	855.05
3/23/2017 10:07	9,240	3.38	18,072,000.00	855.59
3/23/2017 10:08	9,240	3.38	18,072,000.00	855.12
3/23/2017 10:09	9,240	3.34	17,976,000.00	854.5
3/23/2017 10:10	9,240	3.46	18,126,000.00	854.13
3/23/2017 10:11	9,240	3.54	18,192,000.00	854.62
3/23/2017 10:12	9,240	3.5	18,234,000.00	854.1
3/23/2017 10:13	9,240	3.45	18,066,000.00	854.34
3/23/2017 10:14	9,240	3.58	18,336,000.00	854.42
3/23/2017 10:15	9,240	3.66	17,808,000.00	855.3
3/23/2017 10:16	9,240	3.68	18,108,000.00	856.06
3/23/2017 10:17	9,240	3.66	17,820,000.00	855.66
3/23/2017 10:18	9,240	3.57	18,162,000.00	856.01
3/23/2017 10:19	9,240	3.6	17,994,000.00	856.24
3/23/2017 10:20	9,240	3.43	18,168,000.00	856.23
3/23/2017 10:21	9,240	3.36	18,012,000.00	855.55
3/23/2017 10:22	9,240	3.42	18,066,000.00	855.72
3/23/2017 10:23	9,240	3.45	18,162,000.00	855.2
3/23/2017 10:24	9,240	3.5	17,820,000.00	855.01
3/23/2017 10:25	9,240	3.3	18,000,000.00	854.64
3/23/2017 10:26	9,240	3.2	18,036,000.00	853.69
3/23/2017 10:27	9,240	3.28	17,934,000.00	853.4
3/23/2017 10:28	9,240	3.53	17,988,000.00	853.6
3/23/2017 10:29	9,240	3.6	17,898,000.00	854.43
3/23/2017 10:30	9,240	3.58	18,186,000.00	855.35
3/23/2017 10:31	9,240	3.62	17,400,000.00	856.15
3/23/2017 10:32	9,240	3.42	18,000,000.00	855.73
3/23/2017 10:33	9,240	3.34	17,664,000.00	856.47
3/23/2017 10:34	9,240	3.2	17,928,000.00	856.08
3/23/2017 10:35	9,240	3.38	17,682,000.00	856.12
3/23/2017 10:36	9,240	3.29	17,994,000.00	856.75
3/23/2017 10:37	9,240	3.14	18,264,000.00	856.16
3/23/2017 10:38	9,240	3.12	17,838,000.00	854.73
3/23/2017 10:39	9,240	3.5	18,270,000.00	854.35
3/23/2017 10:40	9,240	3.54	18,024,000.00	855.85
3/23/2017 10:41	9,240	3.5	18,192,000.00	856.63
3/23/2017 10:42	9,240	3.68	18,174,000.00	858
3/23/2017 10:43	9,240	3.63	18,048,000.00	858.78
3/23/2017 10:44	9,240	3.46	17,844,000.00	858.92
3/23/2017 10:45	9,240	3.32	17,778,000.00	859.26
3/23/2017 10:46	9,240	3.25	18,030,000.00	858.39
3/23/2017 10:47	9,240	3.3	18,324,000.00	857.92

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/23/2017 10:48	9,240	3.41	18,396,000.00	857.23
3/23/2017 10:49	9,240	3.4	18,126,000.00	856.82
3/23/2017 10:50	9,240	3.58	18,276,000.00	856.92
3/23/2017 10:51	9,240	3.53	17,964,000.00	856.45
3/23/2017 10:52	9,240	3.58	18,324,000.00	857.18
3/23/2017 10:53	9,240	3.59	18,060,000.00	857.3
3/23/2017 10:54	9,240	3.46	18,420,000.00	857.19
3/23/2017 10:55	9,240	3.37	18,378,000.00	856.51
3/23/2017 10:56	9,240	3.43	18,426,000.00	856.35
3/23/2017 10:57	9,240	3.28	18,084,000.00	855.87
3/23/2017 10:58	9,240	3.51	18,132,000.00	855.93
3/23/2017 10:59	9,240	3.68	18,420,000.00	855.92
3/23/2017 11:00	9,240	3.41	17,838,000.00	855.95
3/23/2017 11:01	9,240	3.25	18,090,000.00	855.84
3/23/2017 11:02	9,240	3.3	18,210,000.00	856.39
3/23/2017 11:03	9,240	3.39	17,976,000.00	856.29
3/23/2017 11:04	9,240	3.28	17,790,000.00	856.06
3/23/2017 11:05	9,240	2.9	17,910,000.00	856.41
3/23/2017 11:06	9,240	3.1	18,162,000.00	855.67
3/23/2017 11:07	9,240	3.22	18,264,000.00	855.94
3/23/2017 11:08	9,240	3.29	18,324,000.00	855.86
3/23/2017 11:09	9,240	3.3	18,516,000.00	854.8
3/23/2017 11:10	9,240	3.4	18,066,000.00	854.53
3/23/2017 11:11	9,240	3.54	18,408,000.00	855.13
3/23/2017 11:12	9,240	3.61	18,396,000.00	855.64
3/23/2017 11:13	9,240	3.52	18,690,000.00	855.96
3/23/2017 11:14	9,240	3.53	18,456,000.00	855.22
3/23/2017 11:15	9,240	3.69	18,354,000.00	856.1
3/23/2017 11:16	9,240	3.55	18,174,000.00	855.89
3/23/2017 11:17	9,240	3.5	18,426,000.00	855.17
3/23/2017 11:18	9,240	3.65	18,126,000.00	855.33
3/23/2017 11:19	9,240	3.56	18,522,000.00	855.03
3/23/2017 11:20	9,240	3.57	18,264,000.00	855.56
3/23/2017 11:21	9,240	3.52	18,000,000.00	855.71
3/23/2017 11:22	9,240	3.41	18,570,000.00	856.47
3/23/2017 11:23	9,240	3.34	17,940,000.00	856.56
3/23/2017 11:24	9,240	3.12	18,486,000.00	855.55
3/23/2017 11:25	9,240	3.31	18,132,000.00	855.51
3/23/2017 11:26	9,240	3.2	18,252,000.00	855.42
3/23/2017 11:27	9,240	3.3	18,462,000.00	855.54
3/23/2017 11:28	9,240	3.24	18,372,000.00	854.92
3/23/2017 11:29	9,240	3.33	18,588,000.00	855.11
3/23/2017 11:30	9,240	3.44	18,252,000.00	855.19
3/23/2017 11:31	9,240	3.51	18,018,000.00	856.03
3/23/2017 11:32	9,240	3.4	18,324,000.00	855.14
3/23/2017 11:33	9,240	3.6	18,738,000.00	855.45
3/23/2017 11:34	9,240	3.42	18,486,000.00	855.91
3/23/2017 11:35	9,240	3.27	18,066,000.00	856.34
3/23/2017 11:36	9,240	3.29	18,174,000.00	855.73
3/23/2017 11:37	9,240	3.44	18,246,000.00	855.27
3/23/2017 11:38	9,240	3.34	18,762,000.00	854.25
3/23/2017 11:39	9,240	3.43	18,306,000.00	854.15
3/23/2017 11:40	9,240	3.31	18,372,000.00	854.79
3/23/2017 11:41	9,240	3.57	18,540,000.00	854.8
3/23/2017 11:42	9,240	3.42	18,450,000.00	854.81
3/23/2017 11:43	9,240	3.67	18,222,000.00	855.05
3/23/2017 11:44	9,240	3.63	18,528,000.00	855.14
3/23/2017 11:45	9,240	3.54	18,624,000.00	856.15
3/23/2017 11:46	9,240	3.34	18,504,000.00	856.78
3/23/2017 11:47	9,240	3.38	18,462,000.00	855.59
3/23/2017 11:48	9,240	3.42	18,132,000.00	854.68
3/23/2017 11:49	9,240	3.51	18,360,000.00	854.96
3/23/2017 11:50	9,240	3.54	18,282,000.00	855.98
3/23/2017 11:51	9,240	3.47	18,234,000.00	855.53
3/23/2017 11:52	9,240	3.56	18,132,000.00	856.67
3/23/2017 11:53	9,240	3.43	18,000,000.00	856.76
3/23/2017 11:54	9,240	3.33	18,216,000.00	856.55
3/23/2017 11:55	9,240	3.33	18,186,000.00	856.21

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/23/2017 11:56	9,240	3.23	18,330,000.00	856
3/23/2017 11:57	9,240	3.27	18,348,000.00	856.18
3/23/2017 11:58	9,240	3.32	18,534,000.00	856.79
3/23/2017 11:59	9,240	3.21	18,156,000.00	855.88
3/23/2017 12:00	9,240	3.28	18,660,000.00	855.41
3/23/2017 12:01	9,240	3.24	18,546,000.00	855.17
3/23/2017 12:02	9,240	3.32	18,582,000.00	854.93
3/23/2017 12:03	9,240	3.39	18,372,000.00	855.31
3/23/2017 12:04	9,240	3.45	18,522,000.00	855.46
3/23/2017 12:05	9,240	3.52	18,294,000.00	854.8
3/23/2017 12:06	9,240	3.56	18,420,000.00	855.71
3/23/2017 12:07	9,240	3.59	18,252,000.00	855.78
3/23/2017 12:08	9,240	3.62	18,504,000.00	856.7
3/23/2017 12:09	9,240	3.41	18,528,000.00	857.15
3/23/2017 12:10	9,240	3.37	18,384,000.00	856.92
3/23/2017 12:11	9,240	3.48	18,588,000.00	856.69
3/23/2017 12:12	9,240	3.44	18,480,000.00	856.77
3/23/2017 12:13	9,240	3.5	18,486,000.00	856.32
3/23/2017 12:14	9,240	3.6	18,714,000.00	855.63
3/23/2017 12:15	9,240	3.52	18,888,000.00	855.15
3/23/2017 12:16	9,240	3.54	18,930,000.00	855.26
3/23/2017 12:17	9,240	3.58	18,708,000.00	855.03
3/23/2017 12:18	9,240	3.65	18,762,000.00	855.04
3/23/2017 12:19	9,240	3.61	18,024,000.00	854.77
3/23/2017 12:20	9,240	3.7	17,766,000.00	854.66
3/23/2017 12:21	9,240	3.58	17,994,000.00	855.28
3/23/2017 12:22	9,240	3.58	18,252,000.00	856.78
3/23/2017 12:23	9,240	3.4	18,222,000.00	857.09
3/23/2017 12:24	9,240	3.4	18,180,000.00	858.06
3/23/2017 12:25	9,240	3.42	18,300,000.00	857.6
3/23/2017 12:26	9,240	3.32	18,372,000.00	857.03
3/23/2017 12:27	9,240	3.57	18,246,000.00	856.05
3/23/2017 12:28	9,240	3.44	18,408,000.00	856.09
3/23/2017 12:29	9,240	3.33	18,378,000.00	856.45
3/23/2017 12:30	9,240	3.32	18,228,000.00	856.13
3/23/2017 12:31	9,240	3.51	18,276,000.00	856.28
3/23/2017 12:32	9,240	3.45	18,600,000.00	857.49
3/23/2017 12:33	9,240	3.7	18,648,000.00	857.43
3/23/2017 12:34	9,240	3.66	18,378,000.00	857.04
3/23/2017 12:35	9,240	3.5	18,516,000.00	856.56
3/23/2017 12:36	9,240	3.57	18,924,000.00	856.07
3/23/2017 12:37	9,240	3.56	18,414,000.00	855.98
3/23/2017 12:38	9,240	3.8	19,134,000.00	855.21
3/23/2017 12:39	9,240	3.67	18,660,000.00	855.03
3/23/2017 12:40	9,240	3.67	18,732,000.00	855.24
3/23/2017 12:41	9,240	3.8	18,414,000.00	856.87
3/23/2017 12:42	9,240	3.52	18,684,000.00	857.05
3/23/2017 12:43	9,240	3.38	18,330,000.00	856.36
3/23/2017 12:44	9,240	3.42	18,216,000.00	855.73
3/23/2017 12:45	9,240	3.24	18,312,000.00	856.48
3/23/2017 12:46	9,240	3.39	18,312,000.00	856.73
3/23/2017 12:47	9,240	3.29	18,072,000.00	856.39
3/23/2017 12:48	9,240	3.32	18,240,000.00	856.23
3/23/2017 12:49	9,240	3.26	18,450,000.00	856.75
3/23/2017 12:50	9,240	3.31	18,510,000.00	858.36
3/23/2017 12:51	9,240	3.21	18,690,000.00	857.38
3/23/2017 12:52	9,240	3.12	18,492,000.00	856.79
3/23/2017 12:53	9,240	3.25	18,324,000.00	855.63
3/23/2017 12:54	9,240	3.48	18,444,000.00	855.89
3/23/2017 12:55	9,240	3.39	18,336,000.00	855.43
3/23/2017 12:56	9,240	3.58	18,528,000.00	855.77
3/23/2017 12:57	9,240	3.37	18,504,000.00	856.32
3/23/2017 12:58	9,240	3.38	18,648,000.00	856.28
3/23/2017 12:59	9,240	3.34	18,438,000.00	856
3/23/2017 13:00	9,240	3.57	18,204,000.00	855.69
3/23/2017 13:01	9,240	3.71	18,330,000.00	855.59
3/23/2017 13:02	9,240	3.72	18,594,000.00	855.43
3/23/2017 13:03	9,240	3.65	18,126,000.00	856.31

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/23/2017 13:04	9,240	3.46	18,168,000.00	856.96
3/23/2017 13:05	9,240	3.27	18,168,000.00	857.05
3/23/2017 13:06	9,240	3.38	18,210,000.00	856.68
3/23/2017 13:07	9,240	3.33	18,426,000.00	856.18
3/23/2017 13:08	9,240	3.24	18,210,000.00	856.64
3/23/2017 13:09	9,240	3.24	18,408,000.00	856.46
3/23/2017 13:10	9,240	3.4	18,504,000.00	856.12
3/23/2017 13:11	9,240	3.35	18,588,000.00	854.55
3/23/2017 13:12	9,240	3.6	18,510,000.00	854.99
3/23/2017 13:13	9,240	3.52	18,636,000.00	855.36
3/23/2017 13:14	9,240	3.66	18,582,000.00	856.09
3/23/2017 13:15	9,240	3.47	18,252,000.00	855.76
3/23/2017 13:16	9,240	3.57	18,618,000.00	855.65
3/23/2017 13:17	9,240	3.54	18,204,000.00	855.64
3/23/2017 13:18	9,240	3.38	18,702,000.00	855.53
3/23/2017 13:19	9,240	3.5	18,486,000.00	854.76
3/23/2017 13:20	9,240	3.57	18,612,000.00	854.7
3/23/2017 13:21	9,240	3.56	18,282,000.00	855.4
3/23/2017 13:22	9,240	3.26	18,102,000.00	855.3
3/23/2017 13:23	9,240	3.39	18,036,000.00	854.9
3/23/2017 13:24	9,240	3.41	17,970,000.00	855.05
3/23/2017 13:25	9,240	3.32	18,042,000.00	855.89
3/23/2017 13:26	9,240	3.3	18,024,000.00	856.52
3/23/2017 13:27	9,240	3.24	17,976,000.00	856.26
3/23/2017 13:28	9,240	3.37	18,192,000.00	855.98
3/23/2017 13:29	9,240	3.38	18,102,000.00	855.23
3/23/2017 13:30	9,240	3.3	18,630,000.00	855.69
3/23/2017 13:31	9,240	3.46	18,552,000.00	856.59
3/23/2017 13:32	9,240	3.53	18,876,000.00	855.83
3/23/2017 13:33	9,240	3.5	18,450,000.00	857.25
3/23/2017 13:34	9,240	3.37	19,050,000.00	857.34
3/23/2017 13:35	9,240	3.45	18,546,000.00	856.14
3/23/2017 13:36	9,240	3.56	18,606,000.00	855.19
3/23/2017 13:37	9,240	3.73	18,486,000.00	855.83
3/23/2017 13:38	9,240	3.72	18,528,000.00	856.33
3/23/2017 13:39	9,240	3.66	18,720,000.00	856.63
3/23/2017 13:40	9,240	3.79	18,576,000.00	857.52
3/23/2017 13:41	9,240	3.52	17,940,000.00	857.86
3/23/2017 13:42	9,240	3.42	18,396,000.00	857.22
3/23/2017 13:43	9,240	3.65	18,318,000.00	856.9
3/23/2017 13:44	9,240	3.45	18,372,000.00	857.5
3/23/2017 13:45	9,240	3.31	18,150,000.00	857.23
3/23/2017 13:46	9,240	3.17	18,336,000.00	857.59
3/23/2017 13:47	9,240	3.23	18,102,000.00	856.82
3/23/2017 13:48	9,240	3.27	18,162,000.00	856.17
3/23/2017 13:49	9,240	3.36	18,426,000.00	855.38
3/23/2017 13:50	9,240	3.59	18,660,000.00	855.14
3/23/2017 13:51	9,240	3.53	18,732,000.00	856.93
3/23/2017 13:52	9,240	3.44	18,378,000.00	856.6
3/23/2017 13:53	9,240	3.49	18,612,000.00	855.38
3/23/2017 13:54	9,240	3.6	18,516,000.00	856.29
3/23/2017 13:55	9,240	3.69	18,408,000.00	856.47
3/23/2017 13:56	9,240	3.55	18,384,000.00	856.01
3/23/2017 13:57	9,240	3.63	18,480,000.00	856.62
3/23/2017 13:58	9,240	3.67	18,078,000.00	856.22
3/23/2017 13:59	9,240	3.51	18,252,000.00	856.1
3/23/2017 14:00	9,240	3.43	18,306,000.00	856.69
3/23/2017 14:01	9,240	3.42	18,264,000.00	856.08
3/23/2017 14:02	9,240	3.39	18,192,000.00	856.08
3/23/2017 14:03	9,240	3.36	17,916,000.00	855.95
3/23/2017 14:04	9,240	3.35	17,964,000.00	855.46
3/23/2017 14:05	9,240	3.46	17,832,000.00	855.7
3/23/2017 14:06	9,240	3.37	18,006,000.00	856.03
3/23/2017 14:07	9,240	3.39	18,252,000.00	855.93
3/23/2017 14:08	9,240	3.41	18,114,000.00	856.33
3/23/2017 14:09	9,240	3.34	18,840,000.00	856.18
3/23/2017 14:10	9,240	3.38	18,564,000.00	855.4
3/23/2017 14:11	9,240	3.31	18,480,000.00	855.06

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/23/2017 14:12	9,240	3.42	18,504,000.00	853.4
3/23/2017 14:13	9,240	3.66	18,378,000.00	853.24
3/23/2017 14:14	9,240	3.63	18,384,000.00	853.15
3/23/2017 14:15	9,240	3.74	18,720,000.00	854.04
3/23/2017 14:16	9,240	3.64	17,988,000.00	855.06
3/23/2017 14:17	9,240	3.57	18,054,000.00	854.85
3/23/2017 14:18	9,240	3.48	18,276,000.00	855.37
3/23/2017 14:19	9,240	3.16	17,388,000.00	856.33
3/23/2017 14:20	9,240	3.2	17,940,000.00	855.2
3/23/2017 14:21	9,240	3.38	18,228,000.00	855.06
3/23/2017 14:22	9,240	3.22	17,820,000.00	856.02
3/23/2017 14:23	9,240	3.17	18,072,000.00	855.6
3/23/2017 14:24	9,240	3.3	18,282,000.00	855.73
3/23/2017 14:25	9,240	3.43	18,654,000.00	855.92
3/23/2017 14:26	9,240	3.42	18,252,000.00	855.73
3/23/2017 14:27	9,240	3.37	18,264,000.00	855.85
3/23/2017 14:28	9,240	3.47	18,042,000.00	855.33
3/23/2017 14:29	9,240	3.54	18,348,000.00	855.53
3/23/2017 14:30	9,240	3.57	18,696,000.00	855.75
3/23/2017 14:31	9,240	3.68	18,180,000.00	855.91
3/23/2017 14:32	9,240	3.71	18,504,000.00	855.62
3/23/2017 14:33	9,240	3.52	18,408,000.00	854.98
3/23/2017 14:34	9,240	3.37	18,492,000.00	854.78
3/23/2017 14:35	9,240	3.41	18,348,000.00	854.4
3/23/2017 14:36	9,240	3.48	18,366,000.00	853.8
3/23/2017 14:37	9,240	3.4	18,672,000.00	853.9
3/23/2017 14:38	9,240	3.64	18,576,000.00	853.37
3/23/2017 14:39	9,240	3.57	18,102,000.00	854.59
3/23/2017 14:40	9,240	3.47	17,904,000.00	855.01
3/23/2017 14:41	9,240	3.41	17,784,000.00	855.82
3/23/2017 14:42	9,240	3.04	17,724,000.00	855.42
3/23/2017 14:43	9,240	3.17	18,144,000.00	855.77
3/23/2017 14:44	9,240	3.18	17,982,000.00	855.61
3/23/2017 14:45	9,240	3.19	17,826,000.00	855.86
3/23/2017 14:46	9,240	3.25	17,808,000.00	855.96
3/23/2017 14:47	9,240	3.3	18,012,000.00	856.13
3/23/2017 14:48	9,240	3.33	18,168,000.00	855.92
3/23/2017 14:49	9,240	3.42	18,126,000.00	857.29
3/23/2017 14:50	9,240	3.37	18,552,000.00	857.14
3/23/2017 14:51	9,240	3.17	18,474,000.00	856.17
3/23/2017 14:52	9,240	3.26	18,564,000.00	855.35
3/23/2017 14:53	9,240	3.34	19,026,000.00	853.75
3/23/2017 14:54	9,240	3.42	18,288,000.00	852.8
3/23/2017 14:55	9,240	3.76	18,660,000.00	852.47
3/23/2017 14:56	9,240	3.86	18,300,000.00	853.25
3/23/2017 14:57	9,240	3.59	18,312,000.00	853.88
3/23/2017 14:58	9,240	3.59	17,754,000.00	855.39
3/23/2017 14:59	9,240	3.33	17,952,000.00	855.17
3/23/2017 15:00	9,240	3.32	17,862,000.00	855.05
3/23/2017 15:01	9,240	3.38	17,856,000.00	855.2
3/23/2017 15:02	9,240	3.37	18,024,000.00	855.64
3/23/2017 15:03	9,240	3.41	17,484,000.00	855.73
3/23/2017 15:04	9,240	3.4	18,036,000.00	855.83
3/23/2017 15:05	9,240	3.42	17,772,000.00	856.54
3/23/2017 15:06	9,240	3.45	18,174,000.00	857.1
3/23/2017 15:07	9,240	3.55	18,570,000.00	857.63
3/23/2017 15:08	9,240	3.55	19,074,000.00	857.49
3/23/2017 15:09	9,240	3.37	18,858,000.00	856.37
3/23/2017 15:10	9,240	3.55	18,750,000.00	856.03
3/23/2017 15:11	9,240	3.58	18,756,000.00	855.21
3/23/2017 15:12	9,240	3.62	18,486,000.00	853.57
3/23/2017 15:13	9,240	3.72	18,528,000.00	852.53
3/23/2017 15:14	9,240	3.82	18,396,000.00	853.32
3/23/2017 15:15	9,240	3.73	18,324,000.00	853.66
3/23/2017 15:16	9,240	3.43	18,270,000.00	852.97
3/23/2017 15:17	9,240	3.55	17,796,000.00	854.84
3/23/2017 15:18	9,240	3.31	18,012,000.00	854.97
3/23/2017 15:19	9,240	3.36	17,514,000.00	855.21

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/23/2017 15:20	9,240	3.38	18,024,000.00	855.92
3/23/2017 15:21	9,240	3.46	17,826,000.00	856.62
3/23/2017 15:22	9,240	3.43	18,060,000.00	857.7
3/23/2017 15:23	9,240	3.18	18,060,000.00	858.29
3/23/2017 15:24	9,240	3.16	18,204,000.00	857.33
3/23/2017 15:25	9,240	3.33	18,444,000.00	856.72
3/23/2017 15:26	9,240	3.26	18,804,000.00	856.53
3/23/2017 15:27	9,240	3.38	18,546,000.00	855.26
3/23/2017 15:28	9,240	3.5	18,918,000.00	854.99
3/23/2017 15:29	9,240	3.86	18,858,000.00	854.31
3/23/2017 15:30	9,240	3.7	18,762,000.00	853.68
3/23/2017 15:31	9,240	3.66	18,744,000.00	854.19
3/23/2017 15:32	9,240	3.63	18,420,000.00	854.61
3/23/2017 15:33	9,240	3.56	18,492,000.00	853.83
3/23/2017 15:34	9,240	3.68	18,312,000.00	853.08
3/23/2017 15:35	9,240	3.58	17,844,000.00	853.82
3/23/2017 15:36	9,240	3.59	17,976,000.00	853.81
3/23/2017 15:37	9,240	3.36	18,132,000.00	854.84
3/23/2017 15:38	9,240	3.24	17,688,000.00	855.42
3/23/2017 15:39	9,240	3.23	17,910,000.00	855.15
3/23/2017 15:40	9,240	3.22	17,814,000.00	855.04
3/23/2017 15:41	9,240	3.3	17,826,000.00	854.89
3/23/2017 15:42	9,240	3.26	18,126,000.00	855.07
3/23/2017 15:43	9,240	3.37	18,156,000.00	853.77
3/23/2017 15:44	9,240	3.44	18,168,000.00	854.06
3/23/2017 15:45	9,240	3.39	18,102,000.00	854.75
3/23/2017 15:46	9,240	3.39	18,222,000.00	854.83
3/23/2017 15:47	9,240	3.34	18,420,000.00	854.05
3/23/2017 15:48	9,240	3.53	18,564,000.00	854.66
3/23/2017 15:49	9,240	3.44	18,390,000.00	855.33
3/23/2017 15:50	9,240	3.54	18,360,000.00	854.87
3/23/2017 15:51	9,240	3.64	18,552,000.00	856
3/23/2017 15:52	9,240	3.51	18,432,000.00	855.69
3/23/2017 15:53	9,240	3.49	18,228,000.00	855.08
3/23/2017 15:54	9,240	3.56	18,372,000.00	855.73
3/23/2017 15:55	9,240	3.53	18,768,000.00	855.39
3/23/2017 15:56	9,240	3.62	18,576,000.00	855.59
3/23/2017 15:57	9,240	3.41	18,678,000.00	856.27
3/23/2017 15:58	9,240	3.48	18,138,000.00	855.7
3/23/2017 15:59	9,240	3.71	18,162,000.00	855.98
3/23/2017 16:00	9,240	3.53	18,360,000.00	856.29
3/23/2017 16:01	9,240	3.43	17,922,000.00	856.1
3/23/2017 16:02	9,240	3.48	18,324,000.00	856.72
3/23/2017 16:03	9,240	3.5	18,150,000.00	857
3/23/2017 16:04	9,240	3.41	18,150,000.00	856.29
3/23/2017 16:05	9,240	3.37	18,060,000.00	855.95
3/23/2017 16:06	9,240	3.48	18,126,000.00	856.28
3/23/2017 16:07	9,240	3.42	18,030,000.00	856.47
3/23/2017 16:08	9,240	3.41	17,922,000.00	856.3
3/23/2017 16:09	9,240	3.59	18,102,000.00	856.77
3/23/2017 16:10	9,240	3.26	18,222,000.00	856.57
3/23/2017 16:11	9,240	3.41	18,222,000.00	856.77
3/23/2017 16:12	9,240	3.58	18,246,000.00	856.36
3/23/2017 16:13	9,240	3.49	18,462,000.00	856.46
3/23/2017 16:14	9,240	3.34	18,636,000.00	855.75
3/23/2017 16:15	9,240	3.48	18,054,000.00	854.96
3/23/2017 16:16	9,240	3.58	18,570,000.00	855.46
3/23/2017 16:17	9,240	3.54	18,522,000.00	854.9
3/23/2017 16:18	9,240	3.67	17,982,000.00	854.61
3/23/2017 16:19	9,240	3.66	18,624,000.00	854.69
3/23/2017 16:20	9,240	3.8	18,252,000.00	855.67
3/23/2017 16:21	9,240	3.46	18,132,000.00	856.14
3/23/2017 16:22	9,240	3.44	17,940,000.00	856.1
3/23/2017 16:23	9,240	3.42	18,174,000.00	856.22
3/23/2017 16:24	9,240	3.37	17,934,000.00	856.8
3/23/2017 16:25	9,240	3.22	18,066,000.00	855.53
3/23/2017 16:26	9,240	3.3	17,784,000.00	855.09
3/23/2017 16:27	9,240	3.34	18,162,000.00	855.49

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/23/2017 16:28	9,240	3.24	18,450,000.00	855.64
3/23/2017 16:29	9,240	3.46	18,420,000.00	855.24
3/23/2017 16:30	9,240	3.51	17,982,000.00	854.92
3/23/2017 16:31	9,240	3.29	18,180,000.00	855.75
3/23/2017 16:32	9,240	3.4	18,198,000.00	855.55
3/23/2017 16:33	9,240	3.38	18,228,000.00	854.39
3/23/2017 16:34	9,240	3.48	18,372,000.00	854.66
3/23/2017 16:35	9,240	3.52	18,564,000.00	854.49
3/23/2017 16:36	9,240	3.46	18,030,000.00	853.88
3/23/2017 16:37	9,240	3.62	18,126,000.00	853.82
3/23/2017 16:38	9,240	3.65	17,916,000.00	854.6
3/23/2017 16:39	9,240	3.61	17,748,000.00	856.04
3/23/2017 16:40	9,240	3.3	17,880,000.00	855.33
3/23/2017 16:41	9,240	3.14	18,042,000.00	854.3
3/23/2017 16:42	9,240	3.44	17,754,000.00	855.55
3/23/2017 16:43	9,240	3.46	17,754,000.00	856.21
3/23/2017 16:44	9,240	3.24	17,856,000.00	855.37
3/23/2017 16:45	9,240	3.27	17,850,000.00	853.68
3/23/2017 16:46	9,240	3.38	18,300,000.00	855.04
3/23/2017 16:47	9,240	3.4	18,222,000.00	855.09
3/23/2017 16:48	9,240	3.31	18,282,000.00	854.47
3/23/2017 16:49	9,240	3.31	18,264,000.00	854.48
3/23/2017 16:50	9,240	3.34	18,102,000.00	854.74
3/23/2017 16:51	9,240	3.41	18,060,000.00	854.42
3/23/2017 16:52	9,240	3.4	18,186,000.00	853.7
3/23/2017 16:53	9,240	3.52	18,126,000.00	854.13
3/23/2017 16:54	9,240	3.53	18,204,000.00	855.34
3/23/2017 16:55	9,240	3.44	17,844,000.00	855.03
3/23/2017 16:56	9,240	3.48	18,204,000.00	854.43
3/23/2017 16:57	9,240	3.47	17,976,000.00	855.17
3/23/2017 16:58	9,240	3.42	17,934,000.00	855.53
3/23/2017 16:59	9,240	3.39	17,994,000.00	854.94
3/23/2017 17:00	9,240	3.38	17,730,000.00	854.6
3/23/2017 17:01	9,240	3.4	18,156,000.00	855.8
3/23/2017 17:02	9,240	3.49	17,826,000.00	855.9
3/23/2017 17:03	9,240	3.53	18,204,000.00	855.33
3/23/2017 17:04	9,240	3.26	18,306,000.00	854.83
3/23/2017 17:05	9,240	3.25	18,192,000.00	854.68
3/23/2017 17:06	9,240	3.22	18,102,000.00	853.62
3/23/2017 17:07	9,240	3.52	18,156,000.00	852.89
3/23/2017 17:08	9,240	3.62	18,456,000.00	852.9
3/23/2017 17:09	9,240	3.73	18,060,000.00	853.65
3/23/2017 17:10	9,240	3.64	18,546,000.00	853.9
3/23/2017 17:11	9,240	3.74	18,108,000.00	853.73
3/23/2017 17:12	9,240	3.61	17,994,000.00	854.54
3/23/2017 17:13	9,240	3.29	17,814,000.00	853.98
3/23/2017 17:14	9,240	3.27	17,868,000.00	852.99
3/23/2017 17:15	9,240	3.44	17,700,000.00	853.77
3/23/2017 17:16	9,240	3.3	17,472,000.00	853.22
3/23/2017 17:17	9,240	3.29	17,838,000.00	852.98
3/23/2017 17:18	9,240	3.46	17,292,000.00	853.69
3/23/2017 17:19	9,240	3.6	17,850,000.00	853.48
3/23/2017 17:20	9,240	3.58	17,838,000.00	854.6
3/23/2017 17:21	9,240	3.58	17,724,000.00	855.39
3/23/2017 17:22	9,240	3.15	17,796,000.00	854.74
3/23/2017 17:23	9,240	3.15	17,724,000.00	854.11
3/23/2017 17:24	9,240	3.5	18,252,000.00	854.29
3/23/2017 17:25	9,240	3.31	18,318,000.00	853.22
3/23/2017 17:26	9,240	3.54	17,994,000.00	853.2
3/23/2017 17:27	9,240	3.65	18,384,000.00	852.07
3/23/2017 17:28	9,240	3.84	17,910,000.00	851.35
3/23/2017 17:29	9,240	3.74	18,156,000.00	852.23
3/23/2017 17:30	9,240	3.51	18,000,000.00	851.85
3/23/2017 17:31	9,240	3.72	17,850,000.00	852.96
3/23/2017 17:32	9,240	3.5	17,748,000.00	853.47
3/23/2017 17:33	9,240	3.26	17,724,000.00	852.99
3/23/2017 17:34	9,240	3.15	17,502,000.00	853.28
3/23/2017 17:35	9,240	3.02	17,748,000.00	852.71

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/23/2017 17:36	9,240	3.07	17,652,000.00	852.39
3/23/2017 17:37	9,240	3.23	17,748,000.00	852.17
3/23/2017 17:38	9,240	3.37	17,532,000.00	851.84
3/23/2017 17:39	9,240	3.17	17,286,000.00	852.76
3/23/2017 17:40	9,240	3.3	17,442,000.00	853.82
3/23/2017 17:41	9,240	3.19	17,898,000.00	854.37
3/23/2017 17:42	9,240	3.38	17,640,000.00	854.7
3/23/2017 17:43	9,240	3.27	17,868,000.00	855.05
3/23/2017 17:44	9,240	3.2	17,646,000.00	854.72
3/23/2017 17:45	9,240	3.18	17,982,000.00	854.3
3/23/2017 17:46	9,240	3.34	18,078,000.00	854.79
3/23/2017 17:47	9,240	3.43	18,042,000.00	854.16
3/23/2017 17:48	9,240	3.44	18,480,000.00	852.85
3/23/2017 17:49	9,240	3.45	18,420,000.00	852.77
3/23/2017 17:50	9,240	3.44	18,336,000.00	852.04
3/23/2017 17:51	9,240	3.5	18,360,000.00	852.33
3/23/2017 17:52	9,240	3.62	18,120,000.00	851.64
3/23/2017 17:53	9,240	3.7	18,036,000.00	851.31
3/23/2017 17:54	9,240	3.68	17,646,000.00	851.75
3/23/2017 17:55	9,240	3.71	17,670,000.00	852.11
3/23/2017 17:56	9,240	3.58	17,730,000.00	853.03
3/23/2017 17:57	9,240	3.37	17,622,000.00	853
3/23/2017 17:58	9,240	3.26	17,448,000.00	853.16
3/23/2017 17:59	9,240	3.26	17,844,000.00	854.07
3/23/2017 18:00	9,240	3.2	17,406,000.00	854.05
3/23/2017 18:01	9,240	3.17	17,340,000.00	854.33
3/23/2017 18:02	9,240	3.06	17,760,000.00	854.01
3/23/2017 18:03	9,240	3.24	17,328,000.00	853.43
3/23/2017 18:04	9,240	3.43	17,478,000.00	854.22
3/23/2017 18:05	9,240	3.36	17,952,000.00	854.42
3/23/2017 18:06	9,240	3.44	18,114,000.00	853.83
3/23/2017 18:07	9,240	3.42	17,976,000.00	854.34
3/23/2017 18:08	9,240	3.38	18,186,000.00	854.74
3/23/2017 18:09	9,240	3.45	18,420,000.00	853.62
3/23/2017 18:10	9,240	3.46	18,042,000.00	853.85
3/23/2017 18:11	9,240	3.49	18,186,000.00	853.47
3/23/2017 18:12	9,240	3.39	17,772,000.00	852.87
3/23/2017 18:13	9,240	3.46	17,736,000.00	853.3
3/23/2017 18:14	9,240	3.53	18,120,000.00	853.2
3/23/2017 18:15	9,240	3.44	17,856,000.00	852.92
3/23/2017 18:16	9,240	3.62	17,592,000.00	853.19
3/23/2017 18:17	9,240	3.4	17,706,000.00	853.32
3/23/2017 18:18	9,240	3.18	17,502,000.00	853.38
3/23/2017 18:19	9,240	3.29	16,962,000.00	853.26
3/23/2017 18:20	9,240	3.44	17,268,000.00	853.1
3/23/2017 18:21	9,240	3.25	17,778,000.00	853.89
3/23/2017 18:22	9,240	3.24	18,000,000.00	853.69
3/23/2017 18:23	9,240	3.23	17,574,000.00	853.83
3/23/2017 18:24	9,240	3.36	17,808,000.00	854.43
3/23/2017 18:25	9,240	3.43	17,760,000.00	854.83
3/23/2017 18:26	9,240	3.37	17,706,000.00	854.34
3/23/2017 18:27	9,240	3.31	18,084,000.00	854.26
3/23/2017 18:28	9,240	3.38	18,024,000.00	854.11
3/23/2017 18:29	9,240	3.25	18,030,000.00	853.8
3/23/2017 18:30	9,240	3.52	17,970,000.00	853.61
3/23/2017 18:31	9,240	3.49	18,174,000.00	853.12
3/23/2017 18:32	9,240	3.62	18,168,000.00	853.8
3/23/2017 18:33	9,240	3.66	18,354,000.00	853.99
3/23/2017 18:34	9,240	3.54	18,108,000.00	853.81
3/23/2017 18:35	9,240	3.52	18,222,000.00	853.14
3/23/2017 18:36	9,240	3.43	17,892,000.00	852.39
3/23/2017 18:37	9,240	3.45	17,880,000.00	852.1
3/23/2017 18:38	9,240	3.43	17,922,000.00	852.2
3/23/2017 18:39	9,240	3.4	18,180,000.00	852.21
3/23/2017 18:40	9,240	3.31	17,820,000.00	852.3
3/23/2017 18:41	9,240	3.33	17,490,000.00	852.49
3/23/2017 18:42	9,240	3.43	17,742,000.00	853.43
3/23/2017 18:43	9,240	3.16	17,466,000.00	853.68

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/23/2017 18:44	9,240	3.16	17,388,000.00	853.75
3/23/2017 18:45	9,240	3.36	17,658,000.00	853.93
3/23/2017 18:46	9,240	3.31	17,652,000.00	854.23
				855.10
3/24/2017 8:00	9,240	3.1	17,814,000.00	853.55
3/24/2017 8:01	9,240	3.2	18,054,000.00	852.85
3/24/2017 8:02	9,240	3.4	17,340,000.00	851.31
3/24/2017 8:03	9,240	3.76	18,258,000.00	851.15
3/24/2017 8:04	9,240	3.98	17,940,000.00	851.98
3/24/2017 8:05	9,240	3.84	17,736,000.00	853.73
3/24/2017 8:06	9,240	3.42	17,760,000.00	852.99
3/24/2017 8:07	9,240	3.57	18,048,000.00	852.47
3/24/2017 8:08	9,240	3.4	17,688,000.00	852.31
3/24/2017 8:09	9,240	3.69	17,766,000.00	851.78
3/24/2017 8:10	9,240	3.42	17,544,000.00	852.14
3/24/2017 8:11	9,240	3.54	17,376,000.00	853.76
3/24/2017 8:12	9,240	3.35	18,162,000.00	853.17
3/24/2017 8:13	9,240	3.22	17,970,000.00	851.76
3/24/2017 8:14	9,240	3.12	18,408,000.00	851.17
3/24/2017 8:15	9,240	3.23	17,988,000.00	851.19
3/24/2017 8:16	9,240	3.3	17,886,000.00	849.88
3/24/2017 8:17	9,240	3.44	17,718,000.00	850.1
3/24/2017 8:18	9,240	3.55	16,758,000.00	851.3
3/24/2017 8:19	9,240	3.62	16,794,000.00	851.67
3/24/2017 8:20	9,240	3.68	17,160,000.00	851.79
3/24/2017 8:21	9,240	3.39	17,568,000.00	852.87
3/24/2017 8:22	9,240	3.36	17,448,000.00	853.18
3/24/2017 8:23	9,240	3.34	17,142,000.00	852.2
3/24/2017 8:24	9,240	3.44	16,608,000.00	851.46
3/24/2017 8:25	9,240	3.4	16,968,000.00	852.38
3/24/2017 8:26	9,240	3.13	16,866,000.00	852.51
3/24/2017 8:27	9,240	3.36	16,914,000.00	851.57
3/24/2017 8:28	9,240	3.42	17,058,000.00	851
3/24/2017 8:29	9,240	3.57	17,652,000.00	852.03
3/24/2017 8:30	9,240	3.7	16,776,000.00	853.57
3/24/2017 8:31	9,240	3.58	17,490,000.00	852.68
3/24/2017 8:32	9,240	3.35	17,838,000.00	851.98
3/24/2017 8:33	9,240	3.51	17,268,000.00	852.66
3/24/2017 8:34	9,240	3.34	17,544,000.00	852.63
3/24/2017 8:35	9,240	3.22	17,868,000.00	850.82
3/24/2017 8:36	9,240	3.13	17,658,000.00	849.82
3/24/2017 8:37	9,240	3.29	16,830,000.00	850.15
3/24/2017 8:38	9,240	3.52	17,634,000.00	849.76
3/24/2017 8:39	9,240	3.59	17,676,000.00	849.94
3/24/2017 8:40	9,240	3.49	17,628,000.00	850.84
3/24/2017 8:41	9,240	3.44	17,412,000.00	851.76
3/24/2017 8:42	9,240	3.46	16,908,000.00	852.65
3/24/2017 8:43	9,240	3.21	16,974,000.00	853.66
3/24/2017 8:44	9,240	3.2	16,812,000.00	854.37
3/24/2017 8:45	9,240	3.11	17,160,000.00	854.97
3/24/2017 8:46	9,240	2.87	16,794,000.00	853.84
3/24/2017 8:47	9,240	2.83	17,502,000.00	852.91
3/24/2017 8:48	9,240	3.18	18,024,000.00	853.38
3/24/2017 8:49	9,240	3.29	17,958,000.00	853.23
3/24/2017 8:50	9,240	3.28	18,132,000.00	852.37
3/24/2017 8:51	9,240	3.48	18,108,000.00	853.24
3/24/2017 8:52	9,240	3.42	18,060,000.00	853.62
3/24/2017 8:53	9,240	3.5	17,988,000.00	852.93
3/24/2017 8:54	9,240	3.8	18,102,000.00	852.35
3/24/2017 8:55	9,240	3.7	17,736,000.00	853.17
3/24/2017 8:56	9,240	3.55	17,904,000.00	854.57
3/24/2017 8:57	9,240	3.22	18,264,000.00	854
3/24/2017 8:58	9,240	3.14	18,036,000.00	851.68
3/24/2017 8:59	9,240	3.53	17,790,000.00	851.45
3/24/2017 9:00	9,240	3.52	17,916,000.00	852.87
3/24/2017 9:01	9,240	3.5	17,922,000.00	852.33

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/24/2017 9:02	9,240	3.44	17,196,000.00	852.02
3/24/2017 9:03	9,240	3.47	16,656,000.00	853
3/24/2017 9:04	9,240	3.4	16,950,000.00	854.4
3/24/2017 9:05	9,240	3.15	17,508,000.00	853.5
3/24/2017 9:06	9,240	3.25	17,904,000.00	853.1
3/24/2017 9:07	9,240	3.04	17,250,000.00	852.4
3/24/2017 9:08	9,240	3.04	16,620,000.00	851.18
3/24/2017 9:09	9,240	3.24	16,848,000.00	851.55
3/24/2017 9:10	9,240	3.48	17,718,000.00	852.39
3/24/2017 9:11	9,240	3.44	16,794,000.00	852.65
3/24/2017 9:12	9,240	3.39	16,908,000.00	853.52
3/24/2017 9:13	9,240	3.35	16,746,000.00	854.19
3/24/2017 9:14	9,240	3.27	16,692,000.00	853.31
3/24/2017 9:15	9,240	3.18	16,830,000.00	852.95
3/24/2017 9:16	9,240	3.31	16,374,000.00	853.14
3/24/2017 9:17	9,240	3.58	17,262,000.00	853.12
3/24/2017 9:18	9,240	3.31	18,078,000.00	853.16
3/24/2017 9:19	9,240	3.24	17,640,000.00	852.92
3/24/2017 9:20	9,240	3.16	16,554,000.00	852.56
3/24/2017 9:21	9,240	3.54	16,416,000.00	852.45
3/24/2017 9:22	9,240	3.45	16,896,000.00	852.24
3/24/2017 9:23	9,240	3.21	17,790,000.00	852.66
3/24/2017 9:24	9,240	3.37	18,282,000.00	852.35
3/24/2017 9:25	9,240	3.54	18,168,000.00	852.2
3/24/2017 9:26	9,240	3.32	17,478,000.00	852.47
3/24/2017 9:27	9,240	3.34	17,904,000.00	852.61
3/24/2017 9:28	9,240	3.49	18,216,000.00	850.76
3/24/2017 9:29	9,240	3.56	18,246,000.00	850.84
3/24/2017 9:30	9,240	3.63	17,754,000.00	850.88
3/24/2017 9:31	9,240	3.64	16,734,000.00	852.05
3/24/2017 9:32	9,240	3.54	17,634,000.00	852.43
3/24/2017 9:33	9,240	3.5	17,628,000.00	852.85
3/24/2017 9:34	9,240	3.26	17,898,000.00	853.15
3/24/2017 9:35	9,240	3.37	17,190,000.00	853.07
3/24/2017 9:36	9,240	3.26	16,512,000.00	852.75
3/24/2017 9:37	9,240	3.49	16,770,000.00	853.22
3/24/2017 9:38	9,240	3.23	16,956,000.00	853.32
3/24/2017 9:39	9,240	3.19	17,610,000.00	852.93
3/24/2017 9:40	9,240	3.19	16,776,000.00	852.91
3/24/2017 9:41	9,240	3.3	17,850,000.00	853.85
3/24/2017 9:42	9,240	3.49	16,824,000.00	853.62
3/24/2017 9:43	9,240	3.44	17,904,000.00	854.19
3/24/2017 9:44	9,240	3.3	17,514,000.00	854.47
3/24/2017 9:45	9,240	3.37	17,718,000.00	854.2
3/24/2017 9:46	9,240	3.46	17,940,000.00	854.19
3/24/2017 9:47	9,240	3.53	17,058,000.00	853.99
3/24/2017 9:48	9,240	3.44	16,968,000.00	854.21
3/24/2017 9:49	9,240	3.49	17,088,000.00	855.06
3/24/2017 9:50	9,240	3.42	17,916,000.00	854.89
3/24/2017 9:51	9,240	3.46	17,772,000.00	854.71
3/24/2017 9:52	9,240	3.17	17,634,000.00	854.9
3/24/2017 9:53	9,240	3.07	17,280,000.00	853.03
3/24/2017 9:54	9,240	3.08	16,992,000.00	851.62
3/24/2017 9:55	9,240	3.28	17,862,000.00	851.95
3/24/2017 9:56	9,240	3.44	17,826,000.00	851.91
3/24/2017 9:57	9,240	3.44	17,976,000.00	852.63
3/24/2017 9:58	9,240	3.5	17,736,000.00	853.61
3/24/2017 9:59	9,240	3.44	17,988,000.00	854.8
3/24/2017 10:00	9,240	3.51	17,790,000.00	854.57
3/24/2017 10:01	9,240	3.38	17,754,000.00	855.17
3/24/2017 10:02	9,240	3.4	17,856,000.00	854.91
3/24/2017 10:03	9,240	3.35	18,198,000.00	854.86
3/24/2017 10:04	9,240	3.42	18,528,000.00	855.21
3/24/2017 10:05	9,240	3.26	17,454,000.00	853.5
3/24/2017 10:06	9,240	3.42	17,928,000.00	852.72
3/24/2017 10:07	9,240	3.5	18,294,000.00	852.64
3/24/2017 10:08	9,240	3.6	18,372,000.00	852.81
3/24/2017 10:09	9,240	3.64	17,838,000.00	852.63

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/24/2017 10:10	9,240	3.62	17,610,000.00	852.53
3/24/2017 10:11	9,240	3.6	17,772,000.00	852.45
3/24/2017 10:12	9,240	3.58	17,658,000.00	852.82
3/24/2017 10:13	9,240	3.55	17,202,000.00	853.3
3/24/2017 10:14	9,240	3.5	17,682,000.00	853.32
3/24/2017 10:15	9,240	3.4	17,112,000.00	854.05
3/24/2017 10:16	9,240	3.14	16,944,000.00	854.47
3/24/2017 10:17	9,240	2.91	17,256,000.00	855.16
3/24/2017 10:18	9,240	3.16	17,022,000.00	854.4
3/24/2017 10:19	9,240	3.14	17,148,000.00	854.28
3/24/2017 10:20	9,240	3.3	17,124,000.00	854.48
3/24/2017 10:21	9,240	3.53	17,328,000.00	855.06
3/24/2017 10:22	9,240	3.6	17,430,000.00	855.51
3/24/2017 10:23	9,240	3.45	17,676,000.00	855.96
3/24/2017 10:24	9,240	3.44	17,934,000.00	855.87
3/24/2017 10:25	9,240	3.52	18,324,000.00	855.97
3/24/2017 10:26	9,240	3.47	18,264,000.00	854.24
3/24/2017 10:27	9,240	3.75	18,174,000.00	853.92
3/24/2017 10:28	9,240	3.8	17,976,000.00	853.84
3/24/2017 10:29	9,240	3.62	18,120,000.00	854.53
3/24/2017 10:30	9,240	3.64	17,754,000.00	853.42
3/24/2017 10:31	9,240	3.62	18,228,000.00	852.01
3/24/2017 10:32	9,240	3.65	17,784,000.00	851.55
3/24/2017 10:33	9,240	3.83	17,574,000.00	851.79
3/24/2017 10:34	9,240	3.82	17,466,000.00	851.74
3/24/2017 10:35	9,240	3.79	17,286,000.00	852.8
3/24/2017 10:36	9,240	3.57	17,214,000.00	854.46
3/24/2017 10:37	9,240	3.24	17,016,000.00	855.9
3/24/2017 10:38	9,240	3.06	17,142,000.00	855.05
3/24/2017 10:39	9,240	3.31	17,064,000.00	854.37
3/24/2017 10:40	9,240	3.22	17,058,000.00	853.74
3/24/2017 10:41	9,240	3.39	17,520,000.00	854.13
3/24/2017 10:42	9,240	3.47	18,126,000.00	855.12
3/24/2017 10:43	9,240	3.42	17,730,000.00	854.97
3/24/2017 10:44	9,240	3.39	17,424,000.00	854.39
3/24/2017 10:45	9,240	3.5	17,826,000.00	855.23
3/24/2017 10:46	9,240	3.58	17,844,000.00	855.37
3/24/2017 10:47	9,240	3.35	17,532,000.00	854.99
3/24/2017 10:48	9,240	3.59	17,832,000.00	854.54
3/24/2017 10:49	9,240	3.41	17,640,000.00	853.95
3/24/2017 10:50	9,240	3.41	18,090,000.00	852.46
3/24/2017 10:51	9,240	3.8	17,592,000.00	852
3/24/2017 10:52	9,240	3.89	17,190,000.00	851.37
3/24/2017 10:53	9,240	3.8	17,424,000.00	851.45
3/24/2017 10:54	9,240	3.69	17,058,000.00	852.35
3/24/2017 10:55	9,240	3.55	17,454,000.00	853.06
3/24/2017 10:56	9,240	3.45	16,836,000.00	853.38
3/24/2017 10:57	9,240	3.5	17,712,000.00	854.17
3/24/2017 10:58	9,240	3.28	16,650,000.00	854.18
3/24/2017 10:59	9,240	3.24	16,470,000.00	854.45
3/24/2017 11:00	9,240	3.17	16,968,000.00	853.93
3/24/2017 11:01	9,240	3.26	17,142,000.00	853.85
3/24/2017 11:02	9,240	3.36	16,836,000.00	853.47
3/24/2017 11:03	9,240	3.28	16,860,000.00	853.49
3/24/2017 11:04	9,240	3.25	16,938,000.00	852.5
3/24/2017 11:05	9,240	3.16	17,754,000.00	852.65
3/24/2017 11:06	9,240	3.33	17,976,000.00	853.39
3/24/2017 11:07	9,240	3.4	17,928,000.00	853.38
3/24/2017 11:08	9,240	3.3	17,916,000.00	853.12
3/24/2017 11:09	9,240	3.29	17,718,000.00	852.36
3/24/2017 11:10	9,240	3.47	18,006,000.00	852.77
3/24/2017 11:11	9,240	3.75	17,028,000.00	852.92
3/24/2017 11:12	9,240	3.43	17,748,000.00	852.29
3/24/2017 11:13	9,240	3.47	17,250,000.00	853.03
3/24/2017 11:14	9,240	3.4	17,502,000.00	853.02
3/24/2017 11:15	9,240	3.31	17,670,000.00	853.05
3/24/2017 11:16	9,240	3.45	17,418,000.00	852.36
3/24/2017 11:17	9,240	3.73	16,986,000.00	852.48

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/24/2017 11:18	9,240	3.46	16,884,000.00	853.47
3/24/2017 11:19	9,240	3.34	17,238,000.00	853.97
3/24/2017 11:20	9,240	3.36	17,028,000.00	853.27
3/24/2017 11:21	9,240	3.12	17,880,000.00	853.63
3/24/2017 11:22	9,240	3.01	17,874,000.00	852.83
3/24/2017 11:23	9,240	3.01	17,610,000.00	851.92
3/24/2017 11:24	9,240	3.32	16,944,000.00	851.64
3/24/2017 11:25	9,240	3.48	17,514,000.00	851.54
3/24/2017 11:26	9,240	3.4	17,646,000.00	851.83
3/24/2017 11:27	9,240	3.54	17,952,000.00	852.66
3/24/2017 11:28	9,240	3.33	17,862,000.00	852.08
3/24/2017 11:29	9,240	3.35	17,694,000.00	852.85
3/24/2017 11:30	9,240	3.42	17,208,000.00	853.08
3/24/2017 11:31	9,240	3.38	17,040,000.00	853.1
3/24/2017 11:32	9,240	3.2	17,478,000.00	853.37
3/24/2017 11:33	9,240	3.22	18,042,000.00	852.31
3/24/2017 11:34	9,240	3.26	17,124,000.00	851.72
3/24/2017 11:35	9,240	3.31	17,364,000.00	851.57
3/24/2017 11:36	9,240	3.36	17,820,000.00	851.78
3/24/2017 11:37	9,240	3.47	16,890,000.00	853.01
3/24/2017 11:38	9,240	3.42	17,232,000.00	853.34
3/24/2017 11:39	9,240	3.2	17,742,000.00	853.4
3/24/2017 11:40	9,240	3.27	17,586,000.00	853.33
3/24/2017 11:41	9,240	3.25	17,328,000.00	853.31
3/24/2017 11:42	9,240	3.24	17,754,000.00	852.98
3/24/2017 11:43	9,240	3.3	17,604,000.00	853.35
3/24/2017 11:44	9,240	3.35	17,526,000.00	853.92
3/24/2017 11:45	9,240	3.39	18,096,000.00	854.29
3/24/2017 11:46	9,240	3.25	17,970,000.00	853.46
3/24/2017 11:47	9,240	3.49	17,472,000.00	853.25
3/24/2017 11:48	9,240	3.75	18,042,000.00	853.4
3/24/2017 11:49	9,240	3.6	18,144,000.00	853.64
3/24/2017 11:50	9,240	3.5	18,456,000.00	852.69
3/24/2017 11:51	9,240	3.31	18,126,000.00	852.04
3/24/2017 11:52	9,240	3.43	18,390,000.00	850.82
3/24/2017 11:53	9,240	3.53	17,814,000.00	850.67
3/24/2017 11:54	9,240	3.55	18,030,000.00	850.93
3/24/2017 11:55	9,240	3.67	17,778,000.00	850.92
3/24/2017 11:56	9,240	3.5	17,640,000.00	850.4
3/24/2017 11:57	9,240	3.4	17,274,000.00	851.57
3/24/2017 11:58	9,240	3.47	17,538,000.00	852.59
3/24/2017 11:59	9,240	3.17	16,470,000.00	852.68
3/24/2017 12:00	9,240	3.26	16,620,000.00	853.53
3/24/2017 12:01	9,240	3	17,160,000.00	853.64
3/24/2017 12:02	9,240	3.1	17,520,000.00	853.26
3/24/2017 12:03	9,240	3.18	17,364,000.00	852.99
3/24/2017 12:04	9,240	3.24	17,838,000.00	854.06
3/24/2017 12:05	9,240	3.04	17,724,000.00	854.02
3/24/2017 12:06	9,240	3.16	17,760,000.00	853.53
3/24/2017 12:07	9,240	3.42	17,886,000.00	853.1
3/24/2017 12:08	9,240	3.53	18,546,000.00	853.2
3/24/2017 12:09	9,240	3.72	18,384,000.00	853.36
3/24/2017 12:10	9,240	3.57	18,180,000.00	854.58
3/24/2017 12:11	9,240	3.44	18,162,000.00	853.81
3/24/2017 12:12	9,240	3.47	18,030,000.00	852.96
3/24/2017 12:13	9,240	3.42	18,114,000.00	852.73
3/24/2017 12:14	9,240	3.46	18,198,000.00	852.13
3/24/2017 12:15	9,240	3.47	18,048,000.00	851.4
3/24/2017 12:16	9,240	3.44	17,940,000.00	850.67
3/24/2017 12:17	9,240	3.64	18,018,000.00	850.49
3/24/2017 12:18	9,240	3.72	18,018,000.00	851.52
3/24/2017 12:19	9,240	3.68	18,246,000.00	852.48
3/24/2017 12:20	9,240	3.56	17,592,000.00	853.92
3/24/2017 12:21	9,240	3.28	17,688,000.00	853.69
3/24/2017 12:22	9,240	3.17	17,472,000.00	854.1
3/24/2017 12:23	9,240	3.18	17,454,000.00	853.65
3/24/2017 12:24	9,240	3.25	17,604,000.00	853.8
3/24/2017 12:25	9,240	3.28	17,610,000.00	854.46

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/24/2017 12:26	9,240	3.18	17,634,000.00	854.6
3/24/2017 12:27	9,240	3.06	17,598,000.00	854.93
3/24/2017 12:28	9,240	3.25	17,688,000.00	855.33
3/24/2017 12:29	9,240	3.42	18,054,000.00	855.75
3/24/2017 12:30	9,240	3.28	17,592,000.00	854.94
3/24/2017 12:31	9,240	3.43	17,952,000.00	854.88
3/24/2017 12:32	9,240	3.56	18,252,000.00	855
3/24/2017 12:33	9,240	3.65	18,258,000.00	855.32
3/24/2017 12:34	9,240	3.33	18,126,000.00	854.88
3/24/2017 12:35	9,240	3.43	18,486,000.00	854.69
3/24/2017 12:36	9,240	3.47	18,240,000.00	855.21
3/24/2017 12:37	9,240	3.36	17,988,000.00	853.97
3/24/2017 12:38	9,240	3.56	18,102,000.00	853.45
3/24/2017 12:39	9,240	3.78	18,282,000.00	853.44
3/24/2017 12:40	9,240	3.58	17,850,000.00	853.59
3/24/2017 12:41	9,240	3.54	17,796,000.00	853.87
3/24/2017 12:42	9,240	3.59	17,688,000.00	853.82
3/24/2017 12:43	9,240	3.7	18,036,000.00	854.54
3/24/2017 12:44	9,240	3.74	17,610,000.00	855.07
3/24/2017 12:45	9,240	3.38	17,700,000.00	856.37
3/24/2017 12:46	9,240	3.21	17,778,000.00	855.94
3/24/2017 12:47	9,240	3.32	17,844,000.00	855.75
3/24/2017 12:48	9,240	3.28	17,928,000.00	854.55
3/24/2017 12:49	9,240	3.4	17,868,000.00	854.1
3/24/2017 12:50	9,240	3.32	17,778,000.00	853.81
3/24/2017 12:51	9,240	3.32	17,994,000.00	854.51
3/24/2017 12:52	9,240	3.34	18,168,000.00	853.64
3/24/2017 12:53	9,240	3.34	18,156,000.00	853.08
3/24/2017 12:54	9,240	3.48	17,706,000.00	853.88
3/24/2017 12:55	9,240	3.59	17,994,000.00	854.38
3/24/2017 12:56	9,240	3.56	18,060,000.00	854.33
3/24/2017 12:57	9,240	3.46	18,306,000.00	854.13
3/24/2017 12:58	9,240	3.43	17,964,000.00	853.74
3/24/2017 12:59	9,240	3.43	17,994,000.00	853.03
3/24/2017 13:00	9,240	3.5	17,820,000.00	853.23
3/24/2017 13:01	9,240	3.62	17,928,000.00	853.13
3/24/2017 13:02	9,240	3.47	17,670,000.00	853.4
3/24/2017 13:03	9,240	3.23	17,556,000.00	854.24
3/24/2017 13:04	9,240	3.35	17,496,000.00	854.22
3/24/2017 13:05	9,240	3.39	17,880,000.00	853.26
3/24/2017 13:06	9,240	3.51	17,550,000.00	852.57
3/24/2017 13:07	9,240	3.32	17,772,000.00	853.36
3/24/2017 13:08	9,240	3.45	17,634,000.00	854.24
3/24/2017 13:09	9,240	3.43	17,448,000.00	855.02
3/24/2017 13:10	9,240	3.21	17,736,000.00	855.04
3/24/2017 13:11	9,240	3.38	17,466,000.00	855.07
3/24/2017 13:12	9,240	3.19	18,072,000.00	854.91
3/24/2017 13:13	9,240	3.31	17,784,000.00	854.53
3/24/2017 13:14	9,240	3.47	18,174,000.00	854.66
3/24/2017 13:15	9,240	3.54	18,138,000.00	854.45
3/24/2017 13:16	9,240	3.54	17,856,000.00	853.26
3/24/2017 13:17	9,240	3.48	17,922,000.00	853.55
3/24/2017 13:18	9,240	3.39	18,084,000.00	853.02
3/24/2017 13:19	9,240	3.55	18,108,000.00	851.48
3/24/2017 13:20	9,240	3.77	18,180,000.00	852.5
3/24/2017 13:21	9,240	3.74	18,084,000.00	853.25
3/24/2017 13:22	9,240	3.64	17,106,000.00	853
3/24/2017 13:23	9,240	3.62	17,526,000.00	853.5
3/24/2017 13:24	9,240	3.33	17,478,000.00	853.84
3/24/2017 13:25	9,240	3.23	17,382,000.00	854.65
3/24/2017 13:26	9,240	3.02	17,454,000.00	853.76
3/24/2017 13:27	9,240	3.21	17,118,000.00	852.89
3/24/2017 13:28	9,240	3.42	16,788,000.00	853.84
3/24/2017 13:29	9,240	3.24	17,568,000.00	853.76
3/24/2017 13:30	9,240	3.32	17,496,000.00	853.98
3/24/2017 13:31	9,240	3.44	17,406,000.00	853.23
3/24/2017 13:32	9,240	3.37	18,048,000.00	853.28
3/24/2017 13:33	9,240	3.59	17,976,000.00	853.36

Date/Time	BFB1: FD_WOOD (DSCFMMBTU)	BFB1: O2_P60 (PCT)	BFB1: STACK_FLOW_SCFH_P60 (SCFH)	BFB1: STEAM (KLBHR) Raw Value
3/24/2017 13:34	9,240	3.58	17,820,000.00	854.76
3/24/2017 13:35	9,240	3.48	18,498,000.00	855.83
3/24/2017 13:36	9,240	3.27	18,336,000.00	854.24
3/24/2017 13:37	9,240	3.53	18,366,000.00	852.57
3/24/2017 13:38	9,240	3.67	18,132,000.00	852.54
3/24/2017 13:39	9,240	3.66	18,498,000.00	853.33
3/24/2017 13:40	9,240	3.53	17,928,000.00	853.24
3/24/2017 13:41	9,240	3.52	17,808,000.00	852.3
3/24/2017 13:42	9,240	3.6	17,448,000.00	852.57
3/24/2017 13:43	9,240	3.44	17,658,000.00	853.06
3/24/2017 13:44	9,240	3.39	17,466,000.00	853.15
3/24/2017 13:45	9,240	3.23	16,272,000.00	853.74
				853.22

Appendix B: Mathematical Equations

Example Calculations from Run 1

Volume of Water Collected (scf)

$$V_{w(std)} = 0.04707(V_t)$$

Where:

V_t	= Total Volume of liquid collected in impingers, ml	=	<u>0.00</u>	ml
0.04707	= Water Volume to Standard Water Vapor (ft ³ /ml)	=	<u>0.04707</u>	ft ³ /ml
$V_{wc(std)}$	= Volume of Water Vapor, Corrected to Standard Conditions (scf)	=	<u>0.00</u>	scf

Volume of Water Collected, by weight (scf)

$$V_{w(std)} = 0.04715(W_t)$$

Where:

W_t	= Total mass of liquid collected in impingers, g	=	<u>717.50</u>	g
0.04715	= Water Volume to Standard Water Vapor (ft ³ /ml)	=	<u>0.04715</u>	ft ³ /ml
$V_{wsg(std)}$	= Volume of Water Vapor, Corrected to Standard Conditions (scf)	=	<u>33.83</u>	scf

Volume of dry gas sampled at standard conditions (dscf)

$$V_{m(std)} = V_m Y \frac{T_{std} \left(P_{bar} + \frac{\Delta H}{13.6} \right)}{T_m P_{std}}$$

Where:

V_m	= Volume of Gas Sampled, as Measured by the Dry Gas Meter (dcf)	=	<u>133.82</u>	dcf
Y	= Dry Gas Meter Calibration Factor	=	<u>1.012</u>	
P_{bar}	= Barometric Pressure at the Sample Location (in. Hg)	=	<u>29.93</u>	in. Hg
T_{std}	= Standard Absolute Temperature, (528°R)	=	<u>528.00</u>	°R
ΔH	= Average Differential Pressure Across the Orifice Meter (in. H ₂ O)	=	<u>2.01</u>	in. H ₂ O
13.6	= Specific Gravity of Mercury (in. H ₂ O/in. Hg)	=	<u>13.60</u>	in. H ₂ O/in. Hg
T_m	= Average Absolute Dry Gas Meter Temperature (°F+460)(°R)	=	<u>548.19</u>	°R
P_{std}	= Standard Absolute Pressure (29.92 in. Hg)	=	<u>29.92</u>	in. Hg
$V_{m(std)}$	= Volume of Gas Measured by the Dry Gas Meter, Corrected to Standard Conditions (dscf)	=	<u>131.13</u>	dscf

Portion of Water Vapor in Gas Stream, by Volume

$$B_{ws} = 100 * \frac{V_{wc(std)} + V_{wsg(std)}}{(V_{wc(std)} + V_{wsg(std)}) + V_{m(std)}}$$

Where:

$V_{wc(std)}$	= Volume of Water Vapor, Corrected to Standard Conditions (scf)	=	<u>0.00</u>	scf
$V_{wsg(std)}$	= Volume of Water Vapor, Corrected to Standard Conditions (scf)	=	<u>33.83</u>	scf
$V_{m(std)}$	= Volume of Gas Measured by the Dry Gas Meter, Corrected to Standard Conditions (dscf)	=	<u>131.13</u>	dscf
B_{ws}	= Portion of Water Vapor in the Gas Stream (% by volume)	=	<u>20.5</u>	%

Molecular Weight of Dry Stack Gas, lb/lb-mole

$$M_d = 0.440(\%CO_2) + 0.320(\%O_2) + 0.280(\%N_2 + \%CO)$$

Where:

0.44	= Molecular Weight of CO ₂ , divided by 100	=	<u>0.44</u>	lb/lb-mole
0.32	= Molecular Weight of O ₂ , divided by 100	=	<u>0.32</u>	lb/lb-mole
0.28	= Molecular Weight of N ₂ or CO, divided by 100	=	<u>0.28</u>	lb/lb-mole
%CO ₂	= Percent CO ₂ by Volume, dry basis (%)	=	<u>17.30</u>	%
%O ₂	= Percent O ₂ by Volume, dry basis (%)	=	<u>3.30</u>	%
%N ₂	= Percent N ₂ by Volume, dry basis (%)	=	<u>79.40</u>	%
%CO	= Percent CO by Volume, dry basis (%)	=	<u>0.00</u>	%
M _d	= Dry Molecular Weight of Sample Gas (lb/lb-mole)	=	<u>30.90</u>	lb/lb-mole

Molecular Weight of Wet Stack Gas, lb/lb-mole

$$M_w = M_d \left(1 - \frac{B_{ws}}{100} \right) + \left(18 \frac{B_{ws}}{100} \right)$$

Where:

M _d	= Dry Molecular Weight of Sample Gas (lb/lb-mole)	=	<u>30.90</u>	lb/lb-mole
B _{ws}	= Portion of Water Vapor in the Gas Stream (% by volume)	=	<u>20.43</u>	%
100	= Convert % Water to Fraction	=	<u>100.00</u>	
18	= Molecular Weight of Water, (lb/lb-mole)	=	<u>18.00</u>	lb/lb-mole
M _w	= Wet Molecular Weight of Sample Gas (lb/lb-mole)	=	<u>28.26</u>	lb/lb-mole

Calculated Fuel Factor

$$F_o = \frac{20.9 - \%O_s}{\%CO_2}$$

Where:

20.9	= Percent of O ₂ in ambient air (%)	=	<u>20.90</u>	%
%CO ₂	= Percent CO ₂ by Volume, dry basis (%)	=	<u>17.30</u>	%
%O ₂	= Percent O ₂ by Volume, dry basis (%)	=	<u>3.30</u>	%
F _o	= Fuel Factor	=	<u>1.017</u>	

Percent Excess Air

$$\%EA = \frac{\%O_2 - 0.5\%CO}{0.264\%N_2 - (\%O_2 - 0.5\%CO)} \times 100$$

Where:

%O ₂	= Percent O ₂ by Volume, dry basis (%)	=	<u>3.30</u>	%
%CO	= Percent CO by Volume, dry basis (%)	=	<u>0.00</u>	%
0.264	= Ratio of O ₂ to N ₂ in air (v/v)	=	<u>0.264</u>	
%N ₂	= Percent N ₂ by Volume, dry basis (%)	=	<u>79.40</u>	%
%EA	= Percent of Excess Air in Sample Gas (%)	=	<u>18.68</u>	%

Average Stack Gas Velocity

$$V_s = K_p C_p \left(\sqrt{\Delta P_{avg}} \right) \sqrt{\frac{T_s + 460}{M_w P_s}}$$

Where:

K _p	= Velocity Equation Constant	=	<u>85.49</u>	
C _p	= Pitot Tube Coefficient	=	<u>0.84</u>	
$\sqrt{\Delta P_{avg}}$	= Average Square Roots of Velocity Head Readings (in. H ₂ O)	=	<u>0.94</u>	Sq. Root in. H ₂ O
T _s	= Average Sample Gas Temperature (°F)	=	<u>334.44</u>	°F
460	= °F to °R Conversion Constant	=	<u>460.00</u>	
M _w	= Wet Molecular Weight of Sample Gas (lb/lb-mole)	=	<u>28.26</u>	lb/lb-mole
P _s	= Absolute Sample Gas Pressure (in. Hg)	=	<u>29.89</u>	in. Hg
V _s	= Average Stack Gas Velocity (ft/sec)	=	<u>65.36</u>	ft/sec

Actual Stack Gas Flow Rate

$$Q_{aw} = 60A_s V_s$$

Where:

60	= Conversion Factor (sec/min)	=	<u>60.00</u>	
A_s	= Cross Sectional Area of the Sample Location (ft ²)	=	<u>112.31</u>	ft ²
V_s	= Average Stack Gas Velocity (ft/sec)	=	<u>65.36</u>	ft/sec
Q_{aw}	= Actual Stack Gas Flow Rate at actual conditions (acfm)	=	<u>440452</u>	acfm

Dry Standard Sample Gas Flow Rate

$$Q_{sd} = 60 \left(1 - \frac{B_{ws}}{100} \right) V_s A_s \left[\frac{T_{std} P_s}{(T_s + 460) P_{std}} \right]$$

Where:

60	= Conversion Factor (sec/min)	=	<u>60.00</u>	
B_{ws}	= Portion of Water Vapor in the Gas Stream (% by volume)	=	<u>20.43</u>	%
V_s	= Average Stack Gas Velocity (ft/sec)	=	<u>65.36</u>	ft/sec
A_s	= Cross Sectional Area of the Sample Location (ft ²)	=	<u>112.31</u>	ft ²
T_{std}	= Standard Absolute Temperature (°R)	=	<u>528.00</u>	°R
P_s	= Absolute Sample Gas Pressure (in. Hg)	=	<u>29.89</u>	in. Hg
T_s	= Average Sample Gas Temperature (°F)	=	<u>334.44</u>	°F
460	= °F to °R Conversion Constant	=	<u>460.00</u>	
P_{std}	= Standard Absolute Pressure (29.92 in. Hg)	=	<u>29.92</u>	in. Hg
Q_{sd}	= Dry Volumetric Sample Gas Flow Rate, Corrected to Standard Conditions	=	<u>232703</u>	dscfm

Wet Standard Sample Gas Flow Rate

$$Q_{sw} = \left(\frac{Q_{sd}}{1 - \left(\frac{B_{ws}}{100} \right)} \right) \frac{60}{1000}$$

Where:

Q_{sd}	= Dry Volumetric Sample Gas Flow Rate, Corrected to Standard Conditions	=	<u>232702.57</u>	dscfm
B_{ws}	= Portion of Water Vapor in the Gas Stream (% by volume)	=	<u>20.43</u>	%
100	= Convert % Water to Fraction	=	<u>100</u>	
60	= Conversion Factor (min/hr)	=	<u>60</u>	
1000	= Conversion Factor (wscfh/wkscfh)	=	<u>1000</u>	
Q_{sw}	= Wet Volumetric Sample Gas Flow Rate, Corrected to Standard Conditions	=	<u>17547</u>	wkscfh

Percent of Isokinetic Rate

$$I = \frac{(T_s + 460)V_{m(std)}P_{std}100}{T_{std}V_s\pi\left(\frac{D_n}{12}\right)^2 60\Theta\left(1 - \left(\frac{B_{ws}}{100}\right)\right)}$$

where:

T_s	= Average Sample Gas Temperature (°F)	=	<u>334.44</u>	°F
460	= °F to °R Conversion Constant	=	<u>460</u>	
$V_{m(std)}$	= Volume of Gas Measured by the Dry Gas Meter, Corrected to Standard Conditions (dscf)	=	<u>131.78</u>	dscf
P_{std}	= Standard Absolute Pressure (29.92 in. Hg)	=	<u>29.92</u>	in. Hg
P_s	= Absolute Sample Gas Pressure (in. Hg)	=	<u>29.89</u>	in. Hg
V_s	= Average Stack Gas Velocity (ft/sec)	=	<u>65.36</u>	ft/sec
D_n	= Inner Diameter of nozzle (in.)	=	<u>0.257</u>	in.
100	= Conversion to Percent	=	<u>100</u>	
T_{std}	= Standard Absolute Temperature (°R)	=	<u>528</u>	°R
12	= Conversion from inches to feet	=	<u>12</u>	
60	= Conversion Factor (min/hr)	=	<u>60</u>	
Θ	= Total Sampling Time (min.)	=	<u>180.0</u>	min
B_{ws}	= Portion of Water Vapor in the Gas Stream (% by volume)	=	<u>20.43</u>	%
I	= Percent of Isokinetic Sampling (%)	=	<u>98.08</u>	%

Total Mass of Particulates

$$M_n = M_f + M_a - W_a$$

where:

M_f	= Mass of particulate in the filter (mg)	=	<u>0.00</u>	mg
M_a	= Mass of Particulate in acetone rinse (mg)	=	<u>4.80</u>	mg
W_a	= Mass of Acetone Blank (mg)	=	<u>0.00</u>	mg
M_n	= Total Mass of Particulate Matter Collected during Test Run (mg)	=	<u>4.80</u>	mg

Concentration of Particulate Matter in Gas Sample

$$C_s = \frac{0.001M_n}{V_{m(std)}}$$

where:

0.001	= Conversion constant (g/mg)	=	<u>0.001</u>	
M_n	= Total Mass of Particulate Matter Collected during Test Run (mg)	=	<u>4.80</u>	mg
$V_{m(std)}$	= Volume of Gas Measured by the Dry Gas Meter, Corrected to Standard Conditions (dscf)	=	<u>131.78</u>	dscf
C_s	= Concentration of Particulate Matter (g/dscf)	=	<u>0.000</u>	g/dscf

Concentration of Particulate Matter in Gas Sample

$$C_s = \frac{0.0154 M_n}{V_{m(std)}}$$

where:

0.0154	= Conversion Constant (gr/mg)	=	<u>0.0154</u>	
M _n	= Total Mass of Particulate Matter Collected during Test Run (mg)	=	<u>4.80</u>	mg
V _{m(std)}	= Volume of Gas Measured by the Dry Gas Meter, Corrected to Standard Conditions (dscf)	=	<u>131.78</u>	dscf
C _s	= Concentration of Particulate Matter (gr/dscf)	=	<u>0.001</u>	gr/dscf

Particulate Emissions Rate (kg/hr)

$$E = \frac{C_s Q_{sd} 60}{1000}$$

where:

C _s	= Concentration of Particulate Matter (g/dscf)	=	<u>0.00</u>	g/dscf
Q _{sd}	= Dry Volumetric Sample Gas Flow Rate, Corrected to Standard Conditions	=	<u>232702.57</u>	dscfm
60	= Conversion Constant (min/hr)	=	<u>60</u>	
1000	= Conversion Constant (g/kg)	=	<u>1000</u>	
E	= Particulate Emissions Rate (kg/hr)	=	<u>0.51</u>	kg/hr

Particulate Emissions Rate (lbs/hr)

$$E = \frac{\left(\frac{60}{453.592}\right)\left(\frac{M_n}{1000}\right)}{V_{m(std)}} \times Q_{sd}$$

where:

60	= Conversion Constant (min/hr)	=	<u>60</u>	
453.592	= Conversion Constant (g/lb)	=	<u>453.592</u>	
1000	= Conversion Constant (mg/g)	=	<u>1000</u>	
M _n	= Total Mass of Particulate Matter Collected during Test Run (mg)	=	<u>4.80</u>	mg
V _{m(std)}	= Volume of Gas Measured by the Dry Gas Meter, Corrected to Standard Conditions (dscf)	=	<u>131.78</u>	dscf
Q _{sd}	= Dry Volumetric Sample Gas Flow Rate, Corrected to Standard Conditions	=	<u>232702.57</u>	dscfm
E	= Particulate Emissions Rate (lb/hr)	=	<u>1.12</u>	lb/hr

Particulate Emissions Rate (lbs/mmBtu, O₂)

$$E = \left(\frac{\frac{M_n}{1000}}{V_{m(std)} 453.592} \right) F_d \left(\frac{20.9}{20.9 - \%O_2} \right)$$

where:

M _n	= Total Mass of Particulate Matter Collected during Test Run (mg)	=	<u>4.80</u>	mg
1000	= Conversion Constant (mg/g)	=	<u>1000</u>	
V _{m(std)}	= Volume of Gas Measured by the Dry Gas Meter, Corrected to Standard Conditions (dscf)	=	<u>131.78</u>	dscf
453.592	= Conversion Constant (g/lb)	=	<u>453.592</u>	
F _d	= Ratio of Gas Volume to Heat Content of Fuel (dscf/mmBtu)	=	<u>9240.00</u>	dscf/mmBtu
20.9	= Percent of O ₂ in ambient air (%)	=	<u>20.90</u>	%
%O ₂	= Percent O ₂ by Volume, dry basis (%)	=	<u>3.30</u>	%
E	= Particulate Emissions Rate (lb/mmBtu, O ₂)	=	<u>0.0009</u>	lb/mmBtu, O ₂

Example Calculations From Run 1

Calculation of Breakthrough Trap A

$$B = \frac{m_2}{m_1} \times 100$$

Where:

B=Breakthrough	=	<u>1</u>	%
m ₂ = Mass of Hg measured on sorbent trap section 2	=	<u>0.647</u>	ng
m ₁ = Mass of Hg measured on sorbent trap section 1	=	<u>112.425</u>	ng

Calculation of Breakthrough Trap B

$$B = \frac{m_2}{m_1} \times 100$$

Where:

B= Breakthrough	=	<u>0</u>	%
m ₂ = Mass of Hg measured on sorbent trap section 2	=	<u>0.338</u>	ng
m ₁ = Mass of Hg measured on sorbent trap section 1	=	<u>79.775</u>	ng

Calculation of Hg Concentration Trap A

$$C_a = \frac{(m_1 + m_2) - spike}{V_t}$$

Where:

C _a = Concentration of Hg for the sample collection period, for sorbent trap A	=	<u>0.497</u>	µg/dscm
m ₁ = Mass of Hg measured on sorbent trap section 1	=	<u>112.425</u>	ng
m ₂ = Mass of Hg measured on sorbent trap section 2	=	<u>0.647</u>	ng
spike = Mass of Hg spike concentration	=	<u>50.000</u>	ng
V _t = Total volume of dry gas metered corrected STP defined as to 20° C and 760 mm Hg	=	<u>126.913</u>	L

Calculation of Hg Concentration Trap B

$$C_b = \frac{(m_1 + m_2) - spike}{V_t}$$

Where:

C_b = Concentration of Hg for the sample collection period, for sorbent trap B	=	<u>0.633</u>	µg/dscm
m_1 = Mass of Hg measured on sorbent trap section 1	=	<u>79.775</u>	ng
m_2 = Mass of Hg measured on sorbent trap section 2	=	<u>0.338</u>	ng
spike = Mass of Hg spike concentration	=	<u>0.000</u>	ng
V_t = Total volume of dry gas metered corrected STP defined as to 20° C and 760 mm Hg	=	<u>126.476</u>	L

Calculation of Average Hg Concentration

$$Ave\ Conc = \frac{1}{2} (C_a + C_b)$$

Where:

C_a = Concentration of Hg for the sample collection period, for sorbent trap A	=	<u>0.497</u>	µg/dscm
C_b = Concentration of Hg for the sample collection period, for sorbent trap B	=	<u>0.633</u>	µg/dscm
Average Concentration	=	<u>0.565</u>	µg/dscm

Moisture Correction Calculation

$$C_w = C_d \times (1 - B_{ws})$$

Where:

C_w = Hg concentration, wet basis (µg/dscm)	=	<u>0.486</u>	µg/dscm
C_d = Hg concentration, dry basis (µg/dscm)	=	<u>0.565</u>	µg/dscm
B_{ws} = Moisture content of sample gas as measured by Method 4, percent/100.	=	<u>0.14</u>	%/100

Calculation of Paired Trap Agreement

$$RD = \frac{|C_a - C_b|}{C_a + C_b} \times 100$$

Where:

RD = Relative deviation between the Hg concentrations from traps "a" and "b" (%)	=	<u>12</u>	%
C_a = Concentration of Hg for the sample collection period, for sorbent trap A	=	<u>0.497</u>	µg/dscm
C_b = Concentration of Hg for the sample collection period, for sorbent trap B	=	<u>0.633</u>	µg/dscm

Calculation of Measured Spike Hg Concentration

$$C_{rec} = \frac{m_s}{v_s} - \frac{m_u}{v_u}$$

Where:

C_{rec} = Concentration of spiked compound measured ($\mu\text{g}/\text{m}^3$)	=	<u>0.258</u>	$\mu\text{g}/\text{m}^3$
m_s = Total mass of Hg measured on spiked trap in Field Recovery Test (μg).	=	<u>0.113</u>	μg
m_u = Total mass of Hg measured on unspiked trap in Field Recovery Test (μg).	=	<u>0.080</u>	μg
v_s = Volume of gas sampled, spiked trap in Field Recovery Test (dscm).	=	<u>0.127</u>	dscm
v_u = Volume of gas sampled, unspiked trap in Field Recovery Test (dscm).	=	<u>0.126</u>	dscm

Calculation of Spiked Hg Recovery

$$R = \frac{C_{rec} \times v_s}{m_{spiked}} \times 100$$

Where:

R = Percentage of spiked mass recovered. (%)	=	<u>65</u>	%
C_{rec} = Concentration of spiked compound measured ($\mu\text{g}/\text{m}^3$)	=	<u>0.258</u>	$\mu\text{g}/\text{m}^3$
v_s = Volume of gas sampled, spiked trap in Field Recovery Test (dscm).	=	<u>0.127</u>	dscm
m_{spiked} = Mass of Hg spiked in Analytical Bias of Field Recovery Test (μg).	=	<u>0.050</u>	μg

Appendix C: Sample Location Diagram/Traverse Points

CEM Solutions, Inc.
**METHOD 1: Determining Number of Particulate and Velocity Traverse Points
for a Stack or Duct**

Company:	GREC	Date:	9/30/2014
Facility:	Gainesville	Project:	7864
Unit Number:	1	Operator:	C. Horton
Sample Location:	Stack		


Stack Measurements			
Shape of Stack:	Circular	Stack Diameter:	143.50 Inches
# of Test Ports:	4	Stack Area:	112.3133 ft ²
Port Depth:	8 Inches		

Distance from Test Ports to Disturbances			
Distance Upstream:	222.00 Inches (A)	Distance Downstream:	1326.00 Inches (B)
Diameters Upstream:	1.55 (A _D)	Diameters Downstream:	9.24 (B _D)

Minimum # of Velocity Traverse Points		
From Upstream:	16	
From Downstream:	12	
12-24in Diameter?	False	
Points to be used:	16	


Minimum # of Particulate Traverse Points		
From Upstream:	16	
From Downstream:	12	
12-24in Diameter?	False	
Points to be used:	16	

Single Point			
Sample taken from the following point:			
Traverse Point	Distance	Distance from stack wall (Inches)	Distance including port depth (Inches)
1	1 Meter	39.37	47.37



Test Matrix Diagrams

12 Point Traverse			
Determined according to 40CFR60 Appendix A, Method 1, Figures 1-1 and 1-2. Sample taken from the following points:			
Traverse Point	% of diameter	Distance from stack wall (Inches)	Distance including port depth (Inches)
1	4.4	6.31	14.31
2	14.6	20.95	28.95
3	29.6	42.48	50.48
4	70.4	101.02	109.02
5	85.4	122.55	130.55
6	95.6	137.19	145.19




Test Matrix Diagrams

16 Point Traverse

Determined according to 40CFR60 Appendix A, Method 1, Figures 1-1 and 1-2. Sample taken from the following points:

Traverse Point	% of diameter	Distance from stack wall (Inches)	Distance including port depth (Inches)
1	3.2	4.59	12.59
2	10.5	15.07	23.07
3	19.4	27.84	35.84
4	32.3	46.35	54.35
5	67.7	97.15	105.15
6	80.6	115.66	123.66
7	89.5	128.43	136.43
8	96.8	138.91	146.91



Test Matrix Diagrams

Appendix D: Reference Method QA/QC

Appendix D-1: Instrumental Method QA/QC

Analyzer Calibration Error Tests
Bias and Drift Tests
Calibration Gas Cylinder Certificates of Analysis

Analyzer Calibration Error

Test Performed For:
GREC
Gainesville
Boiler 1
Compliance
Date:3/22/17

Test Performed By:
C.E.M. Solutions, Inc.
1183 E. Overdrive Circle
Hernando, FL 34442
(352) 489-4337
THC Run 1

Oxygen Monitor

Full Scale: 100.00 %

Method 3A

Serial Number: 1151210012

Cylinder Number	Reference Gas Concentration	Analyzer Response	Difference	Calibration Error (%)
CC263051/cg1	0.00 %	0.05 %	0.05 %	0.24 %
EB0070863/cg2	10.11 %	10.27 %	0.16 %	0.78 %
CC221880/cg3	20.61 %	20.67 %	0.06 %	0.29 %

Carbon Dioxide Monitor

Full Scale: 20.00 %

Method 3A

Serial Number: 1151210012

Cylinder Number	Reference Gas Concentration	Analyzer Response	Difference	Calibration Error (%)
CC263051/cg1	0.00 %	-0.20 %	-0.20 %	-1.04 %
EB0070863/cg2	9.44 %	9.48 %	0.04 %	0.22 %
CC221880/cg3	19.26 %	19.41 %	0.15 %	0.78 %

Total Hydrocarbon Monitor

Full Scale: 30.0 ppm

Method 25A

Serial Number: 1106047146

Cylinder Number	Reference Gas Concentration	Analyzer Response	Difference	Calibration Error (%)
CC281749/cg14	0.0 ppm	0.0 ppm	0.0 ppm	N/A
CC453989/cg11	8.93 ppm	8.6 ppm	-0.3 ppm	-3.65 %
CC454100/cg12	15.20 ppm	15.2 ppm	0.0 ppm	0.00 %
CC458494/cg13	25.53 ppm	26.5 ppm	1.0 ppm	3.80 %

Analyzer Calibration Error

Test Performed For:
GREC
Gainesville
Boiler 1
Compliance
Date:3/23/17

Test Performed By:
C.E.M. Solutions, Inc.
1183 E. Overdrive Circle
Hernando, FL 34442
(352) 489-4337
THC Run 3

Oxygen Monitor

Full Scale: 100.00 %

Method 3A

Serial Number: 1151210012

Cylinder Number	Reference Gas Concentration	Analyzer Response	Difference	Calibration Error (%)
CC263051/cg1	0.00 %	0.09 %	0.09 %	0.44 %
EB0070863/cg2	10.11 %	10.31 %	0.20 %	0.97 %
CC221880/cg3	20.61 %	20.72 %	0.11 %	0.53 %

Carbon Dioxide Monitor

Full Scale: 20.00 %

Method 3A

Serial Number: 1151210012

Cylinder Number	Reference Gas Concentration	Analyzer Response	Difference	Calibration Error (%)
CC263051/cg1	0.00 %	-0.21 %	-0.21 %	-1.09 %
EB0070863/cg2	9.44 %	9.45 %	0.01 %	0.07 %
CC221880/cg3	19.26 %	19.39 %	0.13 %	0.67 %

Total Hydrocarbon Monitor

Full Scale: 30.0 ppm

Method 25A

Serial Number: 1106047146

Cylinder Number	Reference Gas Concentration	Analyzer Response	Difference	Calibration Error (%)
CC281749/cg14	0.0 ppm	0.0 ppm	0.0 ppm	N/A
CC453989/cg11	8.93 ppm	8.7 ppm	-0.2 ppm	-2.53 %
CC454100/cg12	15.20 ppm	15.0 ppm	-0.2 ppm	-1.32 %
CC458494/cg13	25.53 ppm	26.6 ppm	1.1 ppm	4.19 %

Sampling System Bias and Drift

Test Performed For:
GREC
Gainesville
Boiler 1
Compliance
Date:3/22/17

Test Performed By:
C.E.M. Solutions, Inc.
1183 E. Overdrive Circle
Hernando, FL 34442
(352) 489-4337
THC Run 1

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
O ₂	0.05 %	0.49 %	2.13 %	0.43 %	1.84 %	-0.29 %
O ₂	10.27 %	10.55 %	1.36 %	10.38 %	0.53 %	-0.82 %
CO ₂	-0.20 %	-0.10 %	0.52 %	-0.15 %	0.26 %	-0.26 %
CO ₂	9.48 %	9.12 %	-1.87 %	9.13 %	-1.82 %	0.05 %
THC	0.0 ppm	0.0 ppm	0.00 %	0.0 ppm	0.00 %	0.00 %
THC	15.2 ppm	14.4 ppm	-2.67 %	14.9 ppm	-1.00 %	1.67 %

Sampling System Bias and Drift

Test Performed For:
GREC
Gainesville
Boiler 1
Compliance
Date:3/22/17

Test Performed By:
C.E.M. Solutions, Inc.
1183 E. Overdrive Circle
Hernando, FL 34442
(352) 489-4337
THC Run 2

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
O ₂	0.05 %	0.43 %	1.84 %	0.48 %	2.09 %	0.24 %
O ₂	10.27 %	10.38 %	0.53 %	10.46 %	0.92 %	0.39 %
CO ₂	-0.20 %	-0.15 %	0.26 %	0.04 %	1.25 %	0.99 %
CO ₂	9.48 %	9.13 %	-1.82 %	9.23 %	-1.30 %	0.52 %
THC	0.0 ppm	0.0 ppm	0.00 %	0.0 ppm	0.00 %	0.00 %
THC	15.2 ppm	14.9 ppm	-1.00 %	15.3 ppm	0.33 %	1.33 %

Sampling System Bias and Drift

Test Performed For:
GREC
Gainesville
Boiler 1
Compliance
Date:3/23/17

Test Performed By:
C.E.M. Solutions, Inc.
1183 E. Overdrive Circle
Hernando, FL 34442
(352) 489-4337
THC Run 3

Monitor Type	Analyzer Cal Response	Initial Cal Value	Pre Run Bias (%)	Final Cal Value	Post Run Bias (%)	Total Run Drift (%)
O ₂	0.09 %	0.23 %	0.68 %	0.18 %	0.44 %	-0.24 %
O ₂	10.31 %	10.23 %	-0.39 %	10.23 %	-0.39 %	0.00 %
CO ₂	-0.21 %	-0.32 %	-0.57 %	-0.13 %	0.42 %	0.99 %
CO ₂	9.45 %	9.24 %	-1.09 %	9.40 %	-0.26 %	0.83 %
THC	0.0 ppm	0.0 ppm	0.00 %	0.0 ppm	0.00 %	0.00 %
THC	15.0 ppm	15.2 ppm	0.67 %	15.4 ppm	1.33 %	0.67 %

CERTIFICATE OF BATCH ANALYSIS

Grade of Product: CEM-CAL ZERO

Part Number:	NI CZ15A	Reference Number:	21-400540138-1
Cylinder Analyzed:	CC355956	Cylinder Volume:	142.0 CF
Laboratory:	110 - Tampa Plant - FL	Cylinder Pressure:	2000 PSIG
Analysis Date:	May 08, 2015	Valve Outlet:	580
Lot Number:	21-400540138-1		

Expiration Date: May 08, 2023

ANALYTICAL RESULTS

Component	Requested Purity	Certified Concentration
NITROGEN	99.9995 %	99.9995 %
CARBON DIOXIDE	< 1.0 PPM	<LDL 0.154 PPM
NOx	< 0.1 PPM	< 0.1 PPM
SO2	< 0.1 PPM	< 0.1 PPM
THC	< 0.1 PPM	<LDL 0.06 PPM
CARBON MONOXIDE	< 0.5 PPM	<LDL 0.154 PPM

Permanent Notes: Airgas certifies that the contents of this cylinder meet the requirements of 40 CFR 72.2

Cylinders in Batch:

CC174164, CC183268, CC185572, CC189776, CC263051, CC267188, CC288593, CC301816, CC308214, CC318826, CC319269, CC326641, CC355956, CC75029, SG9124272BAL, SG9169154BAL, XC015750B

Impurities verified against analytical standards traceable to NIST by weight and/or analysis.

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number: E03NI80E15A2872 Reference Number: 122-124564415-3
Cylinder Number: EB0070863 Cylinder Volume: 150.6 CF
Laboratory: 124 - Durham - NC Cylinder Pressure: 2015 PSIG
PGVP Number: B22016 Valve Outlet: 590
Gas Code: CO2,O2,BALN Certification Date: Jul 11, 2016

Expiration Date: Jul 11, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	9.500 %	9.437 %	G1	+/- 0.6% NIST Traceable	07/11/2016
OXYGEN	10.00 %	10.11 %	G1	+/- 0.4% NIST Traceable	07/11/2016
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12061348	CC360808	11.002 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 11, 2018
NTRM	09060230	CC263091	9.961 % OXYGEN/NITROGEN	+/- 0.3%	Nov 08, 2018

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA510 CO2 2L6YXWY0	Nondispersive Infrared (NDIR)	Jun 23, 2016
Horiba MPA510 O2 41499150042	Paramagnetic	Jun 23, 2016

Triad Data Available Upon Request



Signature on file
Approved for Release

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E03NI60E15A03W3	Reference Number:	122-124375364-1
Cylinder Number:	CC221880	Cylinder Volume:	158.8 CF
Laboratory:	124 - Durham - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22013	Valve Outlet:	590
Gas Code:	CO2,O2,BALN	Certification Date:	May 20, 2013

Expiration Date: May 20, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	19.00 %	19.26 %	G1	+/- 0.6% NIST Traceable	05/20/2013
OXYGEN	20.50 %	20.61 %	G1	+/- 1.0% NIST Traceable	05/20/2013
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12061551	CC354889	19.87 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 27, 2018
NTRM	09061416	CC273522	22.53 % OXYGEN/NITROGEN	+/- 0.4%	Mar 08, 2019

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA510 CO2 42399380022	Nondispersive Infrared (NDIR)	May 06, 2013
Horiba MPA510 O2 41499150042	Paramagnetic	May 10, 2013

Triad Data Available Upon Request



Signature on file
Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02AI99E15A1486	Reference Number:	122-124459561-3
Cylinder Number:	CC453989	Cylinder Volume:	146.2 CF
Laboratory:	124 - Durham - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22014	Valve Outlet:	590
Gas Code:	PPN,BALA	Certification Date:	Oct 20, 2014

Expiration Date: Oct 20, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
PROPANE	9.000 PPM	8.926 PPM	G1	+/- 0.8% NIST Traceable	10/20/2014
AIR	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	10061415	CC315930	9.93 PPM PROPANE/AIR	+/- 0.6%	Jul 20, 2016

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801333 C3H8	FTIR	Oct 03, 2014

Triad Data Available Upon Request



Signature on file
Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02AI99E15A1448	Reference Number:	122-124459561-2
Cylinder Number:	CC454100	Cylinder Volume:	146.2 CF
Laboratory:	124 - Durham - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22014	Valve Outlet:	590
Gas Code:	PPN,BALA	Certification Date:	Oct 20, 2014

Expiration Date: Oct 20, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
PROPANE	15.00 PPM	15.20 PPM	G1	+/- 1.0% NIST Traceable	10/20/2014
AIR	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	10061415	CC315930	9.93 PPM PROPANE/AIR	+/- 0.6%	Jul 20, 2016

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801333 C3H8	FTIR	Oct 03, 2014

Triad Data Available Upon Request



Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E02AI99E15A0080	Reference Number:	122-124460857-1
Cylinder Number:	CC458494	Cylinder Volume:	146.2 CF
Laboratory:	124 - Durham - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22014	Valve Outlet:	590
Gas Code:	PPN,BALA	Certification Date:	Oct 28, 2014

Expiration Date: Oct 28, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
PROPANE	25.50 PPM	25.53 PPM	G1	+/- 0.9% NIST Traceable	10/28/2014
AIR	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	10061415	CC315930	9.93 PPM PROPANE/AIR	+/- 0.6%	Jul 20, 2016

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801333 C3H8	FTIR	Oct 03, 2014

Triad Data Available Upon Request



Signature on file
Approved for Release

Appendix D-2: Wet Chemistry Method QA/QC

Meter Box Pre and Post-Test Calibrations
Sample Probe Thermocouple Calibrations
Probe Nozzle Calibrations
Probe Pitot Tube Coefficient Calibrations

**APEX INSTRUMENTS METHOD 5 POST-TEST CONSOLE CALIBRATION
USING CALIBRATED CRITICAL ORIFICES
3-POINT ENGLISH UNITS**

Meter Console Information	
Console Model Number	XC-522
Console Serial Number	CEMS3MB
DGM Model Number	S-110
DGM Serial Number	357811

Calibration Conditions			
Date	Time	27-Mar-17	12:40
Barometric Pressure		30.1	in Hg
Theoretical Critical Vacuum ¹		14.2	in Hg
Calibration Technician		AL	

Factors/Conversions		
Std Temp	528	°R
Std Press	29.92	in Hg
K ₁	17.647	oR/in Hg

¹For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

²The Critical Orifice Coefficient, 'K', must be entered in English units, (ft³*°R^{1/2})/(in.Hg*min).

Calibration Data										
Run Time	Metering Console				Critical Orifice					
Elapsed	DGM Orifice ΔH	Volume Initial	Volume Final	Outlet Temp Initial	Outlet Temp Final	Serial Number	Coefficient	Amb Temp Initial	Amb Temp Final	Actual Vacuum
(θ)	(P _m)	(V _{mi})	(V _{mf})	(t _{mi})	(t _{mf})		K'	(t _{amb})	(t _{amb})	
min	in H ₂ O	cubic feet	cubic feet	°F	°F		see above ²	°F	°F	in Hg
15.0	1.9	766.027	777.737	71	74	OB-63	0.5750	82	79	21
10.0	1.9	777.737	785.566	74	75	OB-63	0.5750	79	80	21
20.0	1.9	785.566	801.260	75	77	OB-63	0.5750	80	82	21


Standardized Data				Results				
Dry Gas Meter		Critical Orifice		Calibration Factor		Dry Gas Meter		
(V _{m(std)})	(Q _{m(std)})	(V _{cr(std)})	(Q _{cr(std)})	Value	Variation	Flowrate	ΔH @	
cubic feet	cfm	cubic feet	cfm	(Y)	(ΔY)	Std & Corr	0.75 SCFM	Variation
						(Q _{m(std)(corr)})	(ΔH@)	(ΔΔH@)
						cfm	in H ₂ O	
11.751	0.783	11.182	0.745	0.952	-0.001	0.745	1.940	0.007
7.827	0.783	7.460	0.746	0.953	0.001	0.746	1.930	-0.003
15.646	0.782	14.901	0.745	0.952	0.000	0.745	1.930	-0.004
				0.952	Y Average		1.934	ΔH@ Average

Pre-test DGM Y ₁	0.956
Post-test DGM Y ₁	0.952
Percent Change	0.36

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Method 5, CFR 40 Part 60.

Signature



Date

3/27/17

**APEX INSTRUMENTS METHOD 5 POST-TEST CONSOLE CALIBRATION
USING CALIBRATED CRITICAL ORIFICES
3-POINT ENGLISH UNITS**

Meter Console Information	
Console Model Number	XC-522-0
Console Serial Number	CEMS5MB
DGM Model Number	S-110
DGM Serial Number	300919

Calibration Conditions			
Date	Time	27-Mar-17	12:40
Barometric Pressure		30.1	in Hg
Theoretical Critical Vacuum ¹		14.2	in Hg
Calibration Technician		AL	

Factors/Conversions		
Std Temp	528	°R
Std Press	29.92	in Hg
K ₁	17.647	oR/in Hg

¹For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

²The Critical Orifice Coefficient, K', must be entered in English units, (ft³•R^{1/2})/(in.Hg•min).

Calibration Data										
Run Time	Metering Console				Critical Orifice					
Elapsed	DGM Orifice ΔH	Volume Initial	Volume Final	Outlet Temp Initial	Outlet Temp Final	Serial Number	Coefficient	Amb Temp Initial	Amb Temp Final	Actual Vacuum
(Θ)	(P _m)	(V _{mi})	(V _{mf})	(t _{mi})	(t _{mf})		K'	(t _{amb})	(t _{amb})	
min	in H ₂ O	cubic feet	cubic feet	°F	°F		see above ²	°F	°F	in Hg
15.0	1.2	245.326	254.076	71	74	MZ-55	0.4571	82	79	21
10.0	1.2	254.076	259.939	74	76	MZ-55	0.4571	80	80	21
20.0	1.2	259.939	271.689	76	78	MZ-55	0.4571	80	83	21


Standardized Data				Results				
Dry Gas Meter		Critical Orifice		Calibration Factor		Flowrate	ΔH @	
(V _{m(std)})	(Q _{m(std)})	(V _{cr(std)})	(Q _{cr(std)})	Value	Variation	Std & Corr	0.75 SCFM	Variation
cubic feet	cfm	cubic feet	cfm	(Y)	(ΔY)	(Q _{m(std)(corr)})	(ΔH@)	(ΔΔH@)
						cfm	in H ₂ O	
8.765	0.584	8.889	0.593	1.014	0.000	0.593	1.933	0.008
5.846	0.585	5.929	0.593	1.014	0.000	0.593	1.922	-0.003
11.672	0.584	11.842	0.592	1.015	0.000	0.592	1.920	-0.005
				1.014	Y Average		1.925	ΔH@ Average

Pre-test DGM Y ₁	1.012
Post-test DGM Y ₁	1.014
Percent Change	0.19

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Method 5, CFR 40 Part 60.

Signature



Date

3/27/17

**APEX INSTRUMENTS METHOD 5 POST-TEST CONSOLE CALIBRATION
USING CALIBRATED CRITICAL ORIFICES
3-POINT ENGLISH UNITS**

Meter Console Information	
Console Model Number	XC-522
Console Serial Number	CEMS7MB
DGM Model Number	MS-4
DGM Serial Number	1504221

Calibration Conditions			
Date	Time	27-Mar-17	12:40
Barometric Pressure		30.1	in Hg
Theoretical Critical Vacuum ¹		14.2	in Hg
Calibration Technician		AL	

Factors/Conversions		
Std Temp	528	°R
Std Press	29.92	in Hg
K ₁	17.647	oR/in Hg

¹For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

²The Critical Orifice Coefficient, K', must be entered in English units, (ft³°R^{1/2})/(in.Hg*min).

Calibration Data										
Run Time	Metering Console					Critical Orifice				
Elapsed	DGM Orifice ΔH	Volume Initial	Volume Final	Outlet Temp Initial	Outlet Temp Final	Serial Number	Coefficient	Amb Temp Initial	Amb Temp Final	Actual Vacuum
(⊖)	(P _m)	(V _m)	(V _{mf})	(t _m)	(t _{mf})		K'	(t _{amb})	(t _{amb})	
min	in H ₂ O	cubic feet	cubic feet	°F	°F		see above ²	°F	°F	in Hg
19.0	2.0	880.530	895.863	74	77	MZ-63	0.5940	82	79	20
10.0	2.0	895.863	903.968	77	78	MZ-63	0.5940	79	80	19
20.0	2.0	903.968	920.218	78	80	MZ-63	0.5940	80	83	19

Results								
Standardized Data				Dry Gas Meter				
Dry Gas Meter		Critical Orifice		Calibration Factor		Flowrate	ΔH @	
(V _{m(stdg)})	(Q _{m(stdg)})	(V _{Cr(stdg)})	(Q _{Cr(stdg)})	Value	Variation	Std & Corr	0.75 SCFM	Variation
cubic feet	cfm	cubic feet	cfm	(Y)	(ΔY)	(Q _{m(stdg)(corr)})	(ΔH@)	(ΔΔH@)
						cfm	in H ₂ O	
15.304	0.805	14.631	0.770	0.956	0.000	0.770	1.904	0.006
8.059	0.806	7.707	0.771	0.956	0.001	0.771	1.894	-0.004
16.114	0.806	15.387	0.769	0.955	-0.001	0.769	1.895	-0.002
				0.956	Y Average		1.898	ΔH@ Average

Pre-test DGM Y _i	0.965
Post-test DGM Y _i	0.956
Percent Change	0.91

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Method 5, CFR 40 Part 60.

Signature

Date

3/27/17

METHOD 30B POST-TEST CONSOLE CALIBRATION

USING Reference Dry Gas Meter


30B Meter Console Information		Meter A Console Information		Meter B Console Information		Reference Meter Information		Calibration Conditions	
Console Model Number	XC-260	DGM A Model Number	SK25EX	DGM B Model Number	SK25EX	Meter Serial #	1508011	Date	27-Mar-17
Console Serial Number	CEMS30B-01	DGM A Serial Number	20140613	DGM B Serial Number	20140578	Reference Meter Gamma	1.0000	Barometric Pressure	30.14 in Hg
								Reference Thermometer Info.	
								Thermometer Serial #	150431556
								Ambient Temp	79.3 °F

3-Run Meter Calibration											
Outlet TC Ambient Temp Measurement	Run Time Elapsed (t)	Metering Console				Reference Meter					
		Flow Rate	Volume Initial	Volume Final	Outlet Temp Initial	Outlet Temp Final	Volume Initial	Volume Final	Outlet Temp Initial	Outlet Temp Final	
		(lpm)	(V _m)	(V _m)	(t _m)	(t _m)	(V _m)	(V _m)	(t _m)	(t _m)	
°F	min	lpm	l	l	°F	°F	l	l	°F	°F	
Meter A	81	16.0	2.00	0.000	35.377	78.0	80.0	0.000	35.439	77	79
		13.0	2.00	0.000	28.481	81.0	82.0	0.000	28.467	80	82
		31.0	2.00	0.000	67.226	82.0	84.0	0.000	67.146	82	86
Meter B	81	17.0	2.00	0.000	36.203	85.0	85.0	0.000	36.352	84	87
		10.0	2.00	0.000	21.225	85.0	86.0	0.000	21.245	87	86
		11.0	2.00	0.000	23.344	86.0	86.0	0.000	23.350	86	87

Calibration Results											
Standardized Data				Dry Gas Meter							
Dry Gas Meter		Reference Meter		Calibration Factor		Flowrate	Outlet TC	Outlet TC			
(V _{m(Std)})	(Q _{m(Std)})	(V _{r(Std)})	(Q _{r(Std)})	Value	Variation	Std & Corr	vs Reference TC	Calibration			
(l)	(lpm)	(l)	(lpm)	(Y)	(ΔY)	(Q _{m(Std)(Corr)})	(°F)	(°F)			
Meter A	34.913	2.182	35.040	2.190	1.004	0.00	2.19	2	Pass	Pre-test DGM Y	1.002
	27.978	2.152	27.990	2.153	1.000	0.00	2.15			Post-test DGM Y	1.000
	65.856	2.124	65.657	2.118	0.997	0.00	2.12			Percent Change	0
				1.000	Y Average						
Meter B	35.335	2.079	35.448	2.085	1.003	0.00	2.09	2	Pass	Pre-test DGM Y	1.001
	20.697	2.070	20.679	2.068	0.999	0.00	2.07			Post-test DGM Y	1.001
	22.743	2.068	22.728	2.066	0.999	0.00	2.07			Percent Change	0
				1.001	Y Average						


Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.
 The Post-Test DGM Y must not differ from the Pre-Test DGM Y by more than 5%.
 The DGM Outlet Thermocouple ambient temperature measurement must not differ from the Reference Thermocouple ambient temperature measurement by more than 2 degrees oF.

I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Methods, CFR 40 Part 60, using a Calibrated Reference Dry Gas Meter (RDGM) Serial Number: 1508011
 I certify that the above Dry Gas Meter Exit Thermocouples were calibrated in accordance with USEPA ALT-011, using a NIST-Traceable Reference Thermocouple Serial Number: 150431556



Signature:  Date: 3/27/17

C.E.M. Solutions, Inc.
Type S Pitot Tube Inspection


Date of Calibration	03/27/2017
Level and Perpendicular?	Yes
Obstruction?	No
Damaged?	No
α_1 ($-10^\circ < \alpha_1 < +10^\circ$)	0
α_2 ($-10^\circ < \alpha_2 < +10^\circ$)	-2
β_1 ($-5^\circ < \beta_1 < +5^\circ$)	-1
β_2 ($-5^\circ < \beta_2 < +5^\circ$)	1
γ	0
θ	0
D_t ($3/16" < D_t < 3/8"$)	0.371
A	0.961
$z = A \tan \gamma$ ($< 0.125"$)	0.000
$w = A \tan \theta$ ($< 0.03125"$)	0.000
$A/2D_t$ ($1.05 < P_A/D_t < 1.5$)	1.295





Degree indicating level position for determining α_1 and α_2 .




Degree indicating level position for determining β_1 and β_2 .



Degree indicating level position for determining θ .



Degree indicating level position for determining γ then calculate Z.



QA/QC Check:

Completeness: x Legibility: x Reasonableness: x
 Specifications: x Accuracy: x


Certification:

I certify that the Type S pitot tube/probe ID# A3424 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor (C_p) of 0.84.



Certified by: Alexander Lagunas 3/27/2017
 Personnel (Signature/Date)

C.E.M. Solutions, Inc.
Type S Pitot Tube Inspection


Date of Calibration	03/27/2017
Level and Perpendicular?	Yes
Obstruction?	No
Damaged?	No
α_1 ($-10^\circ < \alpha_1 < +10^\circ$)	1
α_2 ($-10^\circ < \alpha_2 < +10^\circ$)	-1
β_1 ($-5^\circ < \beta_1 < +5^\circ$)	0
β_2 ($-5^\circ < \beta_2 < +5^\circ$)	-1
γ	-2
θ	-1
D_t ($3/16" < D_t < 3/8"$)	0.375
A	0.958
$z = A \tan \gamma$ ($< 0.125"$)	-0.033
$w = A \tan \theta$ ($< 0.03125"$)	-0.017
$A/2D_t$ ($1.05 < P_A/D_t < 1.5$)	1.277





Degree indicating level position for determining α_1 and α_2 .




Degree indicating level position for determining β_1 and β_2 .



Degree indicating level position for determining θ .



Degree indicating level position for determining γ then calculate Z.



QA/QC Check:

Completeness: x Legibility: x Reasonableness: x
 Specifications: x Accuracy: x


Certification:

I certify that the Type S pitot tube/probe ID# A5400 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor (C_p) of 0.84.



Certified by: Alexander Lagunas 3/27/2017
 Personnel (Signature/Date)

C.E.M. Solutions, Inc.
Type S Pitot Tube Inspection

Date of Calibration	03/27/2017
Level and Perpendicular?	Yes
Obstruction?	No
Damaged?	No
α_1 ($-10^\circ < \alpha_1 < +10^\circ$)	-1
α_2 ($-10^\circ < \alpha_2 < +10^\circ$)	0
β_1 ($-5^\circ < \beta_1 < +5^\circ$)	1
β_2 ($-5^\circ < \beta_2 < +5^\circ$)	1
γ	-1
θ	-2
D_t ($3/16" < D_t < 3/8"$)	0.374
A	1.004
$z = A \tan \gamma$ ($< 0.125"$)	-0.018
$w = A \tan \theta$ ($< 0.03125"$)	-0.035
$A/2D_t$ ($1.05 < P_A/D_t < 1.5$)	1.342





Degree indicating level position for determining α_1 and α_2 .




Degree indicating level position for determining β_1 and β_2 .



Degree indicating level position for determining θ .



Degree indicating level position for determining γ then calculate Z.



QA/QC Check:

Completeness: x Legibility: x Reasonableness: x
 Specifications: x Accuracy: x


Certification:

I certify that the Type S pitot tube/probe ID# PT-04 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor (C_p) of 0.84.



Certified by: Alexander Lagunas 3/27/2017
 Personnel (Signature/Date)

C.E.M. Solutions, Inc.
Type S Pitot Tube Inspection


Date of Calibration	03/27/2017
Level and Perpendicular?	Yes
Obstruction?	No
Damaged?	No
α_1 ($-10^\circ < \alpha_1 < +10^\circ$)	1
α_2 ($-10^\circ < \alpha_2 < +10^\circ$)	-1
β_1 ($-5^\circ < \beta_1 < +5^\circ$)	0
β_2 ($-5^\circ < \beta_2 < +5^\circ$)	-1
γ	-2
θ	-1
D_t ($3/16" < D_t < 3/8"$)	0.375
A	0.958
$z = A \tan \gamma$ ($< 0.125"$)	-0.033
$w = A \tan \theta$ ($< 0.03125"$)	-0.017
$A/2D_t$ ($1.05 < P_A/D_t < 1.5$)	1.277





Degree indicating level position for determining α_1 and α_2 .




Degree indicating level position for determining β_1 and β_2 .



Degree indicating level position for determining θ .



Degree indicating level position for determining γ then calculate Z.



QA/QC Check:

Completeness: x Legibility: x Reasonableness: x
 Specifications: x Accuracy: x

Certification:

I certify that the Type S pitot tube/probe ID# A5400 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor (C_p) of 0.84.

Certified by: Alexander Lagunas 3/27/2017
 Personnel (Signature/Date)

C.E.M. Solutions, Inc.
Thermocouple Post Test Calibration Check

Standard: Reference Thermometer (calibrated against NIST standards)

Reference: ALT-011 Alternative Method 2 Thermocouple Calibration Procedure

Procedure: Measure ambient temperature with the Reference Thermometer and the Measurement Thermocouple System. Record Results. Next, check the continuity of the Measurement Thermocouple System by subjecting it to a change in temperature. The Measurement Thermocouple System must respond accordingly.

Tolerance: $\pm 2^\circ$ F of actual temperature

Plant: GREC
Thermocouple #: TC5

Date: 3/27/2017
Reference TC#: 150431556

Length (FT.)	Reference Temp. (°F)	Measured Temp. (°F)	Difference (°F)	Continuity Check (PASS/FAIL)
5	84.3	83.5	0.8	PASS

Technician: Alexander Lagunas
Date: 3/27/17

C.E.M. Solutions, Inc.
Thermocouple Post Test Calibration Check

Standard: Reference Thermometer (calibrated against NIST standards)

Reference: ALT-011 Alternative Method 2 Thermocouple Calibration Procedure

Procedure: Measure ambient temperature with the Reference Thermometer and the Measurement Thermocouple System. Record Results. Next, check the continuity of the Measurement Thermocouple System by subjecting it to a change in temperature. The Measurement Thermocouple System must respond accordingly.

Tolerance: $\pm 2^\circ$ F of actual temperature

Plant: GREC
Thermocouple #: TC6-30B

Date: 3/27/2017
Reference TC#: 150431556

Length (FT.)	Reference Temp. (°F)	Measured Temp. (°F)	Difference (°F)	Continuity Check (PASS/FAIL)
6	83.4	83.2	0.2	PASS

Technician: Alexander Lagunas
Date: 3/27/17

C.E.M. Solutions, Inc.
Thermocouple Post Test Calibration Check

Standard: Reference Thermometer (calibrated against NIST standards)

Reference: ALT-011 Alternative Method 2 Thermocouple Calibration Procedure

Procedure: Measure ambient temperature with the Reference Thermometer and the Measurement Thermocouple System. Record Results. Next, check the continuity of the Measurement Thermocouple System by subjecting it to a change in temperature. The Measurement Thermocouple System must respond accordingly.

Tolerance: $\pm 2^{\circ}$ F of actual temperature

Plant: GREC
Thermocouple #: TC6-1

Date: 3/27/2017
Reference TC#: 150431556

Length (FT.)	Reference Temp. (°F)	Measured Temp. (°F)	Difference (°F)	Continuity Check (PASS/FAIL)
6	83.5	83.6	-0.1	PASS

Technician: Alexander Lagunas
Date: 3/27/17

C.E.M. Solutions, Inc.
Thermocouple Post Test Calibration Check

Standard: Reference Thermometer (calibrated against NIST standards)

Reference: ALT-011 Alternative Method 2 Thermocouple Calibration Procedure

Procedure: Measure ambient temperature with the Reference Thermometer and the Measurement Thermocouple System. Record Results. Next, check the continuity of the Measurement Thermocouple System by subjecting it to a change in temperature. The Measurement Thermocouple System must respond accordingly.

Tolerance: $\pm 2^\circ$ F of actual temperature

Plant: GREC
Thermocouple #: TC6-2

Date: 3/27/2017
Reference TC#: 150431556

Length (FT.)	Reference Temp. (°F)	Measured Temp. (°F)	Difference (°F)	Continuity Check (PASS/FAIL)
6	83.7	83	0.7	PASS

Technician: Alexander Lagunas
Date: 3/27/17

Field Balance Calibration Log

Balance Serial #: CP56590

Weight Serial #: 1000116732

Weights Expire: 1/21/2018

Date	Certified Standard (g)	Measured (g)	Difference (g)	Initial if PASS
3/20/17	500.0	499.8	0.2	MP
3/21/17	500.0	499.8	0.2	AL
3/22/17	500.0	499.9	0.1	AL
3/23/17	500.0	499.8	0.2	MP
3/24/17	500.0	499.9	0.1	MP

Check daily before use; the field balance must measure the weight within ± 0.5 g of the certified mass.

Probe Nozzle Calibration Log

Nozzle ID	Date	Nozzle Diameter, D _n (Inches)					Initial if PASS
		(1)	(2)	(3)	Hi - Lo	Average	

Each diameter must be measured to within ± 0.001 inches and the high-low difference must be ≤ 0.004 inches

Field Balance Calibration Log

Balance Serial #: PL42200235

Weight Serial #: 1000116731

Weights Expire: 1/21/2018

Date	Certified Standard (g)	Measured (g)	Difference (g)	Initial if PASS
3/21/2017	500g	499.7	0.3	CRH
3/22/2017	500g	499.7	0.3	CRH
3/23/2017	500g	499.6	0.4	CRH
3/24/2017	500g	499.7	0.3	CRH

Check daily before use; the field balance must measure the weight within ± 0.5 g of the certified mass.

Probe Nozzle Calibration Log

Nozzle ID	Date	Nozzle Diameter, D _n (Inches)					Initial if PASS
		(1)	(2)	(3)	Hi - Lo	Average	
G250-13	3/21/2017	0.258	0.257	0.256	0.002	0.257	CRH
G250-15	3/21/2017	0.257	0.257	0.257	0.000	0.257	CRH
G250-11	3/21/2017	0.253	0.252	0.253	0.001	0.253	CRH
G218-19	3/22/2017	0.221	0.221	0.223	0.002	0.222	CRH
G218-15	3/22/2017	0.217	0.220	0.218	0.003	0.218	CRH
G218-25	3/22/17	0.218	0.219	0.218	0.001	0.218	CRH
1-3	3/22/17	0.158	0.158	0.158	0.000	0.158	CRH
2-3	3/23/17	0.157	0.158	0.158	0.001	0.158	CRH

Each diameter must be measured to within ± 0.001 inches and the high-low difference must be ≤ 0.004 inches

Appendix E: Reference Method Data

Appendix E-1: Instrumental Methods Test Data

Average Calculated Emissions
Raw RM Data

THC Compliance Summary

Test Performed For:
GREC
Gainesville
Boiler 1
Compliance
Date:3/22/17

Run Number	Units	Run 1	Run 2	Run 3	Average	Standard
Date of Run	2017	22-Mar	22-Mar	23-Mar		
Start Time		14:10:00	18:18:00	7:23:00		
Stop Time		15:10:00	19:18:00	8:23:00		
Moisture Diff	B _{WS}	21.1	22.4	23.1	22.2	
THC	ppm	0.0	0.5	0.0	0.2	
THC / O ₂	Lbs/mmBtu	0.000	0.001	0.000	0.000	0.009

Calculation of Average Emissions

Test Performed For:
 GREC
 Gainesville
 Boiler 1
 Compliance
 Date:3/22/17

Test Performed By:
 C.E.M. Solutions, Inc.
 1183 E. Overdrive Circle
 Hernando, FL 34442
 (352) 489-4337
 THC Run 1

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent O ₂	0.49 %	0.43 %	0.46
10.11 percent O ₂	10.55 %	10.38 %	10.46
0.00 percent CO ₂	-0.10 %	-0.15 %	-0.12
9.44 percent CO ₂	9.12 %	9.13 %	9.13
0.0 ppm THC	0.0 ppm	0.0 ppm	-0.01
15.2 ppm THC	14.4 ppm	14.9 ppm	14.65

Mean Reference Values:
 3.74 percent O₂
 16.92 percent CO₂
 0.0 ppm THC

Corrected Results:
 3.3 percent O₂
 17.4 percent CO₂
 0.0 ppm THC

Basis:
 DRY
 DRY
 WET

Emission Calculations:

0.000 THC Lbs/mmBtu from O₂

Bws: 21.10 %

Fuel Factors:

9240 dscf/mmBtu

Calculation of Average Emissions

Test Performed For:
 GREC
 Gainesville
 Boiler 1
 Compliance
 Date:3/22/17

Test Performed By:
 C.E.M. Solutions, Inc.
 1183 E. Overdrive Circle
 Hernando, FL 34442
 (352) 489-4337
 THC Run 2

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent O ₂	0.43 %	0.48 %	0.46
10.11 percent O ₂	10.38 %	10.46 %	10.42
0.00 percent CO ₂	-0.15 %	0.04 %	-0.06
9.44 percent CO ₂	9.13 %	9.23 %	9.18
0.0 ppm THC	0.0 ppm	0.0 ppm	-0.01
15.2 ppm THC	14.9 ppm	15.3 ppm	15.10

Mean Reference Values:
 3.76 percent O₂
 16.84 percent CO₂
 0.5 ppm THC

Corrected Results:
3.40 percent O₂
17.30 percent CO₂
0.5 ppm THC

Basis:
 DRY
 DRY
 WET

Emission Calculations:

0.001 THC Lbs/mmBtu from O₂

Bws: **22.40 %**

Fuel Factors:

9240 dscf/mmBtu

Calculation of Average Emissions

Test Performed For:
 GREC
 Gainesville
 Boiler 1
 Compliance
 Date:3/23/17

Test Performed By:
 C.E.M. Solutions, Inc.
 1183 E. Overdrive Circle
 Hernando, FL 34442
 (352) 489-4337
 THC Run 3

Calibration Gas Value	Initial Calibration	Final Calibration	Average
0.00 percent O ₂	0.23 %	0.18 %	0.21
10.11 percent O ₂	10.23 %	10.23 %	10.23
0.00 percent CO ₂	-0.32 %	-0.13 %	-0.22
9.44 percent CO ₂	9.24 %	9.40 %	9.32
0.0 ppm THC	0.0 ppm	0.0 ppm	-0.01
15.2 ppm THC	15.2 ppm	15.4 ppm	15.32

Mean Reference Values:
 3.55 percent O₂
 17.16 percent CO₂
 0.0 ppm THC

Corrected Results:
 3.4 percent O₂
 17.2 percent CO₂
 0.0 ppm THC

Basis:
 DRY
 DRY
 WET

Emission Calculations:

0.000 THC Lbs/mmBtu from O₂

Bws: **23.10 %**

Fuel Factors:

9240 dscf/mmBtu

name	FE O2	FE CO2	A THC										
sn	1151210012	1151210012	1106047146										
offset	0	0	0										
fullscale	100	20	30										
train	1	1	1										
gastype	o2 3a	co2 3a	thc 25a										
scg14	3/22/2017 13:49:00	20.97	-0.14	0.0	CC281749/cg14	NOx	0	CO2	0	THC	0	SO2	0
thczero1	3/22/2017 13:49:00	20.97	-0.14	0.0	CC281749/cg14	NOx	0	CO2	0	THC	0	SO2	0
scg2	3/22/2017 13:49:15	20.86	-0.15	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:49:30	20.80	-0.15	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:49:45	20.80	-0.15	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:50:00	20.79	-0.16	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:50:15	20.79	-0.16	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:50:30	20.79	-0.16	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:50:45	20.80	-0.16	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:51:00	19.97	-0.04	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:51:15	15.58	1.41	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:51:30	12.17	5.49	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:51:45	10.97	7.81	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:52:00	10.66	8.81	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:52:15	10.57	9.04	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 13:52:30	10.55	9.12	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
o2span1	3/22/2017 13:52:30	10.55	9.12	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
co2span1	3/22/2017 13:52:30	10.55	9.12	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg1	3/22/2017 13:53:00	10.53	9.16	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:53:15	10.53	9.18	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:53:30	10.52	9.19	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:53:45	10.52	9.20	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:54:00	10.51	9.21	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:54:15	10.50	9.21	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:54:30	10.37	9.19	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:54:45	7.89	8.47	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:55:00	3.78	5.24	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:55:15	1.57	2.45	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:55:30	0.77	0.60	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:55:45	0.57	0.12	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:56:00	0.51	-0.06	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 13:56:15	0.49	-0.10	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
o2zero1	3/22/2017 13:56:15	0.49	-0.10	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
co2zero1	3/22/2017 13:56:15	0.49	-0.10	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
THC run1	3/22/2017 13:57:45	0.45	-0.15	0.0									
THC run1	3/22/2017 13:58:00	0.45	-0.15	0.0									
THC run1	3/22/2017 13:58:15	1.04	0.30	0.0									
THC run1	3/22/2017 13:58:30	2.63	5.04	0.0									
THC run1	3/22/2017 13:58:45	3.42	11.38	0.0									
THC run1	3/22/2017 13:59:00	3.39	15.27	-0.1									
THC run1	3/22/2017 13:59:15	3.57	16.34	0.0									
THC run1	3/22/2017 13:59:30	3.62	16.73	0.0									
THC run1	3/22/2017 13:59:45	3.63	16.80	0.0									
THC run1	3/22/2017 14:00:00	3.63	16.86	0.0									
THC run1	3/22/2017 14:00:15	3.64	16.89	0.0									
THC run1	3/22/2017 14:00:30	3.31	16.82	-0.1									
THC run1	3/22/2017 14:00:45	3.31	16.81	-0.1									
THC run1	3/22/2017 14:01:00	3.55	16.91	-0.1									
THC run1	3/22/2017 14:01:15	3.33	16.93	-0.1									
THC run1	3/22/2017 14:01:30	3.07	17.05	-0.1									
THC run1	3/22/2017 14:01:45	3.44	17.19	0.0									
THC run1	3/22/2017 14:02:00	3.42	17.17	0.0									
THC run1	3/22/2017 14:02:15	3.34	17.19	0.0									
THC run1	3/22/2017 14:02:30	3.24	17.30	0.0									
THC run1	3/22/2017 14:02:45	3.22	17.37	0.0									
THC run1	3/22/2017 14:03:00	3.31	17.38	0.0									
THC run1	3/22/2017 14:03:15	3.36	17.33	0.0									
THC run1	3/22/2017 14:03:30	3.46	17.23	0.0									
THC run1	3/22/2017 14:03:45	3.52	17.18	0.0									
THC run1	3/22/2017 14:04:00	3.52	17.14	0.0									
THC run1	3/22/2017 14:04:15	3.44	17.16	0.0									
THC run1	3/22/2017 14:04:30	3.38	17.19	0.0									
THC run1	3/22/2017 14:04:45	3.32	17.24	0.0									
THC run1	3/22/2017 14:05:00	3.32	17.29	0.0									
THC run1	3/22/2017 14:05:15	3.31	17.31	0.0									
THC run1	3/22/2017 14:05:30	3.38	17.29	0.0									
THC run1	3/22/2017 14:05:45	3.55	17.22	0.0									
THC run1	3/22/2017 14:06:00	3.48	17.16	0.0									
THC run1	3/22/2017 14:06:15	3.38	17.21	0.0									
THC run1	3/22/2017 14:06:30	3.32	17.30	0.0									
THC run1	3/22/2017 14:06:45	3.41	17.28	0.0									
THC run1	3/22/2017 14:07:00	3.57	17.14	0.0									
THC run1	3/22/2017 14:07:15	3.74	17.01	0.0									
THC run1	3/22/2017 14:07:30	3.80	16.88	0.0									
THC run1	3/22/2017 14:07:45	3.78	16.85	0.0									
THC run1	3/22/2017 14:08:00	3.71	16.92	0.0									
THC run1	3/22/2017 14:08:15	3.72	16.96	0.0									
THC run1	3/22/2017 14:08:30	3.83	16.92	0.0									
THC run1	3/22/2017 14:08:45	3.93	16.81	0.0									
THC run1	3/22/2017 14:09:00	4.02	16.66	0.0									
THC run1	3/22/2017 14:09:15	4.08	16.57	0.0									
THC run1	3/22/2017 14:09:30	4.17	16.49	0.0									
THC run1	3/22/2017 14:09:45	4.21	16.43	0.0									
THC run1	3/22/2017 14:10:00	4.06	16.47	0.0									
THC run1	3/22/2017 14:10:15	3.90	16.62	0.0									
THC run1	3/22/2017 14:10:30	3.86	16.79	0.0									
THC run1	3/22/2017 14:10:45	3.86	16.81	0.0									
THC run1	3/22/2017 14:11:00	3.86	16.81	0.0									
THC run1	3/22/2017 14:11:15	3.80	16.84	0.0									
THC run1	3/22/2017 14:11:30	3.74	16.88	0.0									
THC run1	3/22/2017 14:11:45	3.77	16.88	0.0									
THC run1	3/22/2017 14:12:00	3.82	16.86	0.0									
THC run1	3/22/2017 14:12:15	3.87	16.81	0.0									
THC run1	3/22/2017 14:12:30	3.87	16.79	0.0									
THC run1	3/22/2017 14:12:45	3.84	16.81	0.0									
THC run1	3/22/2017 14:13:00	3.84	16.83	0.0									
THC run1	3/22/2017 14:13:15	3.84	16.83	0.0									
THC run1	3/22/2017 14:13:30	3.82	16.84	0.0									

name	FE O2	FE CO2	A THC	
sn	1151210012	1151210012	1106047146	
offset	0	0	0	
fullscale	100	20	30	
train	1	1	1	
gastype	o2 3a	co2 3a	thc 25a	
THC run1	3/22/2017 14:13:45	3.74	16.88	0.0
THC run1	3/22/2017 14:14:00	3.65	16.95	0.0
THC run1	3/22/2017 14:14:15	3.59	16.99	0.0
THC run1	3/22/2017 14:14:30	3.57	17.06	0.0
THC run1	3/22/2017 14:14:45	3.60	17.07	0.0
THC run1	3/22/2017 14:15:00	3.64	17.03	0.0
THC run1	3/22/2017 14:15:15	3.67	17.02	0.0
THC run1	3/22/2017 14:15:30	3.74	16.97	0.0
THC run1	3/22/2017 14:15:45	3.76	16.92	0.0
THC run1	3/22/2017 14:16:00	3.69	16.93	0.0
THC run1	3/22/2017 14:16:15	3.64	16.99	0.0
THC run1	3/22/2017 14:16:30	3.64	17.01	0.0
THC run1	3/22/2017 14:16:45	3.70	16.96	0.0
THC run1	3/22/2017 14:17:00	3.66	16.96	0.0
THC run1	3/22/2017 14:17:15	3.53	17.04	0.0
THC run1	3/22/2017 14:17:30	3.47	17.16	0.0
THC run1	3/22/2017 14:17:45	3.48	17.20	0.0
THC run1	3/22/2017 14:18:00	3.55	17.18	0.0
THC run1	3/22/2017 14:18:15	3.54	17.14	0.0
THC run1	3/22/2017 14:18:30	3.56	17.14	0.0
THC run1	3/22/2017 14:18:45	3.60	17.12	0.0
THC run1	3/22/2017 14:19:00	3.66	17.04	0.0
THC run1	3/22/2017 14:19:15	3.72	16.96	0.0
THC run1	3/22/2017 14:19:30	3.78	16.90	0.0
THC run1	3/22/2017 14:19:45	3.78	16.89	0.0
THC run1	3/22/2017 14:20:00	3.76	16.89	0.0
THC run1	3/22/2017 14:20:15	3.75	16.91	0.0
THC run1	3/22/2017 14:20:30	3.79	16.93	0.0
THC run1	3/22/2017 14:20:45	3.89	16.87	0.0
THC run1	3/22/2017 14:21:00	3.92	16.76	0.0
THC run1	3/22/2017 14:21:15	3.80	16.79	0.0
THC run1	3/22/2017 14:21:30	3.68	16.94	0.0
THC run1	3/22/2017 14:21:45	3.59	17.00	0.0
THC run1	3/22/2017 14:22:00	3.56	17.07	0.0
THC run1	3/22/2017 14:22:15	3.64	17.10	0.0
THC run1	3/22/2017 14:22:30	3.65	17.06	0.0
THC run1	3/22/2017 14:22:45	3.68	17.02	0.0
THC run1	3/22/2017 14:23:00	3.68	16.99	0.0
THC run1	3/22/2017 14:23:15	3.67	17.01	0.0
THC run1	3/22/2017 14:23:30	3.74	16.98	0.0
THC run1	3/22/2017 14:23:45	3.79	16.94	0.0
THC run1	3/22/2017 14:24:00	3.85	16.87	0.0
THC run1	3/22/2017 14:24:15	3.87	16.80	0.0
THC run1	3/22/2017 14:24:30	3.79	16.81	0.0
THC run1	3/22/2017 14:24:45	3.80	16.86	0.0
THC run1	3/22/2017 14:25:00	3.88	16.84	0.0
THC run1	3/22/2017 14:25:15	3.98	16.74	0.0
THC run1	3/22/2017 14:25:30	4.03	16.64	0.0
THC run1	3/22/2017 14:25:45	4.07	16.62	0.0
THC run1	3/22/2017 14:26:00	4.13	16.57	0.0
THC run1	3/22/2017 14:26:15	4.14	16.52	0.0
THC run1	3/22/2017 14:26:30	4.04	16.55	0.0
THC run1	3/22/2017 14:26:45	4.02	16.60	0.0
THC run1	3/22/2017 14:27:00	4.09	16.57	0.0
THC run1	3/22/2017 14:27:15	4.10	16.54	0.0
THC run1	3/22/2017 14:27:30	4.10	16.53	0.0
THC run1	3/22/2017 14:27:45	4.08	16.55	0.0
THC run1	3/22/2017 14:28:00	4.05	16.57	0.0
THC run1	3/22/2017 14:28:15	4.03	16.61	0.0
THC run1	3/22/2017 14:28:30	3.95	16.67	0.0
THC run1	3/22/2017 14:28:45	3.86	16.74	0.0
THC run1	3/22/2017 14:29:00	3.85	16.84	0.0
THC run1	3/22/2017 14:29:15	3.91	16.79	0.0
THC run1	3/22/2017 14:29:30	3.95	16.69	0.0
THC run1	3/22/2017 14:29:45	3.92	16.69	0.0
THC run1	3/22/2017 14:30:00	3.85	16.76	0.0
THC run1	3/22/2017 14:30:15	3.88	16.83	0.0
THC run1	3/22/2017 14:30:30	3.86	16.83	0.0
THC run1	3/22/2017 14:30:45	3.91	16.78	0.0
THC run1	3/22/2017 14:31:00	3.92	16.75	0.0
THC run1	3/22/2017 14:31:15	3.92	16.74	0.0
THC run1	3/22/2017 14:31:30	3.90	16.75	0.0
THC run1	3/22/2017 14:31:45	3.86	16.80	0.0
THC run1	3/22/2017 14:32:00	3.94	16.76	0.0
THC run1	3/22/2017 14:32:15	3.99	16.67	0.0
THC run1	3/22/2017 14:32:30	3.92	16.66	0.0
THC run1	3/22/2017 14:32:45	3.89	16.72	0.0
THC run1	3/22/2017 14:33:00	3.85	16.78	0.0
THC run1	3/22/2017 14:33:15	3.79	16.84	0.0
THC run1	3/22/2017 14:33:30	3.76	16.91	0.0
THC run1	3/22/2017 14:33:45	3.69	16.95	0.0
THC run1	3/22/2017 14:34:00	3.64	17.00	0.0
THC run1	3/22/2017 14:34:15	3.68	17.02	0.0
THC run1	3/22/2017 14:34:30	3.72	16.99	0.0
THC run1	3/22/2017 14:34:45	3.81	16.91	0.0
THC run1	3/22/2017 14:35:00	3.87	16.82	0.0
THC run1	3/22/2017 14:35:15	3.87	16.79	0.0
THC run1	3/22/2017 14:35:30	3.82	16.81	0.0
THC run1	3/22/2017 14:35:45	3.78	16.86	0.0
THC run1	3/22/2017 14:36:00	3.76	16.90	0.0
THC run1	3/22/2017 14:36:15	3.70	16.93	0.0
THC run1	3/22/2017 14:36:30	3.62	17.01	0.0
THC run1	3/22/2017 14:36:45	3.55	17.08	0.0
THC run1	3/22/2017 14:37:00	3.51	17.18	0.0
THC run1	3/22/2017 14:37:15	3.57	17.17	0.0
THC run1	3/22/2017 14:37:30	3.63	17.06	0.0
THC run1	3/22/2017 14:37:45	3.57	17.05	0.0
THC run1	3/22/2017 14:38:00	3.52	17.11	0.0

name	FE O2	FE CO2	A THC	
sn	1151210012	1151210012	1106047146	
offset	0	0	0	
fullscale	100	20	30	
train	1	1	1	
gastype	o2 3a	co2 3a	thc 25a	
THC run1	3/22/2017 14:38:15	3.49	17.16	0.0
THC run1	3/22/2017 14:38:30	3.50	17.19	0.0
THC run1	3/22/2017 14:38:45	3.52	17.16	0.0
THC run1	3/22/2017 14:39:00	3.52	17.16	0.0
THC run1	3/22/2017 14:39:15	3.58	17.14	0.2
THC run1	3/22/2017 14:39:30	3.66	17.07	0.3
THC run1	3/22/2017 14:39:45	3.63	17.03	0.2
THC run1	3/22/2017 14:40:00	3.59	17.04	0.1
THC run1	3/22/2017 14:40:15	3.58	17.06	0.0
THC run1	3/22/2017 14:40:30	3.56	17.08	0.0
THC run1	3/22/2017 14:40:45	3.55	17.10	0.0
THC run1	3/22/2017 14:41:00	3.59	17.11	0.0
THC run1	3/22/2017 14:41:15	3.63	17.06	0.0
THC run1	3/22/2017 14:41:30	3.58	17.06	0.0
THC run1	3/22/2017 14:41:45	3.51	17.13	0.0
THC run1	3/22/2017 14:42:00	3.49	17.20	0.0
THC run1	3/22/2017 14:42:15	3.52	17.21	0.0
THC run1	3/22/2017 14:42:30	3.56	17.15	0.0
THC run1	3/22/2017 14:42:45	3.63	17.06	0.0
THC run1	3/22/2017 14:43:00	3.64	17.00	0.0
THC run1	3/22/2017 14:43:15	3.58	17.03	0.0
THC run1	3/22/2017 14:43:30	3.53	17.09	0.0
THC run1	3/22/2017 14:43:45	3.49	17.16	0.0
THC run1	3/22/2017 14:44:00	3.55	17.16	0.0
THC run1	3/22/2017 14:44:15	3.62	17.11	0.0
THC run1	3/22/2017 14:44:30	3.70	17.04	0.0
THC run1	3/22/2017 14:44:45	3.81	16.95	0.0
THC run1	3/22/2017 14:45:00	3.83	16.86	0.0
THC run1	3/22/2017 14:45:15	3.78	16.87	0.0
THC run1	3/22/2017 14:45:30	3.79	16.89	0.0
THC run1	3/22/2017 14:45:45	3.74	16.90	0.0
THC run1	3/22/2017 14:46:00	3.74	16.92	0.0
THC run1	3/22/2017 14:46:15	3.78	16.92	0.0
THC run1	3/22/2017 14:46:30	3.85	16.86	0.0
THC run1	3/22/2017 14:46:45	3.90	16.79	0.0
THC run1	3/22/2017 14:47:00	3.91	16.76	0.0
THC run1	3/22/2017 14:47:15	3.93	16.76	0.0
THC run1	3/22/2017 14:47:30	3.99	16.72	0.0
THC run1	3/22/2017 14:47:45	4.04	16.66	0.0
THC run1	3/22/2017 14:48:00	4.08	16.56	0.0
THC run1	3/22/2017 14:48:15	4.10	16.51	0.0
THC run1	3/22/2017 14:48:30	4.08	16.52	0.0
THC run1	3/22/2017 14:48:45	4.03	16.56	0.0
THC run1	3/22/2017 14:49:00	3.97	16.63	0.0
THC run1	3/22/2017 14:49:15	3.94	16.68	0.0
THC run1	3/22/2017 14:49:30	3.97	16.70	0.0
THC run1	3/22/2017 14:49:45	3.93	16.69	0.0
THC run1	3/22/2017 14:50:00	3.82	16.77	0.0
THC run1	3/22/2017 14:50:15	3.74	16.89	0.0
THC run1	3/22/2017 14:50:30	3.67	16.96	0.0
THC run1	3/22/2017 14:50:45	3.64	16.99	0.0
THC run1	3/22/2017 14:51:00	3.64	16.99	0.0
THC run1	3/22/2017 14:51:15	3.65	16.99	0.0
THC run1	3/22/2017 14:51:30	3.62	17.01	0.0
THC run1	3/22/2017 14:51:45	3.63	17.04	0.0
THC run1	3/22/2017 14:52:00	3.72	17.00	0.0
THC run1	3/22/2017 14:52:15	3.81	16.92	0.0
THC run1	3/22/2017 14:52:30	3.86	16.84	0.0
THC run1	3/22/2017 14:52:45	3.85	16.81	0.0
THC run1	3/22/2017 14:53:00	3.77	16.87	0.0
THC run1	3/22/2017 14:53:15	3.73	16.93	0.0
THC run1	3/22/2017 14:53:30	3.68	16.94	0.0
THC run1	3/22/2017 14:53:45	3.62	16.97	0.0
THC run1	3/22/2017 14:54:00	3.61	17.04	0.0
THC run1	3/22/2017 14:54:15	3.61	17.06	0.0
THC run1	3/22/2017 14:54:30	3.56	17.06	0.0
THC run1	3/22/2017 14:54:45	3.48	17.13	0.0
THC run1	3/22/2017 14:55:00	3.42	17.22	0.0
THC run1	3/22/2017 14:55:15	3.41	17.27	0.0
THC run1	3/22/2017 14:55:30	3.37	17.32	0.0
THC run1	3/22/2017 14:55:45	3.34	17.35	0.0
THC run1	3/22/2017 14:56:00	3.36	17.35	0.0
THC run1	3/22/2017 14:56:15	3.41	17.30	0.0
THC run1	3/22/2017 14:56:30	3.45	17.24	0.0
THC run1	3/22/2017 14:56:45	3.43	17.24	0.0
THC run1	3/22/2017 14:57:00	3.39	17.28	0.0
THC run1	3/22/2017 14:57:15	3.41	17.29	0.0
THC run1	3/22/2017 14:57:30	3.42	17.27	0.0
THC run1	3/22/2017 14:57:45	3.45	17.26	0.0
THC run1	3/22/2017 14:58:00	3.52	17.21	0.0
THC run1	3/22/2017 14:58:15	3.56	17.16	0.0
THC run1	3/22/2017 14:58:30	3.60	17.12	0.0
THC run1	3/22/2017 14:58:45	3.61	17.06	0.0
THC run1	3/22/2017 14:59:00	3.50	17.07	0.0
THC run1	3/22/2017 14:59:15	3.37	17.20	0.0
THC run1	3/22/2017 14:59:30	3.41	17.30	0.0
THC run1	3/22/2017 14:59:45	3.53	17.22	0.0
THC run1	3/22/2017 15:00:00	3.59	17.11	0.0
THC run1	3/22/2017 15:00:15	3.57	17.09	0.0
THC run1	3/22/2017 15:00:30	3.54	17.14	0.0
THC run1	3/22/2017 15:00:45	3.55	17.16	0.0
THC run1	3/22/2017 15:01:00	3.57	17.13	0.0
THC run1	3/22/2017 15:01:15	3.61	17.09	0.0
THC run1	3/22/2017 15:01:30	3.62	17.03	0.0
THC run1	3/22/2017 15:01:45	3.55	17.05	0.0
THC run1	3/22/2017 15:02:00	3.55	17.11	0.0
THC run1	3/22/2017 15:02:15	3.60	17.11	0.0
THC run1	3/22/2017 15:02:30	3.66	17.04	0.0

name	FE O2	FE CO2	A THC							
sn	1151210012	1151210012	1106047146							
offset	0	0	0							
fullscale	100	20	30							
train	1	1	1							
gastype	o2 3a	co2 3a	thc 25a							
THC run1	3/22/2017 15:02:45	3.72	17.00	0.0						
THC run1	3/22/2017 15:03:00	3.79	16.94	0.0						
THC run1	3/22/2017 15:03:15	3.83	16.88	0.0						
THC run1	3/22/2017 15:03:30	3.81	16.86	0.0						
THC run1	3/22/2017 15:03:45	3.80	16.87	0.0						
THC run1	3/22/2017 15:04:00	3.81	16.87	0.0						
THC run1	3/22/2017 15:04:15	3.81	16.82	0.0						
THC run1	3/22/2017 15:04:30	3.81	16.82	0.0						
THC run1	3/22/2017 15:04:45	3.80	16.86	0.0						
THC run1	3/22/2017 15:05:00	3.81	16.87	0.0						
THC run1	3/22/2017 15:05:15	3.82	16.85	0.0						
THC run1	3/22/2017 15:05:30	3.80	16.86	0.0						
THC run1	3/22/2017 15:05:45	3.78	16.88	0.0						
THC run1	3/22/2017 15:06:00	3.77	16.90	0.0						
THC run1	3/22/2017 15:06:15	3.78	16.92	0.0						
THC run1	3/22/2017 15:06:30	3.92	16.85	0.0						
THC run1	3/22/2017 15:06:45	4.04	16.70	0.0						
THC run1	3/22/2017 15:07:00	4.04	16.58	0.0						
THC run1	3/22/2017 15:07:15	4.01	16.58	0.0						
THC run1	3/22/2017 15:07:30	4.02	16.62	0.0						
THC run1	3/22/2017 15:07:45	4.03	16.60	0.0						
THC run1	3/22/2017 15:08:00	4.03	16.60	0.0						
THC run1	3/22/2017 15:08:15	3.97	16.63	0.0						
THC run1	3/22/2017 15:08:30	3.91	16.70	0.0						
THC run1	3/22/2017 15:08:45	3.86	16.79	0.0						
THC run1	3/22/2017 15:09:00	3.87	16.82	0.0						
THC run1	3/22/2017 15:09:15	3.88	16.78	0.0						
THC run1	3/22/2017 15:09:30	3.79	16.79	0.0						
THC run1	3/22/2017 15:09:45	3.72	16.88	0.0						
THC run1	3/22/2017 15:10:00	3.75	16.94	0.0						
THC run1	3/22/2017 15:10:15	3.81	16.90	0.0						
THC run1	3/22/2017 15:10:30	3.85	16.84	0.0						
THC run1	3/22/2017 15:10:45	3.79	16.85	0.0						
THC run1	3/22/2017 15:11:00	3.68	16.93	0.0						
aveTHC run	3/22/2017 14:10:00	3.74	16.92	0.0	60					
scg1	3/22/2017 15:11:30	3.62	17.05	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:11:45	3.62	17.06	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:12:00	3.59	17.04	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:12:15	3.57	17.08	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:12:30	3.54	17.10	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:12:45	3.47	17.15	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:13:00	3.43	16.63	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:13:15	2.50	12.94	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:13:30	1.31	6.33	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:13:45	0.71	2.60	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:14:00	0.54	0.64	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:14:15	0.45	0.16	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:14:30	0.46	-0.01	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:14:45	0.45	-0.06	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:15:00	0.44	-0.08	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:15:15	0.44	-0.09	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:15:30	0.43	-0.10	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:15:45	0.48	-0.11	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:16:00	0.44	-0.12	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:16:15	0.42	-0.13	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:16:30	0.45	-0.13	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:16:45	0.44	-0.14	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:17:00	0.43	-0.14	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:17:15	0.44	-0.15	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:17:30	0.42	-0.15	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg1	3/22/2017 15:17:45	0.43	-0.15	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
o2zero1	3/22/2017 15:17:45	0.43	-0.15	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
co2zero1	3/22/2017 15:17:30	0.42	-0.15	0.0	CC263051/cg1	SO2	0 NOx	0 CO2	0 O2	0
scg2	3/22/2017 15:18:00	0.43	-0.16	0.0	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:18:15	0.42	-0.16	0.0	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:18:30	0.44	-0.16	0.0	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:18:45	0.43	-0.16	0.0	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:19:00	0.43	-0.17	0.0	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:19:15	-0.02	-0.28	0.0	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:19:30	0.01	-0.28	-0.1	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:19:45	0.95	-0.13	-0.1	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:20:00	5.06	1.33	0.0	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:20:15	8.64	4.76	-0.2	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:20:30	9.78	7.79	-0.5	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:20:45	10.26	8.66	-0.2	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:21:00	10.22	8.83	-0.2	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:21:15	10.24	9.05	-0.1	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg2	3/22/2017 15:21:30	10.38	9.13	0.0	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
o2span1	3/22/2017 15:21:30	10.38	9.13	0.0	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
co2span1	3/22/2017 15:21:30	10.38	9.13	0.0	EB0070863/cg2	O2	10.11 CO2	9.437	0	0
scg14	3/22/2017 15:21:45	10.42	9.14	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:22:00	10.26	9.15	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:22:15	10.46	9.17	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:22:30	10.46	9.15	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:22:45	10.42	9.17	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:23:00	10.47	9.18	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:23:15	10.54	9.19	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:23:30	11.42	8.96	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:23:45	15.48	7.28	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:24:00	18.79	3.35	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:24:15	20.16	1.27	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:24:30	20.58	0.25	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:24:45	20.69	0.01	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:25:00	20.72	-0.08	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:25:15	20.76	-0.11	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg14	3/22/2017 15:25:30	20.75	-0.12	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
thczero1	3/22/2017 15:25:30	20.75	-0.12	0.0	CC281749/cg14	NOx	0 CO2	0 THC	0 SO2	0
scg12	3/22/2017 15:25:45	20.82	-0.14	0.0	CC454100/cg12	THC	15.2	0	0	0

name	FE O2	FE CO2	A THC			
sn	1151210012	1151210012	1106047146			
offset	0	0	0			
fullscale	100	20	30			
train	1	1	1			
gastype	o2 3a	co2 3a	thc 25a			
scg12	3/22/2017 15:26:00	20.82	-0.14	0.0	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:26:15	20.75	-0.16	0.0	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:26:30	20.76	-0.16	0.5	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:26:45	20.78	-0.15	7.4	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:27:00	20.79	-0.16	13.9	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:27:15	20.79	-0.16	14.8	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:27:30	20.80	-0.16	14.9	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:27:45	20.96	-0.15	14.9	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:28:00	21.15	-0.15	14.9	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:28:15	21.23	-0.16	14.9	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:28:30	21.27	-0.17	14.9	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:28:45	21.28	-0.17	14.8	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:29:00	20.95	-0.22	14.8	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:29:15	21.28	-0.18	14.8	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:29:30	21.27	-0.18	14.9	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:29:45	21.28	-0.18	14.8	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:30:00	21.29	-0.18	14.8	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:30:15	21.28	-0.19	14.8	CC454100/cg12	THC 15.2 0 0 0
scg12	3/22/2017 15:30:30	21.30	-0.19	14.9	CC454100/cg12	THC 15.2 0 0 0
thcspan1	3/22/2017 15:30:30	21.30	-0.19	14.9	CC454100/cg12	THC 15.2 0 0 0
THC run2	3/22/2017 15:50:30	3.69	16.94	0.0		
THC run2	3/22/2017 15:50:45	3.62	16.99	0.0		
THC run2	3/22/2017 15:51:00	3.59	17.05	0.0		
THC run2	3/22/2017 15:51:15	3.56	17.10	0.0		
THC run2	3/22/2017 15:51:30	3.53	17.14	0.0		
THC run2	3/22/2017 15:51:45	3.46	17.17	0.0		
THC run2	3/22/2017 15:52:00	2.75	17.12	-0.1		
THC run2	3/22/2017 15:52:15	3.38	17.24	0.0		
THC run2	3/22/2017 15:52:30	3.28	17.34	0.0		
THC run2	3/22/2017 15:52:45	3.26	17.40	0.0		
THC run2	3/22/2017 15:53:00	3.29	17.40	0.0		
THC run2	3/22/2017 15:53:15	3.26	17.40	0.0		
THC run2	3/22/2017 15:53:30	3.25	17.43	0.0		
THC run2	3/22/2017 15:53:45	3.30	17.43	0.0		
THC run2	3/22/2017 15:54:00	3.41	17.35	0.0		
THC run2	3/22/2017 15:54:15	3.50	17.22	0.0		
THC run2	3/22/2017 15:54:30	3.51	17.13	0.0		
THC run2	3/22/2017 15:54:45	3.50	17.14	0.0		
THC run2	3/22/2017 15:55:00	3.55	17.14	0.0		
THC run2	3/22/2017 15:55:15	3.56	17.12	0.0		
THC run2	3/22/2017 15:55:30	3.59	17.09	0.0		
THC run2	3/22/2017 15:55:45	3.60	17.07	0.0		
THC run2	3/22/2017 15:56:00	3.69	17.06	0.0		
THC run2	3/22/2017 15:56:15	3.72	17.02	0.0		
THC run2	3/22/2017 15:56:30	3.72	16.96	0.0		
THC run2	3/22/2017 15:56:45	3.62	16.95	0.0		
THC run2	3/22/2017 15:57:00	3.61	17.02	0.0		
THC run2	3/22/2017 15:57:15	3.66	17.02	0.0		
THC run2	3/22/2017 15:57:30	3.64	17.00	0.0		
THC run2	3/22/2017 15:57:45	3.68	17.00	0.0		
THC run2	3/22/2017 15:58:00	3.72	16.97	0.0		
THC run2	3/22/2017 15:58:15	3.75	16.94	0.0		
THC run2	3/22/2017 15:58:30	3.78	16.92	0.0		
THC run2	3/22/2017 15:58:45	3.87	16.87	0.0		
THC run2	3/22/2017 15:59:00	3.93	16.77	0.0		
THC run2	3/22/2017 15:59:15	3.97	16.68	0.0		
THC run2	3/22/2017 15:59:30	3.98	16.65	0.0		
THC run2	3/22/2017 15:59:45	3.92	16.70	0.0		
THC run2	3/22/2017 16:00:00	3.79	16.82	0.0		
THC run2	3/22/2017 16:00:15	3.80	16.88	0.0		
THC run2	3/22/2017 16:00:30	3.82	16.86	0.0		
THC run2	3/22/2017 16:00:45	3.90	16.83	0.0		
THC run2	3/22/2017 16:01:00	3.87	16.81	0.0		
THC run2	3/22/2017 16:01:15	3.84	16.83	0.0		
THC run2	3/22/2017 16:01:30	3.88	16.80	0.0		
THC run2	3/22/2017 16:01:45	3.94	16.74	0.0		
THC run2	3/22/2017 16:02:00	3.98	16.68	0.0		
THC run2	3/22/2017 16:02:15	3.96	16.66	0.0		
THC run2	3/22/2017 16:02:30	3.91	16.71	0.0		
THC run2	3/22/2017 16:02:45	3.87	16.76	0.0		
THC run2	3/22/2017 16:03:00	3.84	16.82	0.0		
THC run2	3/22/2017 16:03:15	3.79	16.87	0.0		
THC run2	3/22/2017 16:03:30	3.79	16.90	0.0		
THC run2	3/22/2017 16:03:45	3.84	16.85	0.0		
THC run2	3/22/2017 16:04:00	3.90	16.77	0.0		
THC run2	3/22/2017 16:04:15	3.91	16.74	0.0		
THC run2	3/22/2017 16:04:30	3.91	16.74	0.0		
THC run2	3/22/2017 16:04:45	3.92	16.74	0.0		
THC run2	3/22/2017 16:05:00	3.93	16.74	0.0		
THC run2	3/22/2017 16:05:15	3.96	16.73	0.0		
THC run2	3/22/2017 16:05:30	4.04	16.69	0.0		
THC run2	3/22/2017 16:05:45	4.08	16.61	0.0		
THC run2	3/22/2017 16:06:00	4.08	16.54	0.0		
THC run2	3/22/2017 16:06:15	4.10	16.54	0.0		
THC run2	3/22/2017 16:06:30	4.03	16.58	0.0		
THC run2	3/22/2017 16:06:45	4.06	16.60	0.0		
THC run2	3/22/2017 16:07:00	4.05	16.59	0.0		
THC run2	3/22/2017 16:07:15	4.04	16.61	0.0		
THC run2	3/22/2017 16:07:30	4.03	16.63	0.0		
THC run2	3/22/2017 16:07:45	3.98	16.65	0.0		
THC run2	3/22/2017 16:08:00	3.91	16.71	0.3		
THC run2	3/22/2017 16:08:15	3.89	16.75	0.5		
THC run2	3/22/2017 16:08:30	3.85	16.78	0.6		
THC run2	3/22/2017 16:08:45	3.87	16.80	0.6		
THC run2	3/22/2017 16:09:00	3.88	16.78	0.6		
THC run2	3/22/2017 16:09:15	3.88	16.76	0.4		
THC run2	3/22/2017 16:09:30	3.88	16.77	0.2		
THC run2	3/22/2017 16:09:45	3.86	16.80	0.0		

name		FE O2	FE CO2	A THC
sn		1151210012	1151210012	1106047146
offset		0	0	0
fullscale		100	20	30
train		1	1	1
gastype		o2 3a	co2 3a	thc 25a
THC run2	3/22/2017 16:10:00	3.86	16.81	0.0
THC run2	3/22/2017 16:10:15	3.85	16.80	0.0
THC run2	3/22/2017 16:10:30	3.79	16.84	0.0
THC run2	3/22/2017 16:10:45	3.69	16.90	0.0
THC run2	3/22/2017 16:11:00	3.57	16.99	0.0
THC run2	3/22/2017 16:11:15	3.54	17.09	0.0
THC run2	3/22/2017 16:11:30	3.59	17.10	0.0
THC run2	3/22/2017 16:11:45	3.72	17.04	0.0
THC run2	3/22/2017 16:12:00	3.82	16.91	0.0
THC run2	3/22/2017 16:12:15	3.79	16.87	0.0
THC run2	3/22/2017 16:12:30	3.76	16.91	0.0
THC run2	3/22/2017 16:12:45	3.79	16.91	0.0
THC run2	3/22/2017 16:13:00	3.77	16.89	0.0
THC run2	3/22/2017 16:13:15	3.67	16.91	0.0
THC run2	3/22/2017 16:13:30	3.60	16.99	0.0
THC run2	3/22/2017 16:13:45	3.57	17.05	0.0
THC run2	3/22/2017 16:14:00	3.61	17.06	0.0
THC run2	3/22/2017 16:14:15	3.71	17.01	0.0
THC run2	3/22/2017 16:14:30	3.76	16.93	0.0
THC run2	3/22/2017 16:14:45	3.71	16.92	0.0
THC run2	3/22/2017 16:15:00	3.65	17.00	0.0
THC run2	3/22/2017 16:15:15	3.69	17.03	0.0
THC run2	3/22/2017 16:15:30	3.73	16.96	0.0
THC run2	3/22/2017 16:15:45	3.77	16.89	0.0
THC run2	3/22/2017 16:16:00	3.81	16.84	0.0
THC run2	3/22/2017 16:16:15	3.76	16.85	0.0
THC run2	3/22/2017 16:16:30	3.62	16.95	0.0
THC run2	3/22/2017 16:16:45	3.53	17.07	0.0
THC run2	3/22/2017 16:17:00	3.51	17.17	0.0
THC run2	3/22/2017 16:17:15	3.53	17.16	0.0
THC run2	3/22/2017 16:17:30	3.51	17.16	0.0
THC run2	3/22/2017 16:17:45	3.45	17.19	0.0
THC run2	3/22/2017 16:18:00	3.38	17.24	0.0
THC run2	3/22/2017 16:18:15	3.39	17.28	0.0
THC run2	3/22/2017 16:18:30	3.43	17.26	0.0
THC run2	3/22/2017 16:18:45	3.45	17.24	0.0
THC run2	3/22/2017 16:19:00	3.46	17.23	0.0
THC run2	3/22/2017 16:19:15	3.50	17.21	0.0
THC run2	3/22/2017 16:19:30	3.56	17.15	0.0
THC run2	3/22/2017 16:19:45	3.55	17.13	0.0
THC run2	3/22/2017 16:20:00	3.55	17.15	0.0
THC run2	3/22/2017 16:20:15	3.56	17.13	0.0
THC run2	3/22/2017 16:20:30	3.59	17.07	0.0
THC run2	3/22/2017 16:20:45	3.66	17.03	0.0
THC run2	3/22/2017 16:21:00	3.73	16.96	0.0
THC run2	3/22/2017 16:21:15	3.75	16.92	0.0
THC run2	3/22/2017 16:21:30	3.68	16.95	0.0
THC run2	3/22/2017 16:21:45	3.65	16.99	0.0
THC run2	3/22/2017 16:22:00	3.65	17.02	0.0
THC run2	3/22/2017 16:22:15	3.65	17.05	0.0
THC run2	3/22/2017 16:22:30	3.72	16.99	0.0
THC run2	3/22/2017 16:22:45	3.75	16.91	0.0
THC run2	3/22/2017 16:23:00	3.76	16.90	0.0
THC run2	3/22/2017 16:23:15	3.78	16.90	0.0
THC run2	3/22/2017 16:23:30	3.80	16.89	0.0
THC run2	3/22/2017 16:23:45	3.80	16.87	0.0
THC run2	3/22/2017 16:24:00	3.83	16.85	0.0
THC run2	3/22/2017 16:24:15	3.88	16.83	0.0
THC run2	3/22/2017 16:24:30	3.88	16.81	0.0
THC run2	3/22/2017 16:24:45	3.86	16.80	0.0
THC run2	3/22/2017 16:25:00	3.87	16.77	0.0
THC run2	3/22/2017 16:25:15	3.92	16.74	0.0
THC run2	3/22/2017 16:25:30	4.02	16.69	0.0
THC run2	3/22/2017 16:25:45	3.98	16.68	0.0
THC run2	3/22/2017 16:26:00	4.01	16.65	0.0
THC run2	3/22/2017 16:26:15	4.00	16.64	0.0
THC run2	3/22/2017 16:26:30	3.97	16.66	0.0
THC run2	3/22/2017 16:26:45	3.96	16.70	0.0
THC run2	3/22/2017 16:27:00	3.89	16.77	0.0
THC run2	3/22/2017 16:27:15	3.91	16.75	0.0
THC run2	3/22/2017 16:27:30	3.95	16.69	0.0
THC run2	3/22/2017 16:27:45	3.92	16.69	0.0
THC run2	3/22/2017 16:28:00	3.90	16.75	0.0
THC run2	3/22/2017 16:28:15	3.92	16.74	0.0
THC run2	3/22/2017 16:28:30	3.94	16.70	0.0
THC run2	3/22/2017 16:28:45	3.92	16.72	0.0
THC run2	3/22/2017 16:29:00	3.92	16.73	0.0
THC run2	3/22/2017 16:29:15	3.90	16.74	0.0
THC run2	3/22/2017 16:29:30	3.84	16.78	0.0
THC run2	3/22/2017 16:29:45	3.82	16.82	0.0
THC run2	3/22/2017 16:30:00	3.81	16.86	0.0
THC run2	3/22/2017 16:30:15	3.79	16.86	0.0
THC run2	3/22/2017 16:30:30	3.80	16.86	0.0
THC run2	3/22/2017 16:30:45	3.86	16.83	0.0
THC run2	3/22/2017 16:31:00	3.92	16.75	0.0
THC run2	3/22/2017 16:31:15	3.97	16.70	0.0
THC run2	3/22/2017 16:31:30	3.95	16.69	0.0
THC run2	3/22/2017 16:31:45	3.80	16.75	0.0
THC run2	3/22/2017 16:32:00	3.62	16.91	0.0
THC run2	3/22/2017 16:32:15	3.52	17.05	0.0
THC run2	3/22/2017 16:32:30	3.49	17.14	0.0
THC run2	3/22/2017 16:32:45	3.53	17.16	0.0
THC run2	3/22/2017 16:33:00	3.59	17.12	0.0
THC run2	3/22/2017 16:33:15	3.62	17.11	0.0
THC run2	3/22/2017 16:33:30	3.69	17.03	0.0
THC run2	3/22/2017 16:33:45	3.76	16.96	0.0
THC run2	3/22/2017 16:34:00	3.81	16.89	0.0
THC run2	3/22/2017 16:34:15	3.81	16.84	0.0

name		FE O2	FE CO2	A THC
sn		1151210012	1151210012	1106047146
offset		0	0	0
fullscale		100	20	30
train		1	1	1
gastype		o2 3a	co2 3a	thc 25a
THC run2	3/22/2017 16:34:30	3.79	16.82	0.0
THC run2	3/22/2017 16:34:45	3.85	16.85	0.0
THC run2	3/22/2017 16:35:00	3.97	16.76	0.0
THC run2	3/22/2017 16:35:15	4.06	16.63	0.0
THC run2	3/22/2017 16:35:30	4.02	16.58	0.0
THC run2	3/22/2017 16:35:45	3.95	16.66	0.0
THC run2	3/22/2017 16:36:00	3.91	16.73	0.0
THC run2	3/22/2017 16:36:15	3.88	16.77	0.0
THC run2	3/22/2017 16:36:30	3.82	16.78	0.0
THC run2	3/22/2017 16:36:45	3.71	16.84	0.0
THC run2	3/22/2017 16:37:00	3.65	16.96	0.0
THC run2	3/22/2017 16:37:15	3.65	16.99	0.0
THC run2	3/22/2017 16:37:30	3.61	17.02	0.0
THC run2	3/22/2017 16:37:45	3.52	17.07	0.0
THC run2	3/22/2017 16:38:00	3.50	17.16	0.0
THC run2	3/22/2017 16:38:15	3.59	17.17	0.0
THC run2	3/22/2017 16:38:30	3.71	17.06	0.0
THC run2	3/22/2017 16:38:45	3.80	16.94	0.0
THC run2	3/22/2017 16:39:00	3.75	16.86	0.0
THC run2	3/22/2017 16:39:15	3.65	16.91	0.0
THC run2	3/22/2017 16:39:30	3.60	17.02	0.0
THC run2	3/22/2017 16:39:45	3.56	17.08	0.0
THC run2	3/22/2017 16:40:00	3.51	17.13	0.0
THC run2	3/22/2017 16:40:15	3.45	17.19	0.0
THC run2	3/22/2017 16:40:30	3.40	17.26	0.0
THC run2	3/22/2017 16:40:45	3.43	17.28	0.0
THC run2	3/22/2017 16:41:00	3.54	17.24	0.0
THC run2	3/22/2017 16:41:15	3.57	17.17	0.0
THC run2	3/22/2017 16:41:30	3.55	17.08	0.0
THC run2	3/22/2017 16:41:45	3.51	17.10	0.0
THC run2	3/22/2017 16:42:00	3.55	17.15	0.0
THC run2	3/22/2017 16:42:15	3.66	17.10	0.0
THC run2	3/22/2017 16:42:30	3.79	16.95	0.0
THC run2	3/22/2017 16:42:45	3.83	16.87	0.0
THC run2	3/22/2017 16:43:00	3.81	16.86	0.0
THC run2	3/22/2017 16:43:15	3.77	16.88	0.0
THC run2	3/22/2017 16:43:30	3.78	16.90	0.0
THC run2	3/22/2017 16:43:45	3.81	16.85	0.0
THC run2	3/22/2017 16:44:00	3.81	16.83	0.0
THC run2	3/22/2017 16:44:15	3.81	16.84	0.0
THC run2	3/22/2017 16:44:30	3.80	16.85	0.0
THC run2	3/22/2017 16:44:45	3.80	16.87	0.0
THC run2	3/22/2017 16:45:00	3.83	16.85	0.0
THC run2	3/22/2017 16:45:15	3.86	16.82	0.0
THC run2	3/22/2017 16:45:30	3.92	16.79	0.0
THC run2	3/22/2017 16:45:45	3.99	16.72	0.0
THC run2	3/22/2017 16:46:00	3.97	16.64	0.0
THC run2	3/22/2017 16:46:15	3.88	16.67	0.0
THC run2	3/22/2017 16:46:30	3.85	16.77	0.0
THC run2	3/22/2017 16:46:45	3.87	16.79	0.0
THC run2	3/22/2017 16:47:00	3.88	16.78	0.0
THC run2	3/22/2017 16:47:15	3.87	16.79	0.0
THC run2	3/22/2017 16:47:30	3.83	16.81	0.0
THC run2	3/22/2017 16:47:45	3.82	16.84	0.0
THC run2	3/22/2017 16:48:00	3.85	16.86	0.0
THC run2	3/22/2017 16:48:15	3.82	16.83	0.0
THC run2	3/22/2017 16:48:30	3.82	16.83	0.0
THC run2	3/22/2017 16:48:45	3.73	16.89	0.0
THC run2	3/22/2017 16:49:00	3.67	16.94	0.0
THC run2	3/22/2017 16:49:15	3.62	16.99	0.0
THC run2	3/22/2017 16:49:30	3.60	17.06	0.0
THC run2	3/22/2017 16:49:45	3.68	17.04	0.0
THC run2	3/22/2017 16:50:00	3.62	16.95	0.0
THC run2	3/22/2017 16:50:15	3.72	16.95	0.0
THC run2	3/22/2017 16:50:30	3.80	16.89	0.0
THC run2	3/22/2017 16:50:45	3.81	16.83	0.0
THC run2	3/22/2017 16:51:00	3.73	16.87	0.0
THC run2	3/22/2017 16:51:15	3.71	16.94	0.0
THC run2	3/22/2017 16:51:30	3.65	16.97	0.0
THC run2	3/22/2017 16:51:45	3.63	17.01	0.0
THC run2	3/22/2017 16:52:00	3.67	17.03	0.0
THC run2	3/22/2017 16:52:15	3.73	16.97	0.0
THC run2	3/22/2017 16:52:30	3.78	16.94	0.0
THC run2	3/22/2017 16:52:45	3.81	16.90	0.0
THC run2	3/22/2017 16:53:00	3.87	16.79	0.0
THC run2	3/22/2017 16:53:15	3.91	16.75	0.0
THC run2	3/22/2017 16:53:30	3.92	16.71	0.0
THC run2	3/22/2017 16:53:45	3.89	16.70	0.0
THC run2	3/22/2017 16:54:00	3.81	16.80	0.0
THC run2	3/22/2017 16:54:15	3.71	16.89	0.0
THC run2	3/22/2017 16:54:30	3.71	16.97	0.0
THC run2	3/22/2017 16:54:45	3.73	16.96	0.0
THC run2	3/22/2017 16:55:00	3.68	16.95	0.0
THC run2	3/22/2017 16:55:15	3.62	16.98	0.0
THC run2	3/22/2017 16:55:30	3.56	17.04	0.0
THC run2	3/22/2017 16:55:45	3.57	17.08	0.0
THC run2	3/22/2017 16:56:00	3.60	17.08	0.0
THC run2	3/22/2017 16:56:15	3.63	17.05	0.0
THC run2	3/22/2017 16:56:30	3.62	17.03	0.0
THC run2	3/22/2017 16:56:45	3.57	17.06	0.0
THC run2	3/22/2017 16:57:00	3.48	17.14	0.0
THC run2	3/22/2017 16:57:15	3.47	17.24	0.0
THC run2	3/22/2017 16:57:30	3.46	17.23	0.0
THC run2	3/22/2017 16:57:45	3.56	17.15	0.0
THC run2	3/22/2017 16:58:00	3.65	17.06	0.0
THC run2	3/22/2017 16:58:15	3.71	16.99	0.0
THC run2	3/22/2017 16:58:30	3.79	16.91	0.0
THC run2	3/22/2017 16:58:45	3.82	16.87	0.0

name		FE O2	FE CO2	A THC
sn		1151210012	1151210012	1106047146
offset		0	0	0
fullscale		100	20	30
train		1	1	1
gastype		o2 3a	co2 3a	thc 25a
THC run2	3/22/2017 16:59:00	3.85	16.83	0.0
THC run2	3/22/2017 16:59:15	3.87	16.80	0.0
THC run2	3/22/2017 16:59:30	3.85	16.80	0.0
THC run2	3/22/2017 16:59:45	3.84	16.82	0.0
THC run2	3/22/2017 17:00:00	3.83	16.80	0.0
THC run2	3/22/2017 17:00:15	3.88	16.78	0.0
THC run2	3/22/2017 17:00:30	3.91	16.73	0.0
THC run2	3/22/2017 17:00:45	3.85	16.74	0.0
THC run2	3/22/2017 17:01:00	3.83	16.80	0.0
THC run2	3/22/2017 17:01:15	3.83	16.84	0.0
THC run2	3/22/2017 17:01:30	3.82	16.84	0.0
THC run2	3/22/2017 17:01:45	3.78	16.87	0.0
THC run2	3/22/2017 17:02:00	3.75	16.91	0.0
THC run2	3/22/2017 17:02:15	3.72	16.89	0.0
THC run2	3/22/2017 17:02:30	3.67	16.92	0.0
THC run2	3/22/2017 17:02:45	3.65	16.98	0.0
THC run2	3/22/2017 17:03:00	3.60	17.03	0.0
THC run2	3/22/2017 17:03:15	3.53	17.10	0.0
THC run2	3/22/2017 17:03:30	3.54	17.14	0.0
THC run2	3/22/2017 17:03:45	3.64	17.10	0.0
THC run2	3/22/2017 17:04:00	3.73	17.00	0.0
THC run2	3/22/2017 17:04:15	3.70	16.95	0.0
THC run2	3/22/2017 17:04:30	3.60	16.99	0.0
THC run2	3/22/2017 17:04:45	3.48	17.09	0.0
THC run2	3/22/2017 17:05:00	3.42	17.21	0.0
THC run2	3/22/2017 17:05:15	3.44	17.25	0.0
THC run2	3/22/2017 17:05:30	3.45	17.25	0.0
THC run2	3/22/2017 17:05:45	3.54	17.19	0.0
THC run2	3/22/2017 17:06:00	3.54	17.14	0.0
THC run2	3/22/2017 17:06:15	3.52	17.16	0.0
THC run2	3/22/2017 17:06:30	3.53	17.16	0.0
THC run2	3/22/2017 17:06:45	3.55	17.11	0.0
THC run2	3/22/2017 17:07:00	3.53	17.09	0.0
THC run2	3/22/2017 17:07:15	3.48	17.14	0.0
THC run2	3/22/2017 17:07:30	3.50	17.17	0.0
THC run2	3/22/2017 17:07:45	3.54	17.15	0.0
THC run2	3/22/2017 17:08:00	3.56	17.12	0.0
THC run2	3/22/2017 17:08:15	3.57	17.11	0.0
THC run2	3/22/2017 17:08:30	3.59	17.09	0.0
THC run2	3/22/2017 17:08:45	3.62	17.07	0.0
THC run2	3/22/2017 17:09:00	3.72	17.00	0.0
THC run2	3/22/2017 17:09:15	3.81	16.88	0.0
THC run2	3/22/2017 17:09:30	3.85	16.81	0.0
THC run2	3/22/2017 17:09:45	3.91	16.78	0.0
THC run2	3/22/2017 17:10:00	3.98	16.69	0.0
THC run2	3/22/2017 17:10:15	4.01	16.63	0.0
THC run2	3/22/2017 17:10:30	4.03	16.63	0.0
THC run2	3/22/2017 17:10:45	4.06	16.61	0.0
THC run2	3/22/2017 17:11:00	4.07	16.58	0.0
THC run2	3/22/2017 17:11:15	4.07	16.58	0.0
THC run2	3/22/2017 17:11:30	4.11	16.52	0.0
THC run2	3/22/2017 17:11:45	4.13	16.48	0.0
THC run2	3/22/2017 17:12:00	4.09	16.50	0.0
THC run2	3/22/2017 17:12:15	4.08	16.54	0.0
THC run2	3/22/2017 17:12:30	4.04	16.56	0.0
THC run2	3/22/2017 17:12:45	3.94	16.62	0.0
THC run2	3/22/2017 17:13:00	3.87	16.67	0.0
THC run2	3/22/2017 17:13:15	3.72	16.75	0.0
THC run2	3/22/2017 17:13:30	3.77	16.86	0.0
THC run2	3/22/2017 17:13:45	3.81	16.86	0.0
THC run2	3/22/2017 17:14:00	3.81	16.82	0.0
THC run2	3/22/2017 17:14:15	3.81	16.84	0.0
THC run2	3/22/2017 17:14:30	3.82	16.84	0.0
THC run2	3/22/2017 17:14:45	3.81	16.85	0.0
THC run2	3/22/2017 17:15:00	3.81	16.87	0.0
THC run2	3/22/2017 17:15:15	3.79	16.87	0.0
THC run2	3/22/2017 17:15:30	3.72	16.90	0.0
THC run2	3/22/2017 17:15:45	3.65	16.97	0.0
THC run2	3/22/2017 17:16:00	3.55	17.02	0.0
THC run2	3/22/2017 17:16:15	3.50	17.11	0.0
THC run2	3/22/2017 17:16:30	3.44	17.21	0.0
THC run2	3/22/2017 17:16:45	3.45	17.22	0.0
THC run2	3/22/2017 17:17:00	3.51	17.18	0.0
THC run2	3/22/2017 17:17:15	3.53	17.16	0.0
THC run2	3/22/2017 17:17:30	3.49	17.17	0.0
THC run2	3/22/2017 17:17:45	3.45	17.21	0.0
THC run2	3/22/2017 17:18:00	3.45	17.23	0.0
THC run2	3/22/2017 17:18:15	3.44	17.22	0.0
THC run2	3/22/2017 17:18:30	3.47	17.19	0.0
THC run2	3/22/2017 17:18:45	3.53	17.15	0.0
THC run2	3/22/2017 17:19:00	3.53	17.12	0.0
THC run2	3/22/2017 17:19:15	3.51	17.14	0.0
THC run2	3/22/2017 17:19:30	3.55	17.13	0.0
THC run2	3/22/2017 17:19:45	3.56	17.12	0.0
THC run2	3/22/2017 17:20:00	3.51	17.15	0.0
THC run2	3/22/2017 17:20:15	3.51	17.18	0.0
THC run2	3/22/2017 17:20:30	3.51	17.18	0.0
THC run2	3/22/2017 17:20:45	3.51	17.16	0.0
THC run2	3/22/2017 17:21:00	3.53	17.11	0.0
THC run2	3/22/2017 17:21:15	3.60	17.08	0.0
THC run2	3/22/2017 17:21:30	3.79	16.97	0.0
THC run2	3/22/2017 17:21:45	3.87	16.85	0.0
THC run2	3/22/2017 17:22:00	3.87	16.79	0.0
THC run2	3/22/2017 17:22:15	3.91	16.77	0.0
THC run2	3/22/2017 17:22:30	4.00	16.71	0.0
THC run2	3/22/2017 17:22:45	3.99	16.67	0.0
THC run2	3/22/2017 17:23:00	3.96	16.65	0.0
THC run2	3/22/2017 17:23:15	4.02	16.63	0.0

name	FE O2	FE CO2	A THC	
sn	1151210012	1151210012	1106047146	
offset	0	0	0	
fullscale	100	20	30	
train	1	1	1	
gastype	o2 3a	co2 3a	thc 25a	
THC run2	3/22/2017 17:23:30	3.76	16.62	0.0
THC run2	3/22/2017 17:23:45	3.91	16.69	0.0
THC run2	3/22/2017 17:24:00	3.82	16.71	0.0
THC run2	3/22/2017 17:24:15	3.68	16.74	0.0
THC run2	3/22/2017 17:24:30	3.79	16.86	0.0
THC run2	3/22/2017 17:24:45	3.84	16.85	0.0
THC run2	3/22/2017 17:25:00	3.78	16.77	0.0
THC run2	3/22/2017 17:25:15	3.87	16.78	0.0
THC run2	3/22/2017 17:25:30	3.86	16.78	0.0
THC run2	3/22/2017 17:25:45	3.80	16.80	0.0
THC run2	3/22/2017 17:26:00	3.77	16.84	0.0
THC run2	3/22/2017 17:26:15	3.85	16.84	0.0
THC run2	3/22/2017 17:26:30	3.88	16.79	0.0
THC run2	3/22/2017 17:26:45	3.85	16.79	0.0
THC run2	3/22/2017 17:27:00	3.70	16.89	0.0
THC run2	3/22/2017 17:27:15	3.68	16.95	0.0
THC run2	3/22/2017 17:27:30	3.76	16.95	0.0
THC run2	3/22/2017 17:27:45	3.78	16.92	0.0
THC run2	3/22/2017 17:28:00	3.76	16.89	0.0
THC run2	3/22/2017 17:28:15	3.76	16.88	0.0
THC run2	3/22/2017 17:28:30	3.75	16.88	0.0
THC run2	3/22/2017 17:28:45	3.75	16.88	0.0
THC run2	3/22/2017 17:29:00	3.76	16.91	0.0
THC run2	3/22/2017 17:29:15	3.67	16.96	0.0
THC run2	3/22/2017 17:29:30	3.63	17.01	0.0
THC run2	3/22/2017 17:29:45	3.61	17.05	0.0
THC run2	3/22/2017 17:30:00	3.66	17.04	0.0
THC run2	3/22/2017 17:30:15	3.75	16.98	0.0
THC run2	3/22/2017 17:30:30	3.78	16.89	0.0
THC run2	3/22/2017 17:30:45	3.79	16.86	0.0
THC run2	3/22/2017 17:31:00	3.80	16.87	0.0
THC run2	3/22/2017 17:31:15	3.80	16.86	0.0
THC run2	3/22/2017 17:31:30	3.76	16.88	0.0
THC run2	3/22/2017 17:31:45	3.65	16.95	0.0
THC run2	3/22/2017 17:32:00	3.61	17.03	0.0
THC run2	3/22/2017 17:32:15	3.64	17.05	0.0
THC run2	3/22/2017 17:32:30	3.70	17.02	0.0
THC run2	3/22/2017 17:32:45	3.77	16.92	0.0
THC run2	3/22/2017 17:33:00	3.73	16.86	0.0
THC run2	3/22/2017 17:33:15	3.62	16.94	0.0
THC run2	3/22/2017 17:33:30	3.58	17.04	0.0
THC run2	3/22/2017 17:33:45	3.54	17.10	0.0
THC run2	3/22/2017 17:34:00	3.57	17.12	0.0
THC run2	3/22/2017 17:34:15	3.61	17.09	0.0
THC run2	3/22/2017 17:34:30	3.61	17.07	0.0
THC run2	3/22/2017 17:34:45	3.66	17.05	0.0
THC run2	3/22/2017 17:35:00	3.70	16.98	0.0
THC run2	3/22/2017 17:35:15	3.68	16.94	0.0
THC run2	3/22/2017 17:35:30	3.69	16.95	0.0
THC run2	3/22/2017 17:35:45	3.68	16.94	0.0
THC run2	3/22/2017 17:36:00	3.72	16.95	0.0
THC run2	3/22/2017 17:36:15	3.75	16.94	0.0
THC run2	3/22/2017 17:36:30	3.70	16.95	0.0
THC run2	3/22/2017 17:36:45	3.76	16.95	0.0
THC run2	3/22/2017 17:37:00	3.79	16.91	0.0
THC run2	3/22/2017 17:37:15	3.73	16.90	0.0
THC run2	3/22/2017 17:37:30	3.67	16.92	0.1
THC run2	3/22/2017 17:37:45	3.69	16.97	0.3
THC run2	3/22/2017 17:38:00	3.73	16.97	0.3
THC run2	3/22/2017 17:38:15	3.78	16.92	0.5
THC run2	3/22/2017 17:38:30	3.68	16.93	0.7
THC run2	3/22/2017 17:38:45	3.68	16.99	0.4
THC run2	3/22/2017 17:39:00	3.67	17.01	0.2
THC run2	3/22/2017 17:39:15	3.67	16.98	0.1
THC run2	3/22/2017 17:39:30	3.68	16.96	0.0
THC run2	3/22/2017 17:39:45	3.71	16.94	0.0
THC run2	3/22/2017 17:40:00	3.57	16.88	0.0
THC run2	3/22/2017 17:40:15	3.63	16.97	0.0
THC run2	3/22/2017 17:40:30	3.10	16.98	0.0
THC run2	3/22/2017 17:40:45	3.37	16.99	0.0
THC run2	3/22/2017 17:41:00	3.73	16.97	0.0
THC run2	3/22/2017 17:41:15	3.60	16.89	0.0
THC run2	3/22/2017 17:41:30	3.52	16.87	0.0
THC run2	3/22/2017 17:41:45	3.75	16.91	0.0
THC run2	3/22/2017 17:42:00	3.75	16.90	0.0
THC run2	3/22/2017 17:42:15	3.81	16.86	0.0
THC run2	3/22/2017 17:42:30	3.78	16.83	0.0
THC run2	3/22/2017 17:42:45	3.72	16.86	0.0
THC run2	3/22/2017 17:43:00	3.62	16.96	0.0
THC run2	3/22/2017 17:43:15	3.56	17.03	0.0
THC run2	3/22/2017 17:43:30	3.58	17.07	0.0
THC run2	3/22/2017 17:43:45	3.55	17.08	0.0
THC run2	3/22/2017 17:44:00	3.53	17.13	0.0
THC run2	3/22/2017 17:44:15	3.56	17.14	0.0
THC run2	3/22/2017 17:44:30	3.51	17.11	0.0
THC run2	3/22/2017 17:44:45	3.44	17.17	0.0
THC run2	3/22/2017 17:45:00	3.41	17.25	0.0
THC run2	3/22/2017 17:45:15	3.43	17.23	0.0
THC run2	3/22/2017 17:45:30	3.42	17.22	0.0
THC run2	3/22/2017 17:45:45	3.44	17.25	0.0
THC run2	3/22/2017 17:46:00	3.45	17.24	0.0
THC run2	3/22/2017 17:46:15	3.49	17.20	0.0
THC run2	3/22/2017 17:46:30	3.47	17.20	0.0
THC run2	3/22/2017 17:46:45	3.41	17.23	0.0
THC run2	3/22/2017 17:47:00	3.31	17.27	0.0
THC run2	3/22/2017 17:47:15	3.31	17.29	0.0
THC run2	3/22/2017 17:47:30	3.42	17.29	0.0
THC run2	3/22/2017 17:47:45	3.50	17.21	0.0

name		FE O2	FE CO2	A THC
sn		1151210012	1151210012	1106047146
offset		0	0	0
fullscale		100	20	30
train		1	1	1
gastype		o2 3a	co2 3a	thc 25a
THC run2	3/22/2017 17:48:00	3.53	17.12	0.0
THC run2	3/22/2017 17:48:15	3.50	17.13	0.0
THC run2	3/22/2017 17:48:30	3.52	17.15	0.0
THC run2	3/22/2017 17:48:45	3.61	17.11	0.0
THC run2	3/22/2017 17:49:00	3.71	17.02	0.0
THC run2	3/22/2017 17:49:15	3.77	16.92	0.0
THC run2	3/22/2017 17:49:30	3.68	16.88	0.0
THC run2	3/22/2017 17:49:45	3.53	16.97	0.0
THC run2	3/22/2017 17:50:00	3.48	17.14	0.0
THC run2	3/22/2017 17:50:15	3.50	17.17	0.0
THC run2	3/22/2017 17:50:30	3.57	17.12	0.0
THC run2	3/22/2017 17:50:45	3.67	17.05	0.0
THC run2	3/22/2017 17:51:00	3.72	16.96	0.0
THC run2	3/22/2017 17:51:15	3.74	16.94	0.0
THC run2	3/22/2017 17:51:30	3.83	16.88	0.0
THC run2	3/22/2017 17:51:45	3.90	16.79	0.0
THC run2	3/22/2017 17:52:00	3.90	16.70	0.0
THC run2	3/22/2017 17:52:15	3.81	16.75	0.0
THC run2	3/22/2017 17:52:30	3.76	16.85	0.0
THC run2	3/22/2017 17:52:45	3.76	16.88	0.0
THC run2	3/22/2017 17:53:00	3.70	16.93	0.0
THC run2	3/22/2017 17:53:15	3.69	16.95	0.0
THC run2	3/22/2017 17:53:30	3.67	16.96	0.0
THC run2	3/22/2017 17:53:45	3.63	16.99	0.0
THC run2	3/22/2017 17:54:00	3.64	17.01	0.0
THC run2	3/22/2017 17:54:15	3.64	16.98	0.0
THC run2	3/22/2017 17:54:30	3.74	16.95	0.0
THC run2	3/22/2017 17:54:45	3.85	16.87	0.0
THC run2	3/22/2017 17:55:00	3.91	16.76	0.0
THC run2	3/22/2017 17:55:15	3.93	16.70	0.0
THC run2	3/22/2017 17:55:30	3.91	16.69	0.0
THC run2	3/22/2017 17:55:45	3.88	16.74	0.0
THC run2	3/22/2017 17:56:00	3.85	16.80	0.0
THC run2	3/22/2017 17:56:15	3.80	16.83	0.0
THC run2	3/22/2017 17:56:30	3.73	16.86	0.0
THC run2	3/22/2017 17:56:45	3.69	16.88	0.0
THC run2	3/22/2017 17:57:00	3.73	16.91	0.0
THC run2	3/22/2017 17:57:15	3.79	16.87	0.0
THC run2	3/22/2017 17:57:30	3.83	16.82	0.0
THC run2	3/22/2017 17:57:45	3.88	16.82	0.0
THC run2	3/22/2017 17:58:00	3.81	16.82	0.0
THC run2	3/22/2017 17:58:15	3.81	16.84	0.0
THC run2	3/22/2017 17:58:30	3.84	16.85	0.0
THC run2	3/22/2017 17:58:45	3.94	16.79	0.0
THC run2	3/22/2017 17:59:00	4.01	16.64	0.0
THC run2	3/22/2017 17:59:15	3.95	16.58	0.0
THC run2	3/22/2017 17:59:30	3.84	16.72	0.0
THC run2	3/22/2017 17:59:45	3.66	16.88	0.0
THC run2	3/22/2017 18:00:00	3.65	16.97	0.0
THC run2	3/22/2017 18:00:15	3.69	16.97	0.0
THC run2	3/22/2017 18:00:30	3.72	16.94	0.0
THC run2	3/22/2017 18:00:45	3.67	16.95	0.0
THC run2	3/22/2017 18:01:00	3.63	16.99	0.0
THC run2	3/22/2017 18:01:15	3.66	16.98	0.0
THC run2	3/22/2017 18:01:30	3.75	16.91	0.0
THC run2	3/22/2017 18:01:45	3.77	16.87	0.0
THC run2	3/22/2017 18:02:00	3.69	16.86	0.0
THC run2	3/22/2017 18:02:15	3.62	16.95	0.0
THC run2	3/22/2017 18:02:30	3.59	17.02	0.0
THC run2	3/22/2017 18:02:45	3.59	17.06	0.0
THC run2	3/22/2017 18:03:00	3.57	17.05	0.0
THC run2	3/22/2017 18:03:15	3.49	17.11	0.0
THC run2	3/22/2017 18:03:30	3.46	17.17	0.0
THC run2	3/22/2017 18:03:45	3.55	17.13	0.0
THC run2	3/22/2017 18:04:00	3.61	17.04	0.0
THC run2	3/22/2017 18:04:15	3.51	17.06	0.0
THC run2	3/22/2017 18:04:30	3.47	17.16	0.0
THC run2	3/22/2017 18:04:45	3.51	17.17	0.0
THC run2	3/22/2017 18:05:00	3.51	17.13	0.0
THC run2	3/22/2017 18:05:15	3.50	17.14	0.0
THC run2	3/22/2017 18:05:30	3.50	17.17	0.0
THC run2	3/22/2017 18:05:45	3.53	17.16	0.0
THC run2	3/22/2017 18:06:00	3.57	17.06	0.0
THC run2	3/22/2017 18:06:15	3.54	17.03	0.0
THC run2	3/22/2017 18:06:30	3.58	17.05	0.0
THC run2	3/22/2017 18:06:45	3.69	17.02	0.0
THC run2	3/22/2017 18:07:00	3.63	16.96	0.0
THC run2	3/22/2017 18:07:15	3.62	17.00	0.0
THC run2	3/22/2017 18:07:30	3.66	17.01	0.0
THC run2	3/22/2017 18:07:45	3.72	16.96	0.0
THC run2	3/22/2017 18:08:00	3.77	16.90	0.0
THC run2	3/22/2017 18:08:15	3.78	16.87	0.0
THC run2	3/22/2017 18:08:30	3.80	16.83	0.0
THC run2	3/22/2017 18:08:45	3.85	16.80	0.0
THC run2	3/22/2017 18:09:00	3.68	16.85	0.0
THC run2	3/22/2017 18:09:15	3.58	16.96	0.0
THC run2	3/22/2017 18:09:30	3.54	17.08	0.0
THC run2	3/22/2017 18:09:45	3.55	17.10	0.0
THC run2	3/22/2017 18:10:00	3.58	17.08	0.0
THC run2	3/22/2017 18:10:15	3.61	17.06	0.0
THC run2	3/22/2017 18:10:30	3.63	17.02	0.0
THC run2	3/22/2017 18:10:45	3.60	17.00	0.0
THC run2	3/22/2017 18:11:00	3.55	17.02	0.0
THC run2	3/22/2017 18:11:15	3.50	17.08	0.0
THC run2	3/22/2017 18:11:30	3.47	17.15	0.0
THC run2	3/22/2017 18:11:45	3.48	17.16	0.0
THC run2	3/22/2017 18:12:00	3.59	17.10	0.0
THC run2	3/22/2017 18:12:15	3.66	17.03	0.0

name		FE O2	FE CO2	A THC
sn		1151210012	1151210012	1106047146
offset		0	0	0
fullscale		100	20	30
train		1	1	1
gastype		o2 3a	co2 3a	thc 25a
THC run2	3/22/2017 18:12:30	3.69	16.97	0.0
THC run2	3/22/2017 18:12:45	3.76	16.94	0.0
THC run2	3/22/2017 18:13:00	3.73	16.92	0.0
THC run2	3/22/2017 18:13:15	3.71	16.88	0.0
THC run2	3/22/2017 18:13:30	3.74	16.87	0.0
THC run2	3/22/2017 18:13:45	3.80	16.85	0.0
THC run2	3/22/2017 18:14:00	3.83	16.80	0.0
THC run2	3/22/2017 18:14:15	3.82	16.79	0.0
THC run2	3/22/2017 18:14:30	3.85	16.78	0.0
THC run2	3/22/2017 18:14:45	3.82	16.77	0.0
THC run2	3/22/2017 18:15:00	3.68	16.87	0.0
THC run2	3/22/2017 18:15:15	3.59	16.99	0.0
THC run2	3/22/2017 18:15:30	3.57	17.05	0.0
THC run2	3/22/2017 18:15:45	3.59	17.01	0.0
THC run2	3/22/2017 18:16:00	3.63	16.98	0.0
THC run2	3/22/2017 18:16:15	3.68	16.95	0.0
THC run2	3/22/2017 18:16:30	3.79	16.88	0.0
THC run2	3/22/2017 18:16:45	3.80	16.84	0.0
THC run2	3/22/2017 18:17:00	3.73	16.84	0.0
THC run2	3/22/2017 18:17:15	3.63	16.94	0.0
THC run2	3/22/2017 18:17:30	3.55	17.05	0.0
THC run2	3/22/2017 18:17:45	3.51	17.09	0.0
THC run2	3/22/2017 18:18:00	3.46	17.11	0.0
THC run2	3/22/2017 18:18:15	3.43	17.16	0.0
THC run2	3/22/2017 18:18:30	3.45	17.19	0.0
THC run2	3/22/2017 18:18:45	3.47	17.18	0.0
THC run2	3/22/2017 18:19:00	3.47	17.16	0.0
THC run2	3/22/2017 18:19:15	3.49	17.16	0.0
THC run2	3/22/2017 18:19:30	3.56	17.12	0.0
THC run2	3/22/2017 18:19:45	3.71	17.03	0.0
THC run2	3/22/2017 18:20:00	3.83	16.86	0.0
THC run2	3/22/2017 18:20:15	3.85	16.75	0.0
THC run2	3/22/2017 18:20:30	3.82	16.75	0.0
THC run2	3/22/2017 18:20:45	3.79	16.80	0.0
THC run2	3/22/2017 18:21:00	3.76	16.84	0.0
THC run2	3/22/2017 18:21:15	3.75	16.86	0.0
THC run2	3/22/2017 18:21:30	3.77	16.88	0.0
THC run2	3/22/2017 18:21:45	3.80	16.86	0.0
THC run2	3/22/2017 18:22:00	3.85	16.83	0.0
THC run2	3/22/2017 18:22:15	3.88	16.78	0.0
THC run2	3/22/2017 18:22:30	3.82	16.75	0.0
THC run2	3/22/2017 18:22:45	3.73	16.81	0.0
THC run2	3/22/2017 18:23:00	3.74	16.88	0.0
THC run2	3/22/2017 18:23:15	3.79	16.85	0.0
THC run2	3/22/2017 18:23:30	3.80	16.82	0.0
THC run2	3/22/2017 18:23:45	3.81	16.83	0.0
THC run2	3/22/2017 18:24:00	3.84	16.81	0.0
THC run2	3/22/2017 18:24:15	3.83	16.79	0.0
THC run2	3/22/2017 18:24:30	3.79	16.82	0.0
THC run2	3/22/2017 18:24:45	3.78	16.85	0.0
THC run2	3/22/2017 18:25:00	3.77	16.83	0.0
THC run2	3/22/2017 18:25:15	3.73	16.85	0.0
THC run2	3/22/2017 18:25:30	3.72	16.88	0.0
THC run2	3/22/2017 18:25:45	3.78	16.86	0.0
THC run2	3/22/2017 18:26:00	3.79	16.84	0.0
THC run2	3/22/2017 18:26:15	3.82	16.83	0.0
THC run2	3/22/2017 18:26:30	3.88	16.77	0.0
THC run2	3/22/2017 18:26:45	3.91	16.74	0.0
THC run2	3/22/2017 18:27:00	3.91	16.70	0.0
THC run2	3/22/2017 18:27:15	3.88	16.70	0.0
THC run2	3/22/2017 18:27:30	3.81	16.74	0.0
THC run2	3/22/2017 18:27:45	3.86	16.77	0.0
THC run2	3/22/2017 18:28:00	3.97	16.69	0.0
THC run2	3/22/2017 18:28:15	4.06	16.58	0.0
THC run2	3/22/2017 18:28:30	4.08	16.51	0.0
THC run2	3/22/2017 18:28:45	4.04	16.52	0.0
THC run2	3/22/2017 18:29:00	4.00	16.59	0.0
THC run2	3/22/2017 18:29:15	3.66	16.58	0.0
THC run2	3/22/2017 18:29:30	3.64	16.55	0.0
THC run2	3/22/2017 18:29:45	3.70	16.60	0.0
THC run2	3/22/2017 18:30:00	3.45	16.69	-0.1
THC run2	3/22/2017 18:30:15	3.52	16.72	0.0
THC run2	3/22/2017 18:30:30	3.81	16.79	0.0
THC run2	3/22/2017 18:30:45	3.77	16.81	0.0
THC run2	3/22/2017 18:31:00	3.79	16.86	0.0
THC run2	3/22/2017 18:31:15	3.82	16.85	0.0
THC run2	3/22/2017 18:31:30	3.77	16.82	0.0
THC run2	3/22/2017 18:31:45	3.73	16.88	0.0
THC run2	3/22/2017 18:32:00	3.69	16.91	0.0
THC run2	3/22/2017 18:32:15	3.67	16.89	0.0
THC run2	3/22/2017 18:32:30	3.66	16.91	0.0
THC run2	3/22/2017 18:32:45	3.71	16.92	0.0
THC run2	3/22/2017 18:33:00	3.78	16.86	0.0
THC run2	3/22/2017 18:33:15	3.78	16.81	0.0
THC run2	3/22/2017 18:33:30	3.83	16.79	0.0
THC run2	3/22/2017 18:33:45	3.86	16.79	0.0
THC run2	3/22/2017 18:34:00	3.90	16.78	0.0
THC run2	3/22/2017 18:34:15	3.82	16.77	0.0
THC run2	3/22/2017 18:34:30	3.75	16.80	0.0
THC run2	3/22/2017 18:34:45	3.70	16.85	0.0
THC run2	3/22/2017 18:35:00	3.73	16.89	0.0
THC run2	3/22/2017 18:35:15	3.75	16.88	0.0
THC run2	3/22/2017 18:35:30	3.68	16.89	0.0
THC run2	3/22/2017 18:35:45	3.65	16.94	0.0
THC run2	3/22/2017 18:36:00	3.61	16.98	0.0
THC run2	3/22/2017 18:36:15	3.57	17.02	0.0
THC run2	3/22/2017 18:36:30	3.57	17.05	0.0
THC run2	3/22/2017 18:36:45	3.56	17.03	0.0

name	FE O2	FE CO2	A THC
sn	1151210012	1151210012	1106047146
offset	0	0	0
fullscale	100	20	30
train	1	1	1
gastype	o2 3a	co2 3a	thc 25a
THC run2	3/22/2017 18:37:00	3.56	17.04
THC run2	3/22/2017 18:37:15	3.54	17.07
THC run2	3/22/2017 18:37:30	3.50	17.09
THC run2	3/22/2017 18:37:45	3.48	17.13
THC run2	3/22/2017 18:38:00	3.49	17.16
THC run2	3/22/2017 18:38:15	3.53	17.14
THC run2	3/22/2017 18:38:30	3.57	17.10
THC run2	3/22/2017 18:38:45	3.61	17.04
THC run2	3/22/2017 18:39:00	3.62	16.96
THC run2	3/22/2017 18:39:15	3.59	16.99
THC run2	3/22/2017 18:39:30	3.52	17.05
THC run2	3/22/2017 18:39:45	3.54	17.09
THC run2	3/22/2017 18:40:00	3.60	17.05
THC run2	3/22/2017 18:40:15	3.62	17.00
THC run2	3/22/2017 18:40:30	3.60	17.01
THC run2	3/22/2017 18:40:45	3.60	17.04
THC run2	3/22/2017 18:41:00	3.68	16.99
THC run2	3/22/2017 18:41:15	3.68	16.91
THC run2	3/22/2017 18:41:30	3.57	16.94
THC run2	3/22/2017 18:41:45	3.53	17.05
THC run2	3/22/2017 18:42:00	3.56	17.08
THC run2	3/22/2017 18:42:15	3.61	17.04
THC run2	3/22/2017 18:42:30	3.67	16.99
THC run2	3/22/2017 18:42:45	3.69	16.94
THC run2	3/22/2017 18:43:00	3.71	16.93
THC run2	3/22/2017 18:43:15	3.67	16.95
THC run2	3/22/2017 18:43:30	3.67	16.97
THC run2	3/22/2017 18:43:45	3.77	16.90
THC run2	3/22/2017 18:44:00	3.77	16.82
THC run2	3/22/2017 18:44:15	3.72	16.85
THC run2	3/22/2017 18:44:30	3.71	16.90
THC run2	3/22/2017 18:44:45	3.68	16.89
THC run2	3/22/2017 18:45:00	3.66	16.95
THC run2	3/22/2017 18:45:15	3.67	16.97
THC run2	3/22/2017 18:45:30	3.73	16.93
THC run2	3/22/2017 18:45:45	3.71	16.90
THC run2	3/22/2017 18:46:00	3.67	16.92
THC run2	3/22/2017 18:46:15	3.66	16.92
THC run2	3/22/2017 18:46:30	3.62	16.96
THC run2	3/22/2017 18:46:45	3.67	16.98
THC run2	3/22/2017 18:47:00	3.82	16.88
THC run2	3/22/2017 18:47:15	3.90	16.77
THC run2	3/22/2017 18:47:30	3.94	16.68
THC run2	3/22/2017 18:47:45	3.97	16.65
THC run2	3/22/2017 18:48:00	3.94	16.65
THC run2	3/22/2017 18:48:15	3.95	16.67
THC run2	3/22/2017 18:48:30	3.99	16.60
THC run2	3/22/2017 18:48:45	4.04	16.55
THC run2	3/22/2017 18:49:00	4.08	16.52
THC run2	3/22/2017 18:49:15	4.09	16.52
THC run2	3/22/2017 18:49:30	3.99	16.57
THC run2	3/22/2017 18:49:45	3.99	16.60
THC run2	3/22/2017 18:50:00	3.95	16.62
THC run2	3/22/2017 18:50:15	3.91	16.65
THC run2	3/22/2017 18:50:30	3.93	16.70
THC run2	3/22/2017 18:50:45	3.99	16.66
THC run2	3/22/2017 18:51:00	4.03	16.57
THC run2	3/22/2017 18:51:15	4.06	16.54
THC run2	3/22/2017 18:51:30	4.00	16.56
THC run2	3/22/2017 18:51:45	3.91	16.63
THC run2	3/22/2017 18:52:00	3.88	16.71
THC run2	3/22/2017 18:52:15	3.89	16.72
THC run2	3/22/2017 18:52:30	3.93	16.71
THC run2	3/22/2017 18:52:45	3.94	16.68
THC run2	3/22/2017 18:53:00	3.90	16.68
THC run2	3/22/2017 18:53:15	3.83	16.75
THC run2	3/22/2017 18:53:30	3.80	16.81
THC run2	3/22/2017 18:53:45	3.85	16.78
THC run2	3/22/2017 18:54:00	3.88	16.75
THC run2	3/22/2017 18:54:15	3.85	16.72
THC run2	3/22/2017 18:54:30	3.76	16.80
THC run2	3/22/2017 18:54:45	3.68	16.88
THC run2	3/22/2017 18:55:00	3.65	16.94
THC run2	3/22/2017 18:55:15	3.65	16.97
THC run2	3/22/2017 18:55:30	3.65	16.97
THC run2	3/22/2017 18:55:45	3.66	16.95
THC run2	3/22/2017 18:56:00	3.73	16.89
THC run2	3/22/2017 18:56:15	3.80	16.84
THC run2	3/22/2017 18:56:30	3.80	16.80
THC run2	3/22/2017 18:56:45	3.79	16.82
THC run2	3/22/2017 18:57:00	3.82	16.81
THC run2	3/22/2017 18:57:15	3.80	16.80
THC run2	3/22/2017 18:57:30	3.76	16.84
THC run2	3/22/2017 18:57:45	3.79	16.88
THC run2	3/22/2017 18:58:00	3.83	16.85
THC run2	3/22/2017 18:58:15	3.86	16.77
THC run2	3/22/2017 18:58:30	3.86	16.73
THC run2	3/22/2017 18:58:45	3.90	16.74
THC run2	3/22/2017 18:59:00	3.96	16.69
THC run2	3/22/2017 18:59:15	3.94	16.65
THC run2	3/22/2017 18:59:30	3.93	16.65
THC run2	3/22/2017 18:59:45	3.91	16.68
THC run2	3/22/2017 19:00:00	3.83	16.73
THC run2	3/22/2017 19:00:15	3.82	16.79
THC run2	3/22/2017 19:00:30	3.81	16.83
THC run2	3/22/2017 19:00:45	3.83	16.79
THC run2	3/22/2017 19:01:00	3.79	16.78
THC run2	3/22/2017 19:01:15	3.72	16.84

name	FE O2	FE CO2	A THC										
sn	1151210012	1151210012	1106047146										
offset	0	0	0										
fullscale	100	20	30										
train	1	1	1										
gastype	o2 3a	co2 3a	thc 25a										
THC run2	3/22/2017 19:01:30	3.65	16.92	0.6									
THC run2	3/22/2017 19:01:45	3.58	16.99	0.5									
THC run2	3/22/2017 19:02:00	3.55	17.06	0.4									
THC run2	3/22/2017 19:02:15	3.52	17.12	0.5									
THC run2	3/22/2017 19:02:30	3.50	17.15	0.7									
THC run2	3/22/2017 19:02:45	3.54	17.13	0.6									
THC run2	3/22/2017 19:03:00	3.56	17.09	0.5									
THC run2	3/22/2017 19:03:15	3.57	17.05	0.5									
THC run2	3/22/2017 19:03:30	3.69	17.01	0.4									
THC run2	3/22/2017 19:03:45	3.70	16.97	0.4									
THC run2	3/22/2017 19:04:00	3.76	16.89	0.4									
THC run2	3/22/2017 19:04:15	3.75	16.86	0.2									
THC run2	3/22/2017 19:04:30	3.70	16.89	0.1									
THC run2	3/22/2017 19:04:45	3.67	16.93	0.2									
THC run2	3/22/2017 19:05:00	3.66	16.98	0.2									
THC run2	3/22/2017 19:05:15	3.73	16.97	0.1									
THC run2	3/22/2017 19:05:30	3.85	16.85	0.2									
THC run2	3/22/2017 19:05:45	3.92	16.72	0.4									
THC run2	3/22/2017 19:06:00	3.97	16.64	0.6									
THC run2	3/22/2017 19:06:15	3.95	16.64	0.7									
THC run2	3/22/2017 19:06:30	3.90	16.68	0.7									
THC run2	3/22/2017 19:06:45	3.87	16.72	0.6									
THC run2	3/22/2017 19:07:00	3.86	16.76	0.5									
THC run2	3/22/2017 19:07:15	3.85	16.77	0.5									
THC run2	3/22/2017 19:07:30	3.80	16.79	0.4									
THC run2	3/22/2017 19:07:45	3.77	16.85	0.5									
THC run2	3/22/2017 19:08:00	3.81	16.87	0.7									
THC run2	3/22/2017 19:08:15	3.85	16.80	1.0									
THC run2	3/22/2017 19:08:30	3.90	16.71	1.2									
THC run2	3/22/2017 19:08:45	3.96	16.67	1.2									
THC run2	3/22/2017 19:09:00	3.97	16.63	0.9									
THC run2	3/22/2017 19:09:15	3.87	16.67	0.4									
THC run2	3/22/2017 19:09:30	3.77	16.79	0.2									
THC run2	3/22/2017 19:09:45	3.73	16.88	0.1									
THC run2	3/22/2017 19:10:00	3.81	16.89	0.0									
THC run2	3/22/2017 19:10:15	3.86	16.82	0.0									
THC run2	3/22/2017 19:10:30	3.84	16.80	0.0									
THC run2	3/22/2017 19:10:45	3.86	16.76	0.0									
THC run2	3/22/2017 19:11:00	3.86	16.75	0.0									
THC run2	3/22/2017 19:11:15	3.86	16.75	0.0									
THC run2	3/22/2017 19:11:30	3.87	16.75	0.0									
THC run2	3/22/2017 19:11:45	3.86	16.76	0.0									
THC run2	3/22/2017 19:12:00	3.71	16.74	-0.1									
THC run2	3/22/2017 19:12:15	3.80	16.81	0.0									
THC run2	3/22/2017 19:12:30	3.78	16.87	0.0									
THC run2	3/22/2017 19:12:45	3.42	16.85	-0.2									
THC run2	3/22/2017 19:13:00	3.04	16.80	-0.3									
THC run2	3/22/2017 19:13:15	3.75	16.84	0.0									
THC run2	3/22/2017 19:13:30	3.79	16.85	0.0									
THC run2	3/22/2017 19:13:45	3.79	16.84	0.0									
THC run2	3/22/2017 19:14:00	3.82	16.82	0.0									
THC run2	3/22/2017 19:14:15	3.84	16.80	0.0									
THC run2	3/22/2017 19:14:30	3.83	16.79	0.0									
THC run2	3/22/2017 19:14:45	3.85	16.81	0.0									
THC run2	3/22/2017 19:15:00	3.81	16.81	0.0									
THC run2	3/22/2017 19:15:15	3.73	16.73	-0.2									
THC run2	3/22/2017 19:15:30	3.78	16.73	-0.2									
THC run2	3/22/2017 19:15:45	3.82	16.77	-0.1									
THC run2	3/22/2017 19:16:00	3.78	16.80	0.0									
THC run2	3/22/2017 19:16:15	3.69	16.87	0.0									
THC run2	3/22/2017 19:16:30	3.65	16.96	0.0									
THC run2	3/22/2017 19:16:45	3.72	16.96	0.0									
THC run2	3/22/2017 19:17:00	3.77	16.90	0.0									
THC run2	3/22/2017 19:17:15	3.82	16.88	0.0									
THC run2	3/22/2017 19:17:30	3.81	16.87	0.0									
THC run2	3/22/2017 19:17:45	3.83	16.84	0.0									
THC run2	3/22/2017 19:18:00	3.85	16.78	0.0									
THC run2	3/22/2017 19:18:15	3.88	16.76	0.0									
THC run2	3/22/2017 19:18:30	3.87	16.76	0.0									
THC run2	3/22/2017 19:18:45	3.77	16.79	0.0									
THC run2	3/22/2017 19:19:00	3.68	16.90	0.0									
THC run2	3/22/2017 19:19:15	3.71	16.96	0.0									
aveTHC run	3/22/2017 18:18:00	3.76	16.84	0.5	60								
scg1	3/22/2017 19:19:30	3.77	16.92	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:19:45	3.79	16.90	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:20:00	3.81	16.87	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:20:15	3.79	16.84	0.1	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:20:30	3.78	16.81	0.1	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:20:45	3.80	16.83	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:21:00	3.76	16.86	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:21:15	3.62	15.98	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:21:30	2.44	10.57	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:21:45	1.39	5.63	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:22:00	0.86	2.64	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:22:15	0.59	1.21	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:22:30	0.50	0.28	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/22/2017 19:22:45	0.48	0.04	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
o2zero1	3/22/2017 19:22:45	0.48	0.04	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
co2zero1	3/22/2017 19:22:45	0.48	0.04	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg2	3/22/2017 19:23:00	0.47	-0.05	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 19:23:15	0.46	-0.08	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 19:23:30	0.46	-0.10	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 19:23:45	0.45	-0.11	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 19:24:00	0.46	-0.11	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 19:24:15	0.44	-0.12	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 19:24:30	0.46	-0.13	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 19:24:45	2.11	0.05	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0
scg2	3/22/2017 19:25:00	6.70	2.45	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0	0	0

name	FE O2		FE CO2		A THC					
	1151210012	1151210012	1151210012	1151210012	1106047146					
sn			0	0	0					
offset			0	0	0					
fullscale			100	20	30					
train			1	1	1					
gastype	o2 3a	co2 3a	thc 25a							
scg2	3/22/2017 19:25:15	9.27	6.00	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:25:30	10.14	8.21	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:25:45	10.36	8.87	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:26:00	10.42	9.09	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:26:15	10.44	9.15	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:26:30	10.44	9.18	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:26:45	10.45	9.20	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:27:00	10.45	9.21	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:27:15	10.50	9.20	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:27:30	10.46	9.20	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:27:45	10.45	9.20	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:28:00	10.47	9.21	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:28:15	10.47	9.22	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg2	3/22/2017 19:28:30	10.46	9.23	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
o2span1	3/22/2017 19:28:30	10.46	9.23	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
co2span1	3/22/2017 19:28:30	10.46	9.23	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0 0 0
scg14	3/22/2017 19:29:00	10.46	9.24	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:29:15	10.47	9.24	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:29:30	10.47	9.23	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:29:45	10.47	9.22	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:30:00	10.48	9.23	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:30:15	10.48	9.23	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:30:30	10.56	9.22	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:30:45	12.82	8.70	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:31:00	17.07	5.48	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:31:15	19.44	2.53	-0.1	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:31:30	20.29	0.60	-0.1	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:31:45	20.62	0.13	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:32:00	20.71	-0.04	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:32:15	20.58	-0.13	-0.1	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:32:30	20.66	-0.13	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:32:45	20.76	-0.11	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg14	3/22/2017 19:33:00	20.76	-0.12	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
thczero1	3/22/2017 19:33:00	20.76	-0.12	0.0	CC281749/cg14	NOx	0	CO2	0	THC 0 SO2 0
scg12	3/22/2017 19:33:15	20.77	-0.13	0.0	CC454100/cg12	THC	15.2		0	0 0 0
scg12	3/22/2017 19:33:30	20.81	-0.14	0.0	CC454100/cg12	THC	15.2		0	0 0 0
scg12	3/22/2017 19:33:45	20.77	-0.14	0.0	CC454100/cg12	THC	15.2		0	0 0 0
scg12	3/22/2017 19:34:00	20.78	-0.15	0.9	CC454100/cg12	THC	15.2		0	0 0 0
scg12	3/22/2017 19:34:15	20.78	-0.15	8.7	CC454100/cg12	THC	15.2		0	0 0 0
scg12	3/22/2017 19:34:30	20.78	-0.16	14.6	CC454100/cg12	THC	15.2		0	0 0 0
scg12	3/22/2017 19:34:45	20.79	-0.16	15.2	CC454100/cg12	THC	15.2		0	0 0 0
scg12	3/22/2017 19:35:00	20.79	-0.15	15.3	CC454100/cg12	THC	15.2		0	0 0 0
scg12	3/22/2017 19:35:15	20.97	-0.15	15.3	CC454100/cg12	THC	15.2		0	0 0 0
scg12	3/22/2017 19:35:30	21.15	-0.14	15.3	CC454100/cg12	THC	15.2		0	0 0 0
scg12	3/22/2017 19:35:45	21.20	-0.18	15.3	CC454100/cg12	THC	15.2		0	0 0 0
thcspan1	3/22/2017 19:35:45	21.20	-0.18	15.3	CC454100/cg12	THC	15.2		0	0 0 0
so2zero										
so2span										
noxzero										
noxspan										
co2zero										
co2span										
o2zero										
o2span										
thczero										
thcspan										
cozero										
cospan										
so2zero	Parameter Not Found									
so2mid	Parameter Not Found									
so2high	Parameter Not Found									
noxzero	Parameter Not Found									
noxlow	Parameter Not Found									
noxmid	Parameter Not Found									
noxhigh	Parameter Not Found									
co2zero	Parameter Not Found									
co2mid	Parameter Not Found									
co2high	Parameter Not Found									
o2zero	Parameter Not Found									
o2mid	Parameter Not Found									
o2high	Parameter Not Found									
thczero	Parameter Not Found									
thclow	Parameter Not Found									
thcmid	Parameter Not Found									
thchigh	Parameter Not Found									
coezero	Parameter Not Found									
colow	Parameter Not Found									
comid	Parameter Not Found									
cohigh	Parameter Not Found									
End										

name		FE O2	FE CO2	A THC	
sn		1151210012	1151210012	1106047146	
offset		0	0	0	
fullscale		100	20	30	
train		1	1	1	
gastype		o2 3a	co2 3a	thc 25a	
THC run3	3/23/2017	7:30:30	3.53	17.14	0.0
THC run3	3/23/2017	7:30:45	3.46	17.21	0.0
THC run3	3/23/2017	7:31:00	3.44	17.30	0.0
THC run3	3/23/2017	7:31:15	3.40	17.34	0.0
THC run3	3/23/2017	7:31:30	3.35	17.39	0.0
THC run3	3/23/2017	7:31:45	3.34	17.40	0.0
THC run3	3/23/2017	7:32:00	3.43	17.34	0.0
THC run3	3/23/2017	7:32:15	3.56	17.27	0.0
THC run3	3/23/2017	7:32:30	3.63	17.16	0.0
THC run3	3/23/2017	7:32:45	3.61	17.13	0.0
THC run3	3/23/2017	7:33:00	3.57	17.13	0.0
THC run3	3/23/2017	7:33:15	3.56	17.14	0.0
THC run3	3/23/2017	7:33:30	3.58	17.18	0.0
THC run3	3/23/2017	7:33:45	3.58	17.18	0.0
THC run3	3/23/2017	7:34:00	3.61	17.17	0.0
THC run3	3/23/2017	7:34:15	3.58	17.12	0.0
THC run3	3/23/2017	7:34:30	3.56	17.14	0.0
THC run3	3/23/2017	7:34:45	3.63	17.16	0.0
THC run3	3/23/2017	7:35:00	3.64	17.12	0.0
THC run3	3/23/2017	7:35:15	3.57	17.14	0.0
THC run3	3/23/2017	7:35:30	3.55	17.17	0.0
THC run3	3/23/2017	7:35:45	3.57	17.16	0.0
THC run3	3/23/2017	7:36:00	3.61	17.14	0.0
THC run3	3/23/2017	7:36:15	3.57	17.16	0.0
THC run3	3/23/2017	7:36:30	3.54	17.20	0.0
THC run3	3/23/2017	7:36:45	3.54	17.19	0.0
THC run3	3/23/2017	7:37:00	3.47	17.22	0.0
THC run3	3/23/2017	7:37:15	3.36	17.31	0.0
THC run3	3/23/2017	7:37:30	3.21	17.45	0.0
THC run3	3/23/2017	7:37:45	3.12	17.60	0.0
THC run3	3/23/2017	7:38:00	3.17	17.61	0.0
THC run3	3/23/2017	7:38:15	3.20	17.55	0.0
THC run3	3/23/2017	7:38:30	3.21	17.55	0.0
THC run3	3/23/2017	7:38:45	3.25	17.54	0.0
THC run3	3/23/2017	7:39:00	3.28	17.52	0.0
THC run3	3/23/2017	7:39:15	3.34	17.44	0.0
THC run3	3/23/2017	7:39:30	3.38	17.37	0.0
THC run3	3/23/2017	7:39:45	3.38	17.37	0.0
THC run3	3/23/2017	7:40:00	3.47	17.36	0.0
THC run3	3/23/2017	7:40:15	3.63	17.24	0.0
THC run3	3/23/2017	7:40:30	3.76	17.04	0.0
THC run3	3/23/2017	7:40:45	3.77	16.95	0.0
THC run3	3/23/2017	7:41:00	3.65	17.02	0.0
THC run3	3/23/2017	7:41:15	3.56	17.13	0.0
THC run3	3/23/2017	7:41:30	3.58	17.21	0.0
THC run3	3/23/2017	7:41:45	3.56	17.18	0.0
THC run3	3/23/2017	7:42:00	3.61	17.15	0.0
THC run3	3/23/2017	7:42:15	3.56	17.17	0.0
THC run3	3/23/2017	7:42:30	3.53	17.22	0.0
THC run3	3/23/2017	7:42:45	3.53	17.23	0.0
THC run3	3/23/2017	7:43:00	3.51	17.21	0.0
THC run3	3/23/2017	7:43:15	3.48	17.23	0.0
THC run3	3/23/2017	7:43:30	3.45	17.31	0.0
THC run3	3/23/2017	7:43:45	3.43	17.34	0.0
THC run3	3/23/2017	7:44:00	3.38	17.36	0.0
THC run3	3/23/2017	7:44:15	3.27	17.40	0.0
THC run3	3/23/2017	7:44:30	3.21	17.49	0.0
THC run3	3/23/2017	7:44:45	3.29	17.53	0.0
THC run3	3/23/2017	7:45:00	3.39	17.45	0.0
THC run3	3/23/2017	7:45:15	3.44	17.37	0.0
THC run3	3/23/2017	7:45:30	3.45	17.33	0.0
THC run3	3/23/2017	7:45:45	3.22	17.22	0.0
THC run3	3/23/2017	7:46:00	3.42	17.15	0.0
THC run3	3/23/2017	7:46:15	3.50	17.09	0.0
THC run3	3/23/2017	7:46:30	3.77	17.07	0.0
THC run3	3/23/2017	7:46:45	3.70	17.02	0.0
THC run3	3/23/2017	7:47:00	3.00	16.92	-0.2
THC run3	3/23/2017	7:47:15	2.13	16.85	-0.4
THC run3	3/23/2017	7:47:30	3.56	17.26	0.0
THC run3	3/23/2017	7:47:45	2.15	17.02	-0.4
THC run3	3/23/2017	7:48:00	0.48	16.65	-0.8
THC run3	3/23/2017	7:48:15	3.59	17.15	0.0
THC run3	3/23/2017	7:48:30	3.50	17.22	0.0
THC run3	3/23/2017	7:48:45	3.47	17.28	0.0
THC run3	3/23/2017	7:49:00	3.45	17.32	0.0
THC run3	3/23/2017	7:49:15	3.50	17.32	0.0
THC run3	3/23/2017	7:49:30	3.59	17.20	0.0
THC run3	3/23/2017	7:49:45	3.59	17.15	0.0
THC run3	3/23/2017	7:50:00	3.57	17.19	0.0
THC run3	3/23/2017	7:50:15	3.61	17.21	0.0
THC run3	3/23/2017	7:50:30	3.74	17.10	0.0
THC run3	3/23/2017	7:50:45	3.83	16.96	0.0
THC run3	3/23/2017	7:51:00	3.79	16.92	0.0
THC run3	3/23/2017	7:51:15	3.73	16.99	0.0
THC run3	3/23/2017	7:51:30	3.67	17.08	0.0
THC run3	3/23/2017	7:51:45	3.69	17.07	0.0
THC run3	3/23/2017	7:52:00	3.79	17.00	0.0
THC run3	3/23/2017	7:52:15	3.79	16.96	0.0
THC run3	3/23/2017	7:52:30	3.75	17.00	0.0
THC run3	3/23/2017	7:52:45	3.69	17.05	0.0
THC run3	3/23/2017	7:53:00	3.62	17.07	0.0
THC run3	3/23/2017	7:53:15	3.59	17.12	0.0
THC run3	3/23/2017	7:53:30	3.56	17.18	0.0
THC run3	3/23/2017	7:53:45	3.55	17.22	0.0
THC run3	3/23/2017	7:54:00	3.52	17.24	0.0
THC run3	3/23/2017	7:54:15	3.50	17.24	0.0
THC run3	3/23/2017	7:54:30	3.58	17.21	0.0
THC run3	3/23/2017	7:54:45	3.70	17.14	0.0

name		FE O2	FE CO2	A THC	
sn		1151210012	1151210012	1106047146	
offset		0	0	0	
fullscale		100	20	30	
train		1	1	1	
gastype		o2 3a	co2 3a	thc 25a	
THC run3	3/23/2017	7:55:00	3.75	17.07	0.0
THC run3	3/23/2017	7:55:15	3.76	17.02	0.0
THC run3	3/23/2017	7:55:30	3.69	17.01	0.0
THC run3	3/23/2017	7:55:45	3.66	17.03	0.0
THC run3	3/23/2017	7:56:00	3.63	17.10	0.0
THC run3	3/23/2017	7:56:15	3.65	17.14	0.0
THC run3	3/23/2017	7:56:30	3.75	17.09	0.0
THC run3	3/23/2017	7:56:45	3.60	17.06	0.0
THC run3	3/23/2017	7:57:00	3.49	17.17	0.0
THC run3	3/23/2017	7:57:15	3.39	17.31	0.0
THC run3	3/23/2017	7:57:30	3.23	17.43	0.0
THC run3	3/23/2017	7:57:45	3.23	17.51	0.0
THC run3	3/23/2017	7:58:00	3.26	17.51	0.0
THC run3	3/23/2017	7:58:15	3.36	17.45	0.0
THC run3	3/23/2017	7:58:30	3.51	17.37	0.0
THC run3	3/23/2017	7:58:45	3.41	17.35	0.0
THC run3	3/23/2017	7:59:00	3.32	17.38	0.0
THC run3	3/23/2017	7:59:15	3.38	17.39	0.0
THC run3	3/23/2017	7:59:30	3.47	17.34	0.0
THC run3	3/23/2017	7:59:45	3.49	17.29	0.0
THC run3	3/23/2017	8:00:00	3.43	17.30	0.0
THC run3	3/23/2017	8:00:15	3.33	17.37	0.0
THC run3	3/23/2017	8:00:30	3.36	17.39	0.0
THC run3	3/23/2017	8:00:45	3.39	17.37	0.0
THC run3	3/23/2017	8:01:00	3.38	17.38	0.0
THC run3	3/23/2017	8:01:15	3.39	17.41	0.0
THC run3	3/23/2017	8:01:30	3.46	17.36	0.0
THC run3	3/23/2017	8:01:45	3.51	17.25	0.0
THC run3	3/23/2017	8:02:00	3.52	17.23	0.0
THC run3	3/23/2017	8:02:15	3.47	17.27	0.0
THC run3	3/23/2017	8:02:30	3.39	17.34	0.0
THC run3	3/23/2017	8:02:45	3.33	17.41	0.0
THC run3	3/23/2017	8:03:00	3.37	17.38	0.0
THC run3	3/23/2017	8:03:15	3.45	17.33	0.0
THC run3	3/23/2017	8:03:30	3.47	17.30	0.0
THC run3	3/23/2017	8:03:45	3.51	17.31	0.0
THC run3	3/23/2017	8:04:00	3.54	17.29	0.0
THC run3	3/23/2017	8:04:15	3.64	17.16	0.0
THC run3	3/23/2017	8:04:30	3.70	17.08	0.0
THC run3	3/23/2017	8:04:45	3.57	17.13	0.0
THC run3	3/23/2017	8:05:00	3.54	17.23	0.0
THC run3	3/23/2017	8:05:15	3.61	17.21	0.0
THC run3	3/23/2017	8:05:30	3.62	17.12	0.0
THC run3	3/23/2017	8:05:45	3.51	17.16	0.0
THC run3	3/23/2017	8:06:00	3.40	17.29	0.0
THC run3	3/23/2017	8:06:15	3.38	17.40	0.0
THC run3	3/23/2017	8:06:30	3.32	17.43	0.0
THC run3	3/23/2017	8:06:45	3.30	17.43	0.0
THC run3	3/23/2017	8:07:00	3.41	17.41	0.0
THC run3	3/23/2017	8:07:15	3.61	17.29	0.0
THC run3	3/23/2017	8:07:30	3.74	17.13	0.0
THC run3	3/23/2017	8:07:45	3.82	16.99	0.0
THC run3	3/23/2017	8:08:00	3.84	16.91	0.0
THC run3	3/23/2017	8:08:15	3.72	16.97	0.0
THC run3	3/23/2017	8:08:30	3.65	17.07	0.0
THC run3	3/23/2017	8:08:45	3.69	17.12	0.0
THC run3	3/23/2017	8:09:00	3.84	17.01	0.0
THC run3	3/23/2017	8:09:15	3.93	16.84	0.0
THC run3	3/23/2017	8:09:30	3.96	16.78	0.0
THC run3	3/23/2017	8:09:45	3.96	16.77	0.0
THC run3	3/23/2017	8:10:00	3.95	16.80	0.0
THC run3	3/23/2017	8:10:15	3.94	16.79	0.0
THC run3	3/23/2017	8:10:30	3.94	16.77	0.0
THC run3	3/23/2017	8:10:45	4.05	16.77	0.0
THC run3	3/23/2017	8:11:00	4.02	16.72	0.0
THC run3	3/23/2017	8:11:15	3.95	16.75	0.0
THC run3	3/23/2017	8:11:30	3.87	16.81	0.0
THC run3	3/23/2017	8:11:45	3.83	16.85	0.0
THC run3	3/23/2017	8:12:00	3.80	16.92	0.0
THC run3	3/23/2017	8:12:15	3.76	16.99	0.0
THC run3	3/23/2017	8:12:30	3.71	17.04	0.0
THC run3	3/23/2017	8:12:45	3.66	17.07	0.0
THC run3	3/23/2017	8:13:00	3.68	17.06	0.0
THC run3	3/23/2017	8:13:15	3.70	17.07	0.0
THC run3	3/23/2017	8:13:30	3.65	17.08	0.0
THC run3	3/23/2017	8:13:45	3.56	17.16	0.0
THC run3	3/23/2017	8:14:00	3.45	17.26	0.0
THC run3	3/23/2017	8:14:15	3.44	17.30	0.0
THC run3	3/23/2017	8:14:30	3.58	17.25	0.0
THC run3	3/23/2017	8:14:45	3.68	17.14	0.0
THC run3	3/23/2017	8:15:00	3.71	17.09	0.0
THC run3	3/23/2017	8:15:15	3.74	17.07	0.0
THC run3	3/23/2017	8:15:30	3.71	17.02	0.0
THC run3	3/23/2017	8:15:45	3.74	17.02	0.0
THC run3	3/23/2017	8:16:00	3.80	17.02	0.0
THC run3	3/23/2017	8:16:15	3.82	16.97	0.0
THC run3	3/23/2017	8:16:30	3.73	16.99	0.0
THC run3	3/23/2017	8:16:45	3.64	17.04	0.0
THC run3	3/23/2017	8:17:00	3.62	17.10	0.0
THC run3	3/23/2017	8:17:15	3.54	17.16	0.0
THC run3	3/23/2017	8:17:30	3.41	17.28	0.0
THC run3	3/23/2017	8:17:45	3.34	17.38	0.0
THC run3	3/23/2017	8:18:00	3.27	17.42	0.0
THC run3	3/23/2017	8:18:15	3.26	17.48	0.0
THC run3	3/23/2017	8:18:30	3.35	17.47	0.0
THC run3	3/23/2017	8:18:45	3.32	17.43	0.0
THC run3	3/23/2017	8:19:00	3.30	17.45	0.0
THC run3	3/23/2017	8:19:15	3.32	17.42	0.0

name	FE O2	FE CO2	A THC										
sn	1151210012	1151210012	1106047146										
offset	0	0	0										
fullscale	100	20	30										
train	1	1	1										
gastype	o2 3a	co2 3a	thc 25a										
THC run3	3/23/2017 8:19:30	3.31	17.43	0.0									
THC run3	3/23/2017 8:19:45	3.36	17.44	0.0									
THC run3	3/23/2017 8:20:00	3.35	17.42	0.0									
THC run3	3/23/2017 8:20:15	3.00	17.40	-0.2									
THC run3	3/23/2017 8:20:30	3.34	17.43	0.0									
THC run3	3/23/2017 8:20:45	3.53	17.34	0.0									
THC run3	3/23/2017 8:21:00	3.63	17.20	0.0									
THC run3	3/23/2017 8:21:15	3.60	17.14	0.0									
THC run3	3/23/2017 8:21:30	3.60	17.15	0.0									
THC run3	3/23/2017 8:21:45	3.71	17.09	0.0									
THC run3	3/23/2017 8:22:00	3.75	17.02	0.0									
THC run3	3/23/2017 8:22:15	3.67	17.02	0.0									
THC run3	3/23/2017 8:22:30	3.48	17.16	0.0									
THC run3	3/23/2017 8:22:45	3.34	17.34	0.0									
THC run3	3/23/2017 8:23:00	3.43	17.37	0.0									
THC run3	3/23/2017 8:23:15	3.52	17.28	0.0									
THC run3	3/23/2017 8:23:30	3.46	17.27	0.0									
THC run3	3/23/2017 8:23:45	3.40	17.35	0.0									
THC run3	3/23/2017 8:24:00	3.33	17.39	0.0									
aveTHC run	3/23/2017 7:23:00	3.55	17.16	0.0									
scg2	3/23/2017 8:25:45	3.18	17.59	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:26:00	3.19	17.60	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:26:15	3.25	17.57	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:26:30	3.29	17.51	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:26:45	3.26	17.44	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:27:00	3.24	17.46	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:27:15	3.90	17.35	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:27:30	6.68	15.68	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:27:45	8.92	12.37	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:28:00	9.84	10.44	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:28:15	10.14	9.70	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:28:30	10.20	9.51	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:28:45	10.21	9.45	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:29:00	10.23	9.44	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:29:15	10.23	9.41	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:29:30	10.23	9.39	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:29:45	10.24	9.40	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg2	3/23/2017 8:30:00	10.23	9.40	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
o2span1	3/23/2017 8:30:00	10.23	9.40	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
co2span1	3/23/2017 8:30:00	10.23	9.40	0.0	EB0070863/cg2	O2	10.11	CO2	9.437	0	0		
scg1	3/23/2017 8:30:15	10.24	9.40	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:30:30	10.25	9.39	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:30:45	10.24	9.38	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:31:00	10.26	9.39	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:31:15	10.25	9.39	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:31:30	10.25	9.39	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:31:45	10.26	9.38	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:32:00	9.84	9.28	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:32:15	6.62	8.02	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:32:30	2.82	4.73	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:32:45	1.02	1.83	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:33:00	0.44	0.57	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:33:15	0.28	0.09	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:33:30	0.24	-0.02	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:33:45	0.23	-0.07	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:34:00	0.22	-0.09	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:34:15	0.21	-0.10	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:34:30	0.21	-0.11	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:34:45	0.19	-0.12	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:35:00	0.21	-0.12	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:35:15	0.18	-0.13	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg1	3/23/2017 8:35:30	0.18	-0.13	0.0	CC263051/cg1	SO2	0	NOx	0	CO2	0	O2	0
scg14	3/23/2017 8:35:30	0.19	-0.14	0.0	CC281749/cg14	NOx	0	CO2	0	THC	0	SO2	0
scg14	3/23/2017 8:35:45	0.19	-0.14	0.0	CC281749/cg14	NOx	0	CO2	0	THC	0	SO2	0
thczero1	3/23/2017 8:35:45	0.19	-0.14	0.0	CC281749/cg14	NOx	0	CO2	0	THC	0	SO2	0
scg12	3/23/2017 8:36:00	0.17	-0.14	0.0	CC454100/cg12	THC	15.2	0	0	0	0	0	
scg12	3/23/2017 8:36:15	0.18	-0.15	0.0	CC454100/cg12	THC	15.2	0	0	0	0	0	
scg12	3/23/2017 8:36:30	0.18	-0.15	0.0	CC454100/cg12	THC	15.2	0	0	0	0	0	
scg12	3/23/2017 8:36:45	0.17	-0.15	0.0	CC454100/cg12	THC	15.2	0	0	0	0	0	
scg12	3/23/2017 8:37:00	0.17	-0.16	5.1	CC454100/cg12	THC	15.2	0	0	0	0	0	
scg12	3/23/2017 8:37:15	0.20	-0.14	13.6	CC454100/cg12	THC	15.2	0	0	0	0	0	
scg12	3/23/2017 8:37:30	1.62	0.53	15.3	CC454100/cg12	THC	15.2	0	0	0	0	0	
scg12	3/23/2017 8:37:45	8.14	2.72	15.5	CC454100/cg12	THC	15.2	0	0	0	0	0	
scg12	3/23/2017 8:38:00	15.36	3.31	15.5	CC454100/cg12	THC	15.2	0	0	0	0	0	
scg12	3/23/2017 8:38:15	19.19	1.73	15.5	CC454100/cg12	THC	15.2	0	0	0	0	0	
scg12	3/23/2017 8:38:30	20.45	0.52	15.4	CC454100/cg12	THC	15.2	0	0	0	0	0	
thcspan1	3/23/2017 8:38:30	20.45	0.52	15.4	CC454100/cg12	THC	15.2	0	0	0	0	0	

Appendix E-2: Particulate Matter Test Data

Summaries
Method 5 Isokinetic Field Data Sheets
Method 4 Field Data Sheets
PM Analytical Results

Method 5 RESULTS SUMMARY

	<u>Units</u>	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>	<u>Limit</u>
Date	mm/dd/yy	3/22/2017	3/23/2017	3/23/2017		
Run Start Time	hh:mm	12:35	7:23	12:45		
Run Stop Time	hh:mm	16:56	11:07	16:15		
Meter Calibration Factor		1.012	1.012	1.012		
Meter Calibration Verification		1.006	1.060	1.014		
DH @ 0.75 SCFM		1.944	1.944	1.944		
Pitot Tube Coefficient		0.840	0.840	0.840		
Actual Nozzle Diameter	in	0.257	0.253	0.257		
<u>Stack Test Data</u>						
Initial Meter Volume	ft ³	763.739	899.859	28.180		
Final Meter Volume	ft ³	898.882	1020.070	164.056		
Leak Check Volume	ft ³	0.661	0.719	0.495		
Total Meter Volume	ft ³	134.482	119.492	135.381	129.785	
Standard Meter Volume	dscf	131.776	122.376	136.787	130.313	
Total Sampling Time	min	180.0	180.0	180.0	180.0	
Average Meter Temperature	°F	88.2	63.1	70.6	73.9	
Average Stack Temperature	°F	334.4	331.6	332.3	332.8	
Barometric Pressure	in Hg	29.93	29.86	29.86	29.88	
Stack Static Pressure	in H ₂ O	-0.54	-0.54	-0.54	-0.54	
Absolute Stack Pressure	in Hg	29.89	29.82	29.82	29.84	
Average Orifice Pressure Drop	in H ₂ O	2.01	1.84	2.14	2.00	
Absolute Meter Pressure	in Hg	30.08	30.00	30.02	30.03	
Avg Square Root Pitot Pressure	(in H ₂ O) ^{1/2}	0.94	0.94	0.97	0.95	
<u>Moisture Content Data</u>						
Impinger Water Volume Gain	ml	0.0	39.7	47.5	29.1	
Impinger Water Weight Gain	g	717.5	737.9	932.8	796.1	
Standard Water Vapor Volume	scf	33.830	36.661	46.217	38.903	
Calculated Stack Moisture	%	20.4	23.1	25.3	22.9	
Saturated Stack Moisture	%	100.00	100.0	100.0	100.0	
Reported Stack Moisture Content	%	20.4	23.1	25.3	22.9	
<u>Gas Analysis Data</u>						
Carbon Dioxide Percentage	%	17.3	17.3	17.3	17.3	
Oxygen Percentage	%	3.3	3.3	3.3	3.3	
Carbon Monoxide Percentage	%	0.0	0.0	0.0	0.0	
Nitrogen Percentage	%	79.4	79.4	79.4	79.4	
Dry Gas Molecular Weight	lb/lb-mole	30.90	30.90	30.90	30.90	
Wet Stack Gas Molecular Weight	lb/lb-mole	28.26	27.93	27.64	27.94	
Calculated Fuel Factor		1.017	1.017	1.017	1.017	
Fuel F-Factor	dscf/mmBtu	9240	9240	9240	9240	
Percent Excess Air	%	18.7	18.7	18.7	18.7	
<u>Volumetric Flow Rate Data</u>						
Average Stack Gas Velocity	ft/sec	65.36	65.84	68.34	66.51	
Stack Cross-Sectional Area	ft ²	112.31	112.31	112.31		
Actual Stack Flow Rate	acfm	440452	443672	460519	448214	
Wet Standard Stack Flow Rate	wkscfh	17547	17696	18354	17865	
Dry Standard Stack Flow Rate	dscfm	232703	226948	228640	229430	
Percent of Isokinetic Rate	%	98.1	96.4	103.6	99.4	
<u>Emission Rate Data</u>						
Mass of Particulate on Filter	mg	0.0	0.0	0.0	0.0	
Mass of Particulate in Acetone	mg	4.8	4.8	6.3	5.3	
Mass due to Acetone Blank	mg	0.0	0.0	0.0	0.0	
Total Mass of Particulates	mg	4.8	4.8	6.3	5.3	
Stack Particulate Concentration	mg/dscf	0.000	0.000	0.000	0.000	
	g/dscf	0.000	0.000	0.000	0.000	
	gr/dscf	0.001	0.001	0.001	0.001	
Particulate Emission Rate	kg/hr	0.51	0.53	0.63	0.56	
	lb/hr	1.1	1.2	1.4	1.2	
	lb/mmBtu, O ₂	0.0009	0.0009	0.0011	0.0010	0.0098

TEST RESULTS and DATA ANALYSIS SHEET

Location: <u>GREC Gainesville unit 1</u>		Start Time: <u>8:20:00</u>	RUN No. <u>1</u>
Date: <u>23-Mar-2017</u>		End Time: <u>11:44:00</u>	JOB No. <u>11542</u>
STACK DATA		ORSAT	
% Moisture: <u>22</u> % est.		%CO2: <u>17.30</u> %	
Barometric: <u>29.86</u> in Hg		%O2: <u>3.30</u> %	
Static Press: <u>-0.54</u> in H ₂ O		%N2/CO: <u>79.40</u> %	
Stack Press: <u>29.82</u> in Hg		Md: <u>30.90</u> lb/lb-mole	
Stack Area: <u>112.3</u> ft ²		Actual Mw: <u>27.93</u> lb/lb-mole	
# of Points: <u>12</u> points		Run Time: <u>121.25</u> min	
		EQUIPMENT	
		METER BOX: <u>-</u>	
		Y: <u>0.965</u>	
		ΔH@: <u>1.920</u> in H ₂ O	
		Cp': <u>0.840</u> S/N <u>PT-04</u>	
		Cp: <u>0.840</u> S/N <u>PT-04</u>	
		Nozzle Dia: <u>0.1580</u> inches	
		AVERAGE TEST DATA	
		Average ΔP: <u>1.03</u> in H ₂ O	
		Average T _m : <u>525.2</u> °R	
		Average T _s : <u>791.8</u> °R	
		Average ΔH: <u>0.33</u> in H ₂ O	
		T _{std} : <u>528.00</u> °R	
		P _{std} : <u>29.92</u> in Hg	

Filter Analysis		<PM_{2.5} Recovery Analysis		Moisture Analysis	
Container 1:	<u>120.8</u> mg	Container 4:	<u>4962.8</u> mg	Silica Gel Final:	<u>864.7</u> g
Filter Tare:	<u>120.8</u> mg	Cont. 4 Tare:	<u>4960.7</u> mg	Silica Gel Initial:	<u>852.6</u> g
Acetone V _{aw1} :	<u>0</u> ml	Acetone V _{aw4} :	<u>50</u> ml	M _{sg} :	<u>12.1</u> g
Acetone W _{a1} :	<u>0</u> mg	Acetone W _{a4} :	<u>0</u> mg	V _{wsg(std)} :	<u>0.570</u> scf
(Filter) M ₁ :	<u>0.000</u> mg	(PM _{2.5}) M ₄ :	<u>2.100</u> mg	Total Water Gain:	<u>226.8</u> ml
>PM₁₀ Recovery Analysis		PM_{2.5-10} Recovery Analysis		V _{wc(std)} :	<u>10.675</u> scf
Container 2:	- mg	Container 3:	- mg	V _{ws} :	<u>11.245</u> scf
Cont. 2 Tare:	- mg	Cont. 3 Tare:	- mg	B _{ws} :	<u>0.230</u> H ₂ O
Acetone V _{aw2} :	- ml	Acetone V _{aw3} :	- ml	Actual % H ₂ O:	<u>23.0</u> %
Acetone W _{a2} :	- mg	Acetone W _{a3} :	- mg	Acetone Blank Analysis	
(PM _{2.5}) M ₂ :	- mg	(PM _{10-2.5}) M ₃ :	- mg	Container 7:	<u>0</u> mg
				Container 7 Tare:	<u>0</u> mg
				Acetone Density ρ _a :	<u>0.79</u> mg/ml
				Blank Volume V _{aw} :	<u>200</u> ml
				Blank Conc.C _a :	<u>0</u> mg _r /mg _v

CALCULATIONS AND DATA ANALYSIS

V _m :	<u>38.7760</u> acf - [Actual Sample Volume]	μ:	<u>217.153</u> mpoise - [Actual Gas Viscosity]
V _{ms} :	<u>37.5755</u> dscf - [Corrected Sample Volume (std)]	C:	<u>1.0962</u> [Cunningham Correction Factor]
V _{ws} :	<u>11.2450</u> scf - [Volume of Water Vapor]	D ₅₀ :	<u>10.013</u> μmeter - D50 for Cyclone 1
Q _{Sst} :	<u>0.30990</u> dscfm - [Corrected Dry Sampling Rate (std)]	D _{50IV} :	<u>2.305</u> μmeter - D50 for Cyclone IV
Q _s :	<u>0.60580</u> acfm - [Actual Final Sampling Rate]	Q _{sd(stack)} :	<u>14,637,113.41</u> dscf/hr - [Dry Stack Flow Rate (std)]
I:	<u>104.784</u> % - [Percent Isokinetic Sampling]	Q _{sw(stack)} :	<u>19,017,480.09</u> scf/hr - [Wet Stack Flow Rate (std)]
N _{re} :	<u>2535</u> [Actual Reynolds Number]		
V _{s(avg)} :	<u>70.77</u> fps - [Average Stack Velocity]		
F _c :	<u>1830</u>		
F _d :	<u>9240</u>		

Concentrations
 PM_{2.5}: 0.00086 gr/dscf

Emission Rates
 PM_{2.5}: 1.8034 lb/hr 0.0014 lb/mmbtu, O₂

TEST RESULTS and DATA ANALYSIS SHEET

Location: <u>GREC Gainesville unit 1</u>	Start Time: <u>12:46:00</u>	RUN No. <u>2</u>
Date: <u>23-Mar-2017</u>	End Time: <u>15:30:00</u>	JOB No. <u>11542</u>

STACK DATA	ORSAT	EQUIPMENT	AVERAGE TEST DATA
% Moisture: <u>22</u> % est.	%CO2: <u>17.30</u> %	METER BOX: <u>-</u>	Average ΔP: <u>0.94</u> in H ₂ O
Barometric: <u>29.86</u> in Hg	%O2: <u>3.30</u> %	Y: <u>0.965</u>	Average T _m : <u>529.5</u> °R
Static Press: <u>-0.54</u> in H ₂ O	%N2/CO: <u>79.40</u> %	ΔH@: <u>1.920</u> in H ₂ O	Average T _s : <u>798.0</u> °R
Stack Press: <u>29.82</u> in Hg	Md: <u>30.90</u> lb/lb-mole	Cp': <u>0.840</u> S/N <u>PT-04</u>	Average ΔH: <u>0.33</u> in H ₂ O
Stack Area: <u>112.3</u> ft ²	Actual Mw: <u>27.64</u> lb/lb-mole	Cp: <u>0.840</u> S/N <u>PT-04</u>	T _{std} : <u>528.00</u> °R
# of Points: <u>12</u> points	Run Time: <u>110.50</u> min	Nozzle Dia: <u>0.1580</u> inches	P _{std} : <u>29.92</u> in Hg

Filter Analysis	<PM _{2.5} Recovery Analysis	Moisture Analysis
Container 1: <u>118.9</u> mg	Container 4: <u>4966.7</u> mg	Silica Gel Final: <u>878.7</u> g
Filter Tare: <u>118.9</u> mg	Cont. 4 Tare: <u>4963.9</u> mg	Silica Gel Initial: <u>864.7</u> g
Acetone V _{aw1} : <u>0</u> ml	Acetone V _{aw4} : <u>0</u> ml	M _{sg} : <u>14</u> g
Acetone W _{a1} : <u>0</u> mg	Acetone W _{a4} : <u>0</u> mg	V _{wsg(std)} : <u>0.659</u> scf
(Filter) M ₁ : <u>0.000</u> mg	(PM _{2.5}) M ₄ : <u>2.800</u> mg	Total Water Gain: <u>225.6</u> ml
>PM ₁₀ Recovery Analysis	PM _{2.5-10} Recovery Analysis	V _{wc(std)} : <u>10.619</u> scf
Container 2: <u>-</u> mg	Container 3: <u>-</u> mg	V _{ws} : <u>11.278</u> scf
Cont. 2 Tare: <u>-</u> mg	Cont. 3 Tare: <u>-</u> mg	B _{ws} : <u>0.253</u> H ₂ O
Acetone V _{aw2} : <u>-</u> ml	Acetone V _{aw3} : <u>-</u> ml	Actual % H ₂ O: <u>25.3</u> %
Acetone W _{a2} : <u>-</u> mg	Acetone W _{a3} : <u>-</u> mg	Acetone Blank Analysis
(PM _{2.5}) M ₂ : <u>-</u> mg	(PM _{10-2.5}) M ₃ : <u>-</u> mg	Container 7: <u>0</u> mg
		Container 7 Tare: <u>0</u> mg
		Acetone Density ρ _a : <u>0.79</u> mg/ml
		Blank Volume V _{aw} : <u>200</u> ml
		Blank Conc.C _a : <u>0</u> mg _r /mg _v

CALCULATIONS AND DATA ANALYSIS

V _m : <u>34.6910</u> acf - [Actual Sample Volume]	μ: <u>216.694</u> mpoise - [Actual Gas Viscosity]
V _{ms} : <u>33.3419</u> dscf - [Corrected Sample Volume (std)]	C: <u>1.0972</u> [Cunningham Correction Factor]
V _{ws} : <u>11.2780</u> scf - [Volume of Water Vapor]	D ₅₀ : <u>9.961</u> μmeter - D50 for Cyclone 1
Q _{Sst} : <u>0.30174</u> dscfm - [Corrected Dry Sampling Rate (std)]	D _{50IV} : <u>2.298</u> μmeter - D50 for Cyclone IV
Q _s : <u>0.61233</u> acfm - [Actual Final Sampling Rate]	Q _{sd(stack)} : <u>13,594,140.89</u> dscf/hr - [Dry Stack Flow Rate (std)]
I: <u>109.851</u> % - [Percent Isokinetic Sampling]	Q _{sw(stack)} : <u>18,192,389.38</u> scf/hr - [Wet Stack Flow Rate (std)]
N _{re} : <u>2522</u> [Actual Reynolds Number]	
V _{s(avg)} : <u>68.23</u> fps - [Average Stack Velocity]	
F _c : <u>1830</u>	
F _d : <u>9240</u>	

Concentrations	Emission Rates
PM _{2.5} : <u>0.00130</u> gr/dscf	PM _{2.5} : <u>2.5168</u> lb/hr <u>0.0020</u> lb/mmbtu, O ₂

TEST RESULTS and DATA ANALYSIS SHEET

Location: <u>GREC Gainesville unit 1</u>		Start Time: <u>16:25:00</u>	RUN No. <u>3</u>
Date: <u>23-Mar-2017</u>		End Time: <u>18:47:00</u>	JOB No. <u>11542</u>
STACK DATA		ORSAT	
% Moisture: <u>22</u> % est.		%CO2: <u>17.30</u> %	
Barometric: <u>29.86</u> in Hg		%O2: <u>3.30</u> %	
Static Press: <u>-0.54</u> in H ₂ O		%N2/CO: <u>79.40</u> %	
Stack Press: <u>29.82</u> in Hg		Md: <u>30.90</u> lb/lb-mole	
Stack Area: <u>112.3</u> ft ²		Actual Mw: <u>28.04</u> lb/lb-mole	
# of Points: <u>12</u> points		Run Time: <u>109.50</u> min	
		EQUIPMENT	
		METER BOX: <u>CEMS7MB</u>	
		Y: <u>0.965</u>	
		ΔH@: <u>1.920</u> in H ₂ O	
		Cp': <u>0.840</u> S/N <u>PT-04</u>	
		Cp: <u>0.840</u> S/N <u>PT-04</u>	
		Nozzle Dia: <u>0.1580</u> inches	
		AVERAGE TEST DATA	
		Average ΔP: <u>0.93</u> in H ₂ O	
		Average T _m : <u>528.2</u> °R	
		Average T _s : <u>797.8</u> °R	
		Average ΔH: <u>0.33</u> in H ₂ O	
		T _{std} : <u>528.00</u> °R	
		P _{std} : <u>29.92</u> in Hg	

Filter Analysis		<PM_{2.5} Recovery Analysis		Moisture Analysis	
Container 1:	<u>119.4</u> mg	Container 4:	<u>4940.8</u> mg	Silica Gel Final:	<u>888.3</u> g
Filter Tare:	<u>119.4</u> mg	Cont. 4 Tare:	<u>4936.9</u> mg	Silica Gel Initial:	<u>878.7</u> g
Acetone V _{aw1} :	<u>0</u> ml	Acetone V _{aw4} :	<u>0</u> ml	M _{sg} :	<u>9.6</u> g
Acetone W _{a1} :	<u>0</u> mg	Acetone W _{a4} :	<u>0</u> mg	V _{wsg(std)} :	<u>0.452</u> scf
(Filter) M ₁ :	<u>0.000</u> mg	(PM _{2.5}) M ₄ :	<u>3.900</u> mg	Total Water Gain:	<u>190.7</u> ml
>PM₁₀ Recovery Analysis		PM_{2.5-10} Recovery Analysis		V _{wc(std)} :	<u>8.976</u> scf
Container 2:	- mg	Container 3:	- mg	V _{ws} :	<u>9.428</u> scf
Cont. 2 Tare:	- mg	Cont. 3 Tare:	- mg	B _{ws} :	<u>0.222</u> H ₂ O
Acetone V _{aw2} :	- ml	Acetone V _{aw3} :	- ml	Actual % H ₂ O:	<u>22.2</u> %
Acetone W _{a2} :	- mg	Acetone W _{a3} :	- mg	Acetone Blank Analysis	
(PM _{2.5}) M ₂ :	- mg	(PM _{10-2.5}) M ₃ :	- mg	Container 7:	<u>0</u> mg
				Container 7 Tare:	<u>0</u> mg
				Acetone Density ρ _a :	<u>0.79</u> mg/ml
				Blank Volume V _{aw} :	<u>200</u> ml
				Blank Conc.C _a :	<u>0</u> mg _r /mg _v

CALCULATIONS AND DATA ANALYSIS

V _m :	<u>34.3860</u> acf - [Actual Sample Volume]	μ:	<u>219.288</u> mpoise - [Actual Gas Viscosity]
V _{ms} :	<u>33.1322</u> dscf - [Corrected Sample Volume (std)]	C:	<u>1.0927</u> [Cunningham Correction Factor]
V _{ws} :	<u>9.4281</u> scf - [Volume of Water Vapor]	D ₅₀ :	<u>10.290</u> μmeter - D50 for Cyclone 1
Q _{Sst} :	<u>0.30258</u> dscfm - [Corrected Dry Sampling Rate (std)]	D _{50IV} :	<u>2.419</u> μmeter - D50 for Cyclone IV
Q _s :	<u>0.58928</u> acfm - [Actual Final Sampling Rate]	Q _{sd(stack)} :	<u>13,977,163.65</u> dscf/hr - [Dry Stack Flow Rate (std)]
I:	<u>107.138</u> % - [Percent Isokinetic Sampling]	Q _{sw(stack)} :	<u>17,954,515.82</u> scf/hr - [Wet Stack Flow Rate (std)]
N _{re} :	<u>2434</u> [Actual Reynolds Number]		
V _{s(avg)} :	<u>67.33</u> fps - [Average Stack Velocity]		
F _c :	<u>1830</u>		
F _d :	<u>9240</u>		

Concentrations

PM_{2.5}: 0.00182 gr/dscf

Emission Rates

PM_{2.5}: 3.6272 lb/hr 0.0028 lb/mmbtu, O₂

Method 5/CTM-027 Isokinetic Field Data Sheets

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name <u>Greene</u>	Date <u>3/22/17</u>
Sampling Location <u>STACK</u>	Project # <u>1154</u>
Operators <u>TSC</u>	Run # <u>1</u>
Test Method <u>S</u>	Sampling Type <input checked="" type="checkbox"/> Isokinetic <input type="checkbox"/> Constant Rate

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	330	°F
Avg Gas Meter Temp	(t _m)	75	°F
DH @ 0.75 SCFM	(ΔH@)	1.944	in H ₂ O
Avg Pitot Tube Diff. Pressure	(ΔP _{avg})	1.0	in H ₂ O
Stack Moisture Content	(B _{ws})	22	%
Oxygen	(O ₂)	3	%
Carbon Dioxide	(CO ₂)	17	%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)	2.28	
Pressures			
Barometric Pressure	(P _b)	29.93	in Hg
Stack Static Pressure	(P _{static})	-.54	in H ₂ O
Sampling Equipment Checks			
Pump to Meter Leak	Pre	0/1 N	Post 0/1 N
Orsat Leak	Pre	0/1 N	Post 0/1 N
Nozzle in direction of flow?	<input checked="" type="checkbox"/>		

Sampling Equipment			
Meter #	<u>Cams 5MB</u>		
Meterbox Cal. Factor	(M)	1.012	
Filter / Nozzle #	<u>6250-15/MQ-323</u>		
Actual Nozzle Diameter	(D _{na})	0.257	in
Req. Nozzle Diameter	(D _{ni})	0.248	in
Probe #	<u>P6-02</u>		
Liner Material	<u>Glass</u>		
Pitot #	<u>A2421</u>		
Thermocouple #	<u>TC 6-02</u>		

ΔV _m Vacuum Leak Check					
Pre	.00	ft ³ /min	@	12	in Hg
Post	1.00	ft ³ /min	@	16	in Hg
Pitot Leak Checks					
Pre	.00	inches	@	4.8	in H ₂ O
Post	0.0	inches	@	4.9	in H ₂ O

Traverse Point #	Sampling Time (°)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum
1	0	1235	763.739	1.0	2.28	2.3	330	297	82	323	63	8
2	11.3	1246	791.64	.95	2.16	2.2	334	301	82	331	67	11
3	22.5	1258	780.15	.90	2.05	2.1	333	309	82	324	66	11
4	33.8	1309	788.45	.84	1.92	1.9	327	311	84	318	60	10.5
		1320	796.913									
1	45	1412	797.174	.84	1.92	1.9	331	296	83	336	63	11
2	56.3	1423	805.93	.84	1.92	1.9	334	298	85	341	66	11
3	67.5	1432	815.47	.75	1.458	1.5	335	312	88	341	67	10
4	78.8	1433	822.82	.70	1.596	1.6	335	318	89	340	65	9
			830.984									
1	90	1515	831.82	.90	2.05	2.1	335	318	90	347	66	10
2	101.3	1516	839.64	.84	1.92	1.9	335	320	91	342	64	10
3	112.5	1537	846.92	.93	2.1204	2.1	336	321	91	340	65	10
4	123.8	1549	855.17	.66	1.5048	1.5	335	314	93	341	66	10.9
			864.037									
1	135	1611	864.239	1.0	2.28	2.3	335	316	91	327	66	12
2	146.3	1626	872.76	1.0	2.28	2.3	336	322	91	340	65	12
3	157.3	1637	881.87	1.0	2.28	2.3	336	321	97	324	66	12
4	168.8	1648	890.72	1.0	2.28	2.3	336	323	97	330	67	12
		1700	898.882									

Operator Signature [Signature]

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name <i>GMC</i>	Date <i>3/23/17</i>
Sampling Location <i>STACK</i>	Project # <i>11542</i>
Operators <i>JJC</i>	Run # <i>2</i>
Test Method <i>S</i>	Sampling Type Isokinetic <input checked="" type="checkbox"/> Constant Rate <input type="checkbox"/>

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient (C _p)	0.84		
Avg Stack Temp (t _s)	<i>330</i>	°F	
Avg Gas Meter Temp (t _m)	<i>60</i>	°F	
DH @ 0.75 SCFM (ΔH@)	<i>1.944</i>	in H ₂ O	
Avg Pitot Tube Diff. Pressure (ΔP _{avg})	<i>1.0</i>	in H ₂ O	
Stack Moisture Content (B _{ws})	<i>22</i>	%	
Oxygen (O ₂)	<i>3.0</i>	%	
Carbon Dioxide (CO ₂)	<i>17</i>	%	
Estimated Orifice Flow Rate (Q _m)	<i>0.75</i>	acfm	
K-Factor (K)	<i>2.09</i>		
Pressures			
Barometric Pressure (P _b)	<i>29.86</i>	in Hg	
Stack Static Pressure (P _{static})	<i>-54</i>	in H ₂ O	
Sampling Equipment Checks			
Pump to Meter Leak	Pre <input checked="" type="checkbox"/> / N	Post <input checked="" type="checkbox"/> / N	
Orsat Leak	Pre <input checked="" type="checkbox"/> / N	Post <input checked="" type="checkbox"/> / N	
Nozzle in direction of flow? <input checked="" type="checkbox"/>			

Sampling Equipment		
Meter #	<i>Cems SMR</i>	
Meterbox Cal. Factor (Y)	<i>1.012</i>	
Filter / Nozzle #	<i>G250-11 M10-231</i>	
Actual Nozzle Diameter (D _{na})	<i>0.253</i>	in
Req. Nozzle Diameter (D _{ni})	<i>0.254</i>	in
Probe #	<i>P6-2</i>	
Liner Material	<i>Glass</i>	
Pitot #	<i>A3424</i>	
Thermocouple #	<i>TC6-2</i>	

ΔV _m Vacuum Leak Check				
Pre	<i>.00</i>	ft ³ /min	@	<i>12</i> in Hg
Post	<i>.001</i>	ft ³ /min	@	<i>17</i> in Hg
Pitot Leak Checks				
Pre	<i>.00</i>	inches	@	<i>5.1</i> in H ₂ O
Post	<i>.00</i>	inches	@	<i>4.8</i> in H ₂ O

Traverse Point #	Sampling Time (θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	in Hg
1	0	723	899.858	1.0	2.09	2.1	324	319	316	316	52	7
2	11.3	734	909.04	.84	1.76	1.8	321	319	59	331	54	11
3	22.5	735	916.77	.80	1.67	1.7	331	319	60	325	61	10
4	33.8	747	924.44	.73	1.53	1.5	330	319	67	317	63	9
	45		932.142									
1	45	822	932.384	.94	1.96	2.0	332	322	60	323	57	10
2	56.3	831	940.36	1.0	2.09	2.1	333	320	61	308	58	11
3	67.3	842	947.02	.84	1.76	1.8	332	323	62	307	64	11
4	78.8	855	955.64	.96	2.00	2.0	332	320	62	299	54	10
	90		963.904									
1	90	827	964.144	.84	1.76	1.8	332	303	64	302	49	10
2	10.15	938	972.67	.92	1.96	2.0	332	321	65	316	47	11
3	11.5	949	980.45	.84	1.76	1.8	333	320	66	319	52	11
4	123.5	1001	988.02	.73	1.53	1.5	331	303	68	311	52	10
	135		996.074									
1	135	1027	996.261	.92	1.92	1.9	332	297	69	303	60	11
2	144.5	1033	1003.34	.92	1.92	1.9	332	296	63	301	55	11
3	150.3	1044	1013.33	.94	1.96	2.0	332	297	59	310	59	11
4	166.8	1052	1020.07	.96	1.92	1.9	333	301	71	297	60	10
	180	1027.793										

Operator Signature

TEST DATA SHEET

Location: GREC Gainesville unit 1 Start Time: 8:20:00 RUN No. 1
 Date: 23-Mar-2017 End Time: 11:44:00 JOB No. 11542

STACK DATA		EQUIPMENT		ESTIMATES		+/- 50°F ΔH	
% Moisture:	22 % est.	METER BOX:	CEMS7MB	Ts (°F):	333	Tm (°F):	80
Barometric:	29.86 in Hg	Y:	0.965	Est. Qs:	0.5735 acfm	Ts-50°	283
Static Press:	-0.54 in H ₂ O	ΔH@:	1.920 in H ₂ O	Est. μ _s :	218.31 mpoise	Est. Qs:	0.5980
Stack Press:	29.82 in Hg	Cp':	0.840 S/N PT-04	Est. ΔH:	0.329 (in H ₂ O)	Est. μ _s :	228.14
%CO ₂ :	17.30 %	Cp:	0.840 S/N PT-04	Est. ΔH:	0.375	Est. ΔH:	0.291
%O ₂ :	3.30 %	Nozzle Dia:	0.1580 inches	LEAK CHECKS			
%N ₂ /CO:	79.40 %	Stack Area:	112.3 ft ²	DGM initial	0	0	cf
M _d :	30.90 lb/lb-mole	# of Points:	12 points	DGM final	0	0	cf
Est. ΔP:	1 lb/lb-mole	Run Time:	120.00 min	Time	1	1	min.
T _{std} :	528 °R	P _{std} :	29.92 in Hg	Leak Rate	0.0000	0.0000	cfm
				Vacuum	10	10	in. Hg

Sample Point	Clock Time (min)	Dry Gas Meter Reading (ft ³)	Pitot ΔP (in H ₂ O)	Gas Temperatures (°F)			Orifice Press. ΔH (in H ₂ O)		Pump Vac. (in Hg)	Gas Temps (°F)			Qs (acfm)	D ₅₀ [10 μm]	D ₅₀ [2.5 μm]
				DGM		Stack	Ideal	Actual		Probe	Filter	Imp. Exit			
				Inlet	Outlet										
1	10.00	740.1880	1.000	60.0	60.0	336	0.314	0.330	2	252	n/a	58	0.6020	10.12	2.35
2	21.00	743.3600	1.200	61.0	61.0	338	0.313	0.330	2	243	n/a	58	0.5904	10.28	2.41
3	31.50	746.7800	1.100	62.0	62.0	310	0.337	0.330	2	248	n/a	59	0.5873	10.03	2.29
4	41.50	750.1520	1.000	63.0	63.0	338	0.314	0.330	2	246	n/a	60	0.7298	8.85	1.86
5	53.75	754.0100	1.500	64.0	64.0	338	0.315	0.330	2	220	n/a	61	0.6027	10.13	2.35
6	65.50	757.9200	1.400	65.0	65.0	336	0.317	0.330	2	246	n/a	63	0.5897	10.27	2.41
7	74.25	761.6060	0.780	68.0	68.0	338	0.317	0.330	2	254	n/a	57	0.5962	10.21	2.39
8	83.25	764.3900	0.810	67.0	67.0	337	0.318	0.330	2	251	n/a	56	0.5771	10.44	2.48
9	92.50	767.1600	0.840	68.0	68.0	319	0.333	0.330	2	251	n/a	57	0.5652	10.40	2.45
10	101.75	770.0180	0.860	69.0	69.0	338	0.318	0.330	2	230	n/a	63	0.5807	10.40	2.46
11	111.50	772.8900	0.960	69.0	69.0	339	0.317	0.330	2	244	n/a	63	0.5800	10.42	2.47
12	121.25	775.9100	0.940	70.0	70.0	318	0.335	0.330	2	231	n/a	65	0.5701	10.33	2.42
13	-	778.9640		-			-						-	-	-
14	-			-			-						-	-	-
15	-			-			-						-	-	-
16	-			-			-						-	-	-
17	-			-			-						-	-	-
18	-			-			-						-	-	-
19	-			-			-						-	-	-
20	-			-			-						-	-	-
21	-			-			-						-	-	-
22	-			-			-						-	-	-
23	-			-			-						-	-	-
24	-			-			-						-	-	-

Actual Run Time	V _m	ΔP (avg)	T _m (avg)	T _s (avg)	Max Vac.	ΔH (avg)	V _s (avg)
121.25 min	38.776 cf	1.033 in H ₂ O	525.2 °R	791.8 °R	2	0.330 in H ₂ O	70.600 fps

Test Personnel (signature/date)

Project Leader (signature/date)

TEST DATA SHEET

Location: GREC Gainesville unit 1 Start Time: 12:46:00 RUN No. 2
 Date: 23-Mar-2017 End Time: 15:30:00 JOB No. 11542

STACK DATA		EQUIPMENT		ESTIMATES		+/- 50°F ΔH	
% Moisture:	22 % est.	METER BOX:	CEMS7MB	Ts (°F):	333	Tm (°F):	73
Barometric:	29.86 in Hg	Y:	0.965	Est. Qs:	0.5735 acfm	Ts-50°	283
Static Press:	-0.54 in H ₂ O	ΔH@:	1.920 in H ₂ O	Est. μ _s :	218.31 mpoise	Est. Qs:	0.5980
Stack Press:	29.82 in Hg	Cp':	0.840 S/N PT-04	Est. ΔH:	0.325 ("H ₂ O)	Est. μ _s :	228.14
%CO ₂ :	17.30 %	Cp:	0.840 S/N PT-04	Est. ΔH:	0.370 ("H ₂ O)	Est. ΔH:	0.287
%O ₂ :	3.30 %	Nozzle Dia:	0.1580 inches	LEAK CHECKS			
%N ₂ /CO:	79.40 %	Stack Area:	112.3 ft ²	DGM initial	0	0	cf
M _d :	30.90 lb/lb-mole	# of Points:	12 points	DGM final	0	0	cf
Est. ΔP:	1.1	Run Time:	120.00 min	Time	1	1	min.
T _{std} :	528 °R	P _{std} :	29.92 in Hg	Leak Rate	0.0000	0.0000	cfm
				Vacuum	10	10	in. Hg

Sample Point	Clock Time (min)	Dry Gas Meter Reading (ft ³)	Pitot ΔP ("H ₂ O)	Gas Temperatures (°F)			Orifice Press. ΔH (in H ₂ O)		Pump Vac. (in Hg)	Gas Temps (°F)			Qs (acfm)	D ₅₀ [10 μm]	D ₅₀ [2.5 μm]
				DGM		Stack	Ideal	Actual		Probe	Filter	Imp. Exit			
				Inlet	Outlet										
1	8.50	782.4060	0.810	69.0	69.0	340	0.316	0.330	2	246	n/a	57	0.5766	10.48	2.50
2	17.50	785.0200	0.890	69.0	69.0	339	0.317	0.330	2	249	n/a	55	0.5868	10.34	2.44
3	26.25	787.8400	0.820	69.0	69.0	339	0.317	0.330	2	248	n/a	56	0.5997	10.18	2.37
4	34.50	790.6420	0.770	70.0	70.0	337	0.319	0.330	2	237	n/a	60	0.5668	10.57	2.53
5	43.50	793.1500	0.870	70.0	70.0	338	0.319	0.330	2	251	n/a	57	0.5787	10.43	2.47
6	53.50	795.9400	1.100	70.0	70.0	337	0.319	0.330	2	248	n/a	60	0.5880	10.30	2.42
7	62.75	799.0940	0.940	70.0	70.0	338	0.319	0.330	2	245	n/a	62	0.6006	10.16	2.36
8	72.75	802.0700	1.100	70.0	70.0	338	0.319	0.330	2	256	n/a	59	0.5824	10.38	2.46
9	83.25	805.1900	1.200	70.0	70.0	338	0.319	0.330	2	258	n/a	61	0.5901	10.28	2.42
10	92.00	808.5090	0.840	71.0	71.0	336	0.321	0.330	2	230	n/a	62	0.5865	10.31	2.42
11	101.25	811.2700	0.960	70.0	70.0	340	0.317	0.330	2	246	n/a	63	0.5908	10.30	2.42
12	110.50	814.1900	0.940	70.0	70.0	340	0.317	0.330	2	246	n/a	64	0.5881	10.33	2.44
13	-	817.0970		-			-				n/a		-	-	-
14	-			-			-						-	-	-
15	-			-			-						-	-	-
16	-			-			-						-	-	-
17	-			-			-						-	-	-
18	-			-			-						-	-	-
19	-			-			-						-	-	-
20	-			-			-						-	-	-
21	-			-			-						-	-	-
22	-			-			-						-	-	-
23	-			-			-						-	-	-
24	-			-			-						-	-	-

Actual Run Time	V _m	ΔP (avg)	T _m (avg)	T _s (avg)	Max Vac.	ΔH (avg)	V _s (avg)
110.50 min	34.691 cf	0.937 in H ₂ O	529.5 °R	798.0 °R	2	0.330 in H ₂ O	67.717 fps
			69.8 °F	338.3 °F			

Test Personnel (signature/date)

Project Leader (signature/date)

TEST DATA SHEET

Location: GREC Gainesville unit 1 Start Time: 16:25:00 RUN No. 3
 Date: 23-Mar-2017 End Time: 18:47:00 JOB No. 11542

STACK DATA		EQUIPMENT		ESTIMATES		+/- 50°F ΔH	
% Moisture: <u>22</u> % est.	METER BOX: <u>CEMS7MB</u>	Ts (°F): <u>338</u>	Tm (°F): <u>67</u>	Ts-50°: <u>288</u>	Ts+50°: <u>388</u>		
Barometric: <u>29.86</u> in Hg	Y: <u>0.965</u>	Est. Qs: <u>0.5780</u> acfm		Est. Qs: <u>0.6023</u>	Est. Qs: <u>0.6250</u>		
Static Press: <u>-0.54</u> in H ₂ O	ΔH@: <u>1.920</u> in H ₂ O	Est. μ _s : <u>219.45</u> mpoise		Est. μ _s : <u>206.42</u>	Est. μ _s : <u>229.26</u>		
Stack Press: <u>29.82</u> in Hg	Cp': <u>0.840</u> S/N <u>PT-04</u>	Est. ΔH: <u>0.322</u> (in H ₂ O)		Est. ΔH: <u>0.366</u>	Est. ΔH: <u>0.285</u>		
%CO ₂ : <u>17.30</u> %	Cp: <u>0.840</u> S/N <u>PT-04</u>	LEAK CHECKS					
%O ₂ : <u>3.30</u> %	Nozzle Dia: <u>0.1580</u> inches	DGM initial	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	cf
%N ₂ /CO: <u>79.40</u> %	Stack Area: <u>112.3</u> ft ²	DGM final	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	cf
M _d : <u>30.90</u> lb/lb-mole	# of Points: <u>12</u> points	Time	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	min.
Est. ΔP: <u>1.1</u> in H ₂ O	Run Time: <u>120.00</u> min	Leak Rate	<u>0.0000</u>	<u>0.0000</u>	<u>0.0000</u>	<u>0.0000</u>	cfm
T _{std} : <u>528</u> °R	P _{std} : <u>29.92</u> in Hg	Vacuum	<u>10</u>	<u>10</u>	<u>10</u>	<u>10</u>	in. Hg

Sample Point	Clock Time (min)	Dry Gas Meter Reading (ft ³)	Pitot ΔP (in H ₂ O)	Gas Temperatures (°F)			Orifice Press. ΔH (in H ₂ O)		Pump Vac. (in Hg)	Gas Temps (°F)			Qs (acfm)	D ₅₀ [10 μm]	D ₅₀ [2.5 μm]
				DGM		Stack	Ideal	Actual		Probe	Filter	Imp. Exit			
				Inlet	Outlet										
1	8.75	817.3980	0.840	69.0	69.0	341	0.321	0.330	2	229	n/a	60	0.5926	10.28	2.42
2	18.00	820.1600	0.940	69.0	69.0	340	0.321	0.330	2	247	n/a	53	0.5899	10.31	2.43
3	26.75	823.0700	0.860	69.0	69.0	339	0.322	0.330	2	246	n/a	55	0.5851	10.36	2.45
4	36.00	825.8040	0.940	69.0	69.0	338	0.323	0.330	2	250	n/a	60	0.5916	10.27	2.41
5	46.00	828.7300	1.100	69.0	69.0	338	0.323	0.330	2	252	n/a	57	0.5948	10.23	2.39
6	56.00	831.9100	1.100	69.0	69.0	337	0.324	0.330	2	254	n/a	57	0.5841	10.35	2.44
7	66.00	835.0370	1.100	68.0	68.0	340	0.321	0.330	2	251	n/a	57	0.5961	10.23	2.40
8	75.00	838.2100	0.910	68.0	68.0	339	0.322	0.330	2	249	n/a	57	0.5629	10.65	2.57
9	84.00	840.9100	0.910	68.0	68.0	339	0.322	0.330	2	252	n/a	58	0.6023	10.15	2.36
10	92.00	843.7990	0.710	68.0	68.0	334	0.326	0.330	2	250	n/a	58	0.5829	10.33	2.43
11	101.00	846.3000	0.880	68.0	68.0	336	0.324	0.330	2	248	n/a	58	0.5857	10.32	2.43
12	109.50	849.1200	0.810	68.0	68.0	337	0.323	0.330	2	250	n/a	58	0.5865	10.32	2.43
13	-	851.7840		-	-		-	-					-	-	-
14	-			-	-		-	-					-	-	-
15	-			-	-		-	-					-	-	-
16	-			-	-		-	-					-	-	-
17	-			-	-		-	-					-	-	-
18	-			-	-		-	-					-	-	-
19	-			-	-		-	-					-	-	-
20	-			-	-		-	-					-	-	-
21	-			-	-		-	-					-	-	-
22	-			-	-		-	-					-	-	-
23	-			-	-		-	-					-	-	-
24	-			-	-		-	-					-	-	-

Actual Run Time	V _m	ΔP (avg)	T _m (avg)		T _s (avg)		Max Vac.	ΔH (avg)	V _s (avg)
			528.2 °R	797.8 °R	68.5 °F	338.2 °F			
109.50 min	34.386 cf	0.925 in H ₂ O	68.5 °F	797.8 °R	338.2 °F	797.8 °R	2	0.330 in H ₂ O	67.302 fps

Test Personnel (signature/date)

Project Leader (signature/date)

C.E.M. SOLUTIONS, INC.
METHOD 201A SAMPLE DATA SHEET

Plant Name	6AEC	Date	03/23/17
Sampling Location	Stack	Project #	11542
Test Method	201A	Run #	1
# of Points Across	4	# of Ports Used	4
Operators	MYJ	Technician Signature	<i>[Signature]</i>

Estimate Data			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	330	°F
Avg Gas Meter Temp	(t _m)	65	°F
DH @ 0.75 SCFM	(ΔH@)	1.920	in H ₂ O
Avg Pitot Tube Diff. Pressure	(Δp _{avg})	1.0	in H ₂ O
Stack Moisture Content	(B _{ws})	29.06	%
Oxygen	(O ₂)	3.3	%
Carbon Dioxide	(CO ₂)	17.3	%
Carbon Monoxide	(CO)	0.0	%

Sampling Equipment			
Meter #	CEMS7MB		
Meterbox Cal. Factor	(Y)	1.965	
Nozzle #	1-3 947-99		
Actual Nozzle Diameter	(D _{na})	1.58	in
Req. Nozzle Diameter	(D _{ni})	1.58	in
Probe # / Length	05 5ft		
Liner Material	Glass		

Pressures			
Barometric Pressure	(P _b)	29.86	in Hg
Stack Static Pressure	(P _{static})	-0.54	in H ₂ O

REMOVE FILTER HEAD BEFORE POST LEAK CHECK

ΔV _m		Leak Checks			
Pre	0.000	ft ³ /min	@	10	in Hg
Post	0.005	ft ³ /min	@	10	in Hg
Pitot		Leak Checks			
Pre	0.0	ft ³ /min	@	9.1	in Hg
Post	0.0	ft ³ /min	@	4.2	in Hg

Traverse Point #	Dwell Time (θ)	Elapsed Time	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Impinger Exit Temp <68 °F	Pump Vacuum
	min	hh:mm:ss	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	in Hg
A1	1.0	0	0829	740.88	1.0	.324	.330	336	252	60	58	2
2	1.1	10	0830	743.36	1.2	.313	.33	338	243	61	58	2
3	1.05	21	0841	746.78	1.1	.332	.33	310	248	62	59	2
B1	1.0	31.5	0902	750.15	1.0	.315	.33	328	246	63	60	2
2	12.25	41.5	0940	754.01	1.5	.315	.33	332	220	64	61	2
3	11.75	53.25	0940	757.92	1.4	.317	.33	336	246	65	63	2
C1	8.75	65.50	0953	761.06	.78	.318	.33	338	254	68	57	2
2	9.0	74.25	1002	764.39	.81	.318	.33	338	251	67	56	2
3	9.25	83.25	1011	767.16	.94	.333	.33	319	226	69	57	2
D1	9.25	92.50	1115	770.08	.86	.318	.33	338	230	69	63	2
2	8.75	101.75	1114	772.89	.96	.317	.33	339.4	239	69	63	2
3	9.75	111.50	1124	775.91	.94	.335	.33	318	231	70	65	2
Last		121.25	1144	778.964								

Paused
0959
resumed
1003

Paused
1030
resumed
1115

1144

Method 4 Field Data Sheets

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	GREC			Date	03/22/17		
Sampling Location	Boiler stack			Project #	11542		
Operator	TC			# of Ports Used	4		
Stack Type	Circular			Meter Box Number	CEMS5MB		
Train Leak Check	<input type="checkbox"/>	PreTest	<input type="checkbox"/>	PostTest			

Moisture Content Data								
Run Number	1		Run Start Time		12:35		Run Stop Time	16:56
Total Meter Volume	(V _m)	135.143	dcf	Barometric Press.		(P _b)	29.93	in Hg
Avg Meter Temp	(t _m) _{avg}	88	°F	Stack Static Press.		(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	334	°F	Avg Orifice Press.		(ΔH) _{avg}	2.01	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		g	g	g	g	ml	ml	ml
Contents		DI	DI		Sil Gel			
Initial Value	(V _i),(W _i)	781.5	765.6	626.1	893.3			
Final Value	(V _f),(W _f)	948.0	911.3	963.7	961.0			
Net Value	(V _n),(W _n)	166.5	145.7	337.6	67.7			
Results								
Total Volume	(V _t)	0.00	ml	Water Vol Condensed		(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	717.50	g	Water Vol Weighed		(V _{wsg(std)})	33.830	scf
Std Meter Volume	(V _{m(std)})	131.776	dscf	Sat. Moisture Content		(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws(calc)})	20.4	%	Final Moisture Content		(B _{ws})	20.4	%

Moisture Content Data								
Run Number	2		Run Start Time		7:23		Run Stop Time	11:07
Total Meter Volume	(V _m)	120.211	dcf	Barometric Press.		(P _b)	29.86	in Hg
Avg Meter Temp	(t _m) _{avg}	63	°F	Stack Static Press.		(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	332	°F	Avg Orifice Press.		(ΔH) _{avg}	1.84	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		g	g	g	g	ml	ml	ml
Contents			DI	DI		Sil Gel		
Initial Value	(V _i),(W _i)	752.4	726.6	615.5	594.9	907.9		
Final Value	(V _f),(W _f)	966.8	931.8	929.4	599.3	947.6		
Net Value	(V _n),(W _n)	214.4	205.2	313.9	4.4	39.7		
Results								
Total Volume	(V _t)	39.70	ml	Water Vol Condensed		(V _{wc(std)})	1.869	scf
Total Weight	(W _t)	737.90	g	Water Vol Weighed		(V _{wsg(std)})	34.792	scf
Std Meter Volume	(V _{m(std)})	122.376	dscf	Sat. Moisture Content		(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	23.1	%	Final Moisture Content		(B _{ws})	23.1	%

Moisture Content Data								
Run Number	3		Run Start Time		12:45		Run Stop Time	16:15
Total Meter Volume	(V _m)	135.876	dcf	Barometric Press.		(P _b)	29.86	in Hg
Avg Meter Temp	(t _m) _{avg}	71	°F	Stack Static Press.		(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	332	°F	Avg Orifice Press.		(ΔH) _{avg}	2.14	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		g	g	g	g	ml	ml	ml
Contents			DI	DI		Sil Gel		
Initial Value	(V _i),(W _i)	565.5	723.7	678.9	615.0	945.1		
Final Value	(V _f),(W _f)	1086.0	963.6	746.2	720.1	992.6		
Net Value	(V _n),(W _n)	520.5	239.9	67.3	105.1	47.5		
Results								
Total Volume	(V _t)	47.50	ml	Water Vol Condensed		(V _{wc(std)})	2.236	scf
Total Weight	(W _t)	932.80	g	Water Vol Weighed		(V _{wsg(std)})	43.982	scf
Std Meter Volume	(V _{m(std)})	136.787	dscf	Sat. Moisture Content		(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	25.3	%	Final Moisture Content		(B _{ws})	25.3	%

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	PREC	Date	3/22/12
Sampling Location	STACK	Project #	11542
Operators	TC	Run #	1
Test Method	5	Impinger Bucket #	14

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		H ₂ O	H ₂ O	MT	SG 8-3.3			
Initial Value	(Vi),(Wi)	781.5	765.4	626.1	893.3			
Final Value	(Vf),(Wf)	948.0	911.3	426.4	961.0			
Net Value	(Vn),(Wn)	166.5	145.7	337.6	67.7			

963.7

Train Prepared by: AZ AGUNAS

Train Recovered by: AZ AGUNAS

20.9% BWS

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GPEC	Date	3/23/17
Sampling Location	SACK	Project #	11542
Operators	MB, AL, TC	Run #	2
Test Method	5	Impinger Bucket #	14

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		H ₂ O	H ₂ O	MT	MT	SG		
Initial Value	(Vi),(Wi)	752.4	726.4	615.5	594.9	907.9		
Final Value	(Vf),(Wf)	966.8	931.8	929.4	599.3	947.6		
Net Value	(Vn),(Wn)	214.4	205.2	313.9	4.7	39.7		

Train Prepared by: A. LAGUNAS

Train Recovered by: T. Cowie

23 % Bns

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	<i>Greer</i>	Date	<i>3/23/17</i>
Sampling Location	<i>STACK</i>	Project #	<i>11542</i>
Operators	<i>DC</i>	Run #	<i>3</i>
Test Method	<i>9.5</i>	Impinger Bucket #	<i>14</i>

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		<i>40</i>						
Contents		<i>MT</i>	<i>DI</i>	<i>DI</i>	<i>MT</i>	<i>SG</i>		
Initial Value	(Vi),(Wi)	<i>565.5</i>	<i>723.7</i>	<i>678.9</i>	<i>615.0</i>	<i>945.1</i>		
Final Value	(Vf),(Wf)	<i>408.6</i>	<i>963.6</i>	<i>746.2</i>	<i>720.1</i>	<i>992.6</i>		
Net Value	(Vn),(Wn)	<i>520.5</i>	<i>239.9</i>	<i>67.3</i>	<i>105.1</i>	<i>47.5</i>		

Inlet: 1086.0

Train Prepared by: *[Signature]*

Train Recovered by: *[Signature]*

25.3 % DWS

METHOD 3 - GAS ANALYSIS FOR THE DETERMINATION OF DRY MOLECULAR WEIGHT

Plant Name	GREC			Date	03/22/17		
Sampling Location	Boiler stack			Project #	11542		
Operator	TC			# of Ports Used	4		
Fuel Type	N/A			Minimum Fuel Factor	Maximum Fuel Factor		
Orsat Leak Check	<input type="checkbox"/>	PreTest	<input type="checkbox"/>	PostTest	Orsat Identification		

All Values must be DRY

Gas Analysis Data											
Run Number		1			Run Start Time		12:35		Run Stop Time		16:56
Sample Analysis Time	Carbon Dioxide Volume (V _{CO2})	Oxygen Volume (V _{O2})	Carbon Monoxide Volume (V _{CO})	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)		
hh:mm	ml	ml	ml	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole		
	17.3	20.6		17.3	3.3	0.0	79.4	30.90	0.00		
	17.3	20.6		17.3	3.3	0.0	79.4	30.90	0.00		
	17.3	20.6		17.3	3.3	0.0	79.4	30.90	0.00		
Results			Averages	17.3	3.3	0.0	79.4	30.90			
Average Calculated Fuel Factor			(F _o) _{avg}	1.017	Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>			
Average Excess Air			(%EA) _{avg}	18.7	percent	Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>		

All Values must be DRY

Gas Analysis Data											
Run Number		2			Run Start Time		7:23		Run Stop Time		11:07
Sample Analysis Time	Carbon Dioxide Volume (V _{CO2})	Oxygen Volume (V _{O2})	Carbon Monoxide Volume (V _{CO})	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)		
hh:mm	ml	ml	ml	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole		
	17.3	20.6		17.3	3.3	0.0	79.4	30.90	0.00		
	17.3	20.6		17.3	3.3	0.0	79.4	30.90	0.00		
	17.3	20.6		17.3	3.3	0.0	79.4	30.90	0.00		
Results			Averages	17.3	3.3	0.0	79.4	30.90			
Average Calculated Fuel Factor			(F _o) _{avg}	1.017	Molecular Wt Deviation < 0.3?			<input type="checkbox"/>			
Average Excess Air			(%EA) _{avg}	18.7	percent	Fuel Factor in Handbook Range?			<input type="checkbox"/>		

All Values must be DRY

Gas Analysis Data											
Run Number		3			Run Start Time		12:45		Run Stop Time		16:15
Sample Analysis Time	Carbon Dioxide Volume (V _{CO2})	Oxygen Volume (V _{O2})	Carbon Monoxide Volume (V _{CO})	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)		
hh:mm	ml	ml	ml	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole		
	17.3	20.6		17.3	3.3	0.0	79.4	30.90	0.00		
	17.3	20.6		17.3	3.3	0.0	79.4	30.90	0.00		
	17.3	20.6		17.3	3.3	0.0	79.4	30.90	0.00		
Results			Averages	17.3	3.3	0.0	79.4	30.90			
Average Calculated Fuel Factor			(F _o) _{avg}	1.017	Molecular Wt Deviation < 0.3?			<input type="checkbox"/>			
Average Excess Air			(%EA) _{avg}	18.7	percent	Fuel Factor in Handbook Range?			<input type="checkbox"/>		

Fuel Factor Fo		
Fuel Type	Minimum	Maximum
Coal, Anthracite	1.016	1.130
Coal, Lignite	1.016	1.130
Coal, Bituminous	1.083	1.230
Oil, Distillate	1.260	1.413
Oil, Residual	1.210	1.370
Gas, Natural	1.600	1.836
Gas, Propane	1.434	1.586
Gas, Butane	1.405	1.553
Wood	1.000	1.120
Wood Bark	1.003	1.130

Formulas Used
$\%CO_2 = V_{CO2}$
$\%O_2 = V_{O2} - V_{CO2}$
$\%CO = V_{CO} - V_{O2}$
$\%N_2 = 100 - \%CO_2 - \%O_2 - \%CO$
$M_d = .44(\%CO_2) + .32(\%O_2) + .28(\%N_2 + \%CO)$
$\Delta M_d = M_d - M_{davg}$
$F_o = (20.9 - \%O_2 - .5\%CO) / (\%CO_2 + \%CO)$
$\%EA = (\%O_2 - .5\%CO) / (.264\%NO_2 - (\%O_2 - .5\%CO))$

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	3/23/17
Sampling Location	Stack	Project #	11542
Operators	MIS	Run #	1
Test Method	201A	Impinger Bucket #	2

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		DI	DI	MD	SG			
Initial Value	(Vi),(Wi)	627.1	648.2	635.3	852.6			
Final Value	(Vf),(Wf)	807.4	696.0	634.0	874.7			
Net Value	(Vn),(Wn)	180.3	47.8	-1.3	12.1			

Train Prepared by: C. Horton

Train Recovered by: C. Horton

Imp: 226.8

SG: 12.1

23.0% SO_2

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	3/23/17
Sampling Location	Stack	Project #	11542
Operators	MIS	Run #	2
Test Method	201A	Impinger Bucket #	2

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		DI	DI	MT	SG			
Initial Value	(Vi),(Wi)	807.4	696.0	634.0	864.7			
Final Value	(Vf),(Wf)	983.8	746.0	633.2	878.7			
Net Value	(Vn),(Wn)	176.4	50.0	-0.8	14.0			

Train Prepared by: C. Horton

Train Recovered by: C. Horton / M. Brock

Imp 225.6
SG: 14.0

25.3% BWS

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	3/23/17
Sampling Location	Stack	Project #	1542
Operators	MLB	Run #	3
Test Method	LOIA	Impinger Bucket #	2

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		DI	DI	MT	SG			
Initial Value	(Vi),(Wi)	676.3	674.8	633.2	878.7			
Final Value	(Vf),(Wf)	884.2	676.2	634.6	888.3			
Net Value	(Vn),(Wn)	187.9	1.4	1.4	9.6			

Train Prepared by: 

Train Recovered by: 

BWS 22.2%
190.7

PM Analytical Results

PARTICULATE ANALYTICAL DATA SHEET

Plant Name	GREC	Date	03/22/17
Sampling Location	Boiler stack	Project #	11542
Operator	TC	Acetone Lot Number	-

Analytical Data								
Placed in Desiccator					Run Number			
	Number	Date	Time	Run Start Time	1			
Filter	MQ-323	04/04/17	7:45	Leakage Evident?	<input type="checkbox"/>			
Acetone Wash Beaker	45	04/04/17	14:00	Estimated Volume				
	Filter	Acetone	Date	Time	Humidity	Temp	Cal Audit	
	g	g	mm/dd/yy	hh:mm	%RH	°F	g	
Measurement 1	(m _{1f}),(m _{1a})	0.4074	5.2590	04/06/17	7:50	42	73	5.0000
Measurement 2	(m _{2f}),(m _{2a})	0.4075	5.2590	04/07/17	7:15	31	70	0.5000
Measurement 3	(m _{3f}),(m _{3a})							
Measurement 4	(m _{4f}),(m _{4a})							

Results				Acetone Wash				
Final Weight	(m _{ff}),(m _{fa'})	0.4075	5.2590	g	Bottle Wt with Wash	(m _{bw})	64.1152	g
Tare Weight	(m _{tf}),(m _{ta'})	0.4087	5.2542	g	Additional Rinse Wt	(m _{ar})	4.2792	g
Weight Gain	(m _f),(m _{a'})	-1.3	4.8	mg	Bottle Tare Weight	(m _{tb})	5.2542	g
Blank Adjustment	(W _a)		0.0	mg	Net Wash Weight	(m _{nw})	63.1402	g
Total Particulates	(m _n)		3.6	mg	Blank Concentration	(C _a)	0.0000	mg/g

Analytical Data								
Placed in Desiccator					Run Number			
	Number	Date	Time	Run Start Time	2			
Filter	MQ-281	04/04/17	7:45	Leakage Evident?	<input type="checkbox"/>			
Acetone Wash Beaker	52	04/04/17	14:00	Estimated Volume				
	Filter	Acetone	Date	Time	Humidity	Temp	Cal Audit	
	g	g	mm/dd/yy	hh:mm	%RH	°F	g	
Measurement 1	(m _{1f}),(m _{1a})	0.4099	4.9644	04/06/17	7:50	42	73	5.0000
Measurement 2	(m _{2f}),(m _{2a})	0.4102	4.9646	04/07/17	7:15	31	70	0.5000
Measurement 3	(m _{3f}),(m _{3a})							
Measurement 4	(m _{4f}),(m _{4a})							

Results				Acetone Wash				
Final Weight	(m _{ff}),(m _{fa'})	0.4101	4.9645	g	Bottle Wt with Wash	(m _{bw})	79.2514	g
Tare Weight	(m _{tf}),(m _{ta'})	0.4128	4.9597	g	Additional Rinse Wt	(m _{ar})	7.9136	g
Weight Gain	(m _f),(m _{a'})	-2.7	4.8	mg	Bottle Tare Weight	(m _{tb})	4.9597	g
Blank Adjustment	(W _a)		0.0	mg	Net Wash Weight	(m _{nw})	82.2053	g
Total Particulates	(m _n)		2.1	mg	Blank Concentration	(C _a)	0.0000	mg/g

Analytical Data								
Placed in Desiccator					Run Number			
	Number	Date	Time	Run Start Time	3			
Filter	MQ-282	04/04/17	7:45	Leakage Evident?	<input type="checkbox"/>			
Acetone Wash Beaker	53	04/04/17	14:00	Estimated Volume				
	Filter	Acetone	Date	Time	Humidity	Temp	Cal Audit	
	g	g	mm/dd/yy	hh:mm	%RH	°F	g	
Measurement 1	(m _{1f}),(m _{1a})	0.4132	5.3748	04/06/17	7:50	42	73	5.0000
Measurement 2	(m _{2f}),(m _{2a})	0.4133	5.3748	04/07/17	7:15	31	70	0.5000
Measurement 3	(m _{3f}),(m _{3a})							
Measurement 4	(m _{4f}),(m _{4a})							

Results				Acetone Wash				
Final Weight	(m _{ff}),(m _{fa'})	0.4133	5.3748	g	Bottle Wt with Wash	(m _{bw})	87.3747	g
Tare Weight	(m _{tf}),(m _{ta'})	0.4152	5.3685	g	Additional Rinse Wt	(m _{ar})	5.7167	g
Weight Gain	(m _f),(m _{a'})	-2.0	6.3	mg	Bottle Tare Weight	(m _{tb})	5.3685	g
Blank Adjustment	(W _a)		0.0	mg	Net Wash Weight	(m _{nw})	87.7229	g
Total Particulates	(m _n)		4.3	mg	Blank Concentration	(C _a)	0.0000	mg/g

Formulas Used			
m _{ff} = average of last two filter measurements	m _f = m _{ff} - m _{tf}	W _a = C _a m _{nw}	m _n = m _f + m _{a'} - W _a
m _{fa'} = average of last two acetone measurements	m _{a'} = m _{fa'} - m _{ta'}	m _{nw} = m _{bw} + m _{ar} - m _{tb}	

Appendix E-3: Sulfuric Acid Mist Test Data

Summaries
CTM-13 Field Data Sheets
Analytical Results

Method 8A RESULTS SUMMARY

	<u>Units</u>	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>	<u>Limit</u>
Date	mm/dd/yy	3/24/2017	3/24/2017	3/24/2017		
Run Start Time	hh:mm	8:00	10:22	12:10		
Run Stop Time	hh:mm	9:00	11:22	13:20		
Meter Calibration Factor		1.012	1.012	1.012		
Meter Calibration Verification		1.057	1.041	1.009		
DH @ 0.75 SCFM		1.944	1.944	1.944		
Pitot Tube Coefficient		0.840	0.840	0.840		
<u>Stack Test Data</u>						
Initial Meter Volume	ft ³	169.290	188.177	209.046		
Final Meter Volume	ft ³	186.569	205.980	227.408		
Leak Check Volume	ft ³	0.000	0.000	0.000		
Total Meter Volume	ft ³	17.279	17.803	18.362	17.815	
Standard Meter Volume	dscf	17.948	17.959	18.531	18.146	
Total Sampling Time	min	60.0	60.0	60.0	60.0	
Average Meter Temperature	°F	56.4	71.8	71.5	66.6	
Average Stack Temperature	°F	330.0	330.0	330.0	330.0	
Barometric Pressure	in Hg	30.01	30.01	30.01	30.01	
Stack Static Pressure	in H ₂ O	-0.54	-0.54	-0.54	-0.54	
Absolute Stack Pressure	in Hg	29.97	29.97	29.97	29.97	
Average Orifice Pressure Drop	in H ₂ O	0.35	0.35	0.35	0.35	
Absolute Meter Pressure	in Hg	30.04	30.04	30.04	30.04	
<u>Moisture Content Data</u>						
Impinger Water Volume Gain	ml	0.0	0.0	0.0	0.0	
Impinger Water Weight Gain	g	98.1	94.3	105.6	99.3	
Standard Water Vapor Volume	scf	4.625	4.446	4.979	4.684	
Calculated Stack Moisture	%	20.5	19.8	21.2	20.5	
Saturated Stack Moisture	%	100.00	100.0	100.0	100.0	
Reported Stack Moisture Content	%	20.5	19.8	21.2	20.5	
<u>Gas Analysis Data</u>						
Carbon Dioxide Percentage	%	17.2	17.3	17.4	17.3	
Oxygen Percentage	%	3.4	3.4	3.4	3.4	
Carbon Monoxide Percentage	%	0.0	0.0	0.0	0.0	
Nitrogen Percentage	%	79.4	79.3	79.2	79.3	
Dry Gas Molecular Weight	lb/lb-mole	30.89	30.90	30.92	30.90	
Wet Stack Gas Molecular Weight	lb/lb-mole	28.25	28.34	28.18	28.26	
Calculated Fuel Factor		1.017	1.012	1.006	1.012	
Fuel F-Factor	dscf/mmBtu	9240	9240	9240	9240	
Percent Excess Air	%	19.4	19.4	19.4	19.4	
<u>Volumetric Flow Rate Data</u>						
Average Stack Gas Velocity	ft/sec	65.06	64.86	64.77	64.90	
Stack Cross-Sectional Area	ft ²	112.31	112.31	112.31		
Actual Stack Flow Rate	acfm	438424	437091	436501	437339	
Wet Standard Stack Flow Rate	wkscfh	17611	17557	17534	17567	
Dry Standard Stack Flow Rate	dscfm	233372	234552	230340	232755	
<u>Emission Rate Data</u>						
Mass of Sulfuric Acid from Lab	ug	51.2	60.1	51.8	54.4	
Sulfuric Acid Concentration	ppm	0.02	0.03	0.02	0.03	
Sulfuric Acid Emission Rate	lb/hr	0.1	0.1	0.1	0.1	1.4

CTM-013 Field Data Sheets

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name GREC	Date 3/24/17
Sampling Location STACK	Project # 11542
Operators AL	Run # 1
Test Method SAM SA	Sampling Type <input type="checkbox"/> Isokinetic <input checked="" type="checkbox"/> Constant Rate

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	—	°F
Avg Gas Meter Temp	(t _m)	—	°F
DH @ 0.75 SCFM	(ΔH@)	1944	in H ₂ O
Avg Pitot Tube Diff. Pressure	(ΔP _{avg})	—	in H ₂ O
Stack Moisture Content	(B _{ws})	—	%
Oxygen	(O ₂)	—	%
Carbon Dioxide	(CO ₂)	—	%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)	—	
Pressures			
Barometric Pressure	(P _b)	30.01	in Hg
Stack Static Pressure	(P _{static})	-54	in H ₂ O
Sampling Equipment Checks			
Pump to Meter Leak	Pre	Y/N	Post
Orsat Leak	Pre	Y/N	Post
Nozzle in direction of flow? <input checked="" type="checkbox"/>			

Sampling Equipment			
Meter #	CEM55MB		
Meterbox Cal. Factor	(Y)	1.012	
Filter / Nozzle #	—		
Actual Nozzle Diameter	(D _{na})	—	in
Req. Nozzle Diameter	(D _{ni})	—	in
Probe #	HTP-06		
Liner Material	BS		
Pitot #	—		
Thermocouple #	TC HTP-06		

ΔV _m Vacuum Leak Check				
Pre	0.00	ft ³ /min	@	13 in Hg
Post	0.00	ft ³ /min	@	13 in Hg
Pitot Leak Checks				
Pre	0.00	inches	@	— in H ₂ O
Post	—	inches	@	— in H ₂ O

Traverse Point #	Sampling Time (0)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp <68°F	Pump Vacuum	OVEN
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	in Hg	
8:00	1	0	169.27 → 880			.35		600	55	172	46	11	510
		5	170.73			.35		600	55	158	46	12	510
172.13		10	606			.35		601	56	157	47	12	512
		15	173.64			.35		600	56	153	49	12	520
		20	174.83			.35		603	56	149	47	10	525
		25	176.10			.35		607	56	140	47	7	532
		30	177.65			.35		600	57	159	48	7	534
		35	179.17			.35		600	56	155	49	3	538
		40	180.69			.35		602	57	160	49	3	544
		45	182.28			.35		601	57	158	49	4	548
		50	183.44			.35		599	58	156	50	4	554
		55	185.11			.35		600	58	158	50	5	555
		60	186.59										

Operator Signature

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name GDFEC	Date 3/24/12
Sampling Location STACK	Project # 11541
Operators AL	Run # 2
Test Method SA	Sampling Type <input type="checkbox"/> Isokinetic <input checked="" type="checkbox"/> Constant Rate

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	—	°F
Avg Gas Meter Temp	(t _m)	—	°F
DH @ 0.75 SCFM	(ΔH@)	1.944	in H ₂ O
Avg Pitot Tube Diff. Pressure	(Δp _{avg})	—	in H ₂ O
Stack Moisture Content	(B _{ws})	—	%
Oxygen	(O ₂)	—	%
Carbon Dioxide	(CO ₂)	—	%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)	—	
Pressures			
Barometric Pressure	(P _b)	30.0	in Hg
Stack Static Pressure	(P _{static})	-1.54	in H ₂ O
Sampling Equipment Checks			
Pump to Meter Leak	Pre	Y / N	Post
Orsat Leak	Pre	Y / N	Post
Nozzle in direction of flow?		<input checked="" type="checkbox"/>	

Sampling Equipment			
Meter #	CEISSMB		
Meterbox Cal. Factor	(Y)	1.012	
Filter / Nozzle #	—		
Actual Nozzle Diameter	(D _{na})	—	in
Req. Nozzle Diameter	(D _{ni})	—	in
Probe #	HTP-6		
Liner Material	BS		
Pitot #	—		
Thermocouple #	TCHRP-6		

ΔV _m Vacuum Leak Check				
Pre	000	ft ³ /min	@	13
Post	000	ft ³ /min	@	8
Pitot		Leak Checks		
Pre	—	inches	@	—
Post	—	inches	@	—

Traverse Point #	Sampling Time (θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{ma})	Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum	Over
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	in Hg	
A	0	1022	188.177			.35		69	596	141	61	3	555
	5	1027	189.71			.35		71	603	146	60	3	572
	10	1032	191.17			.35		72	606	141	60	3	582
	15	1037	192.70			.35		73	601	145	60	4	581
	20	1042	194.06			.35		73	603	152	62	4	580
	25	1047	195.57			.35		72	610	155	59	4	579
	30	1052	197.11			.35		72	604	160	57	3	573
	35	1057	198.63			.35		72	608	144	60	4	585
	40	1102	200.07			.35		72	592	140	60	5	577
	45	1107	201.48			.35		72	598	143	59	6	558
	50	1112	203.00			.35		72	598	146	59	6	566
	55	1117	204.51			.35		71	591	147	59	6	577
	60	1122	205.98			.35							

Operator Signature

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name: <u>GPEC</u>	Date: <u>3/24/17</u>
Sampling Location: <u>STACK</u>	Project #: <u>11542</u>
Operators: <u>AL</u>	Run #: <u>3</u>
Test Method: <u>8A</u>	Sampling Type: <input type="checkbox"/> Isokinetic <input checked="" type="checkbox"/> Constant Rate

Pitot Tube Coefficient (C _p)	0.84	
Avg Stack Temp (t _s)	—	°F
Avg Gas Meter Temp (t _m)	—	°F
DH @ 0.75 SCFM (ΔH@)	<u>7.982</u>	in H ₂ O
Avg Pitot Tube Diff. Pressure (ΔP _{avg})	—	in H ₂ O
Stack Moisture Content (B _{ws})	—	%
Oxygen (O ₂)	—	%
Carbon Dioxide (CO ₂)	—	%
Estimated Orifice Flow Rate (Q _m)	0.75	acfm
K-Factor (K)	—	

Meter #	<u>CEM55MB</u>
Meterbox Cal. Factor (Y)	<u>1.012</u>
Filter / Nozzle #	—
Actual Nozzle Diameter (D _{na})	— in
Req. Nozzle Diameter (D _{nl})	— in
Probe #	<u>HTP-6</u>
Liner Material	<u>BS</u>
Pitot #	—
Thermocouple #	<u>TC HTP-6</u>

Barometric Pressure (P _b)	<u>30.01</u>	in Hg
Stack Static Pressure (P _{static})	<u>-0.54</u>	in H ₂ O

Pump to Meter Leak	Pre: <u>Y/N</u>	Post: <u>Y/N</u>
Orsat Leak	Pre: <u>Y/N</u>	Post: <u>Y/N</u>

Nozzle in direction of flow? N/A

Pre	<u>000</u> ft ³ /min	@	<u>8</u> in Hg
Post	<u>0041</u> ft ³ /min	@	<u>15.7</u> in Hg

Pre	— inches	@	— in H ₂ O
Post	— inches	@	— in H ₂ O

P 1237
216.365
R 11247

Traverse Point #	Sampling Time (θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum	
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	in Hg	
1	0	1210	209.046			.35		591	70	140	53	2	580
	5	1215	210.707			.35		594	71	154	58	3	579
	10	1220	212.09			.35		601	71	160	58	3	586
	15	1225	213.64			.35		597	71	160	58	3	585
	20	1230	215.06			.35		598	71	159	58	3	577
	25	1235	216.82			.35		595	72	141	60	11	572
	30	1240	217.68			.35		598	72	142	59	15	567
	35	1245	219.28			.35		603	72	143	55	14	569
	40	1250	220.90			.35		601	72	144	60	13	588
	45	1255	222.31			.35		601	72	145	61	14	590
	50	1300	223.89			.35		594	72	153	63	13	580
	55	1305	225.45			.35		593	72	160	64	14	577
	60	1320	227.40			.35							

OVEN

END TIME
1320

Operator Signature:

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Gainesville			Date	03/24/17		
Sampling Location	Boiler Stack			Project #	11542		
Operator	AL			# of Ports Used	1		
Stack Type	Circular			Meter Box Number	CEMS5MB		
Train Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest			

Moisture Content Data							
Run Number	1	Run Start Time		8:00	Run Stop Time		9:00
Total Meter Volume	(V _m)	17.279	dcf	Barometric Press.	(P _b)	30.01	in Hg
Avg Meter Temp	(t _m) _{avg}	56	°F	Stack Static Press.	(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	330	°F	Avg Orifice Press.	(ΔH) _{avg}	0.35	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6
		g	g	g	g	ml	ml
Contents		DI	DI		Sil Gel		
Initial Value	(V _i),(W _i)	692.50	676.20	634.60	888.30		
Final Value	(V _f),(W _f)	783.90	676.40	634.80	894.60		
Net Value	(V _n),(W _n)	91.4	0.2	0.2	6.3		
Results							
Total Volume	(V _t)	0.00	ml	Water Vol Condensed	(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	98.10	g	Water Vol Weighed	(V _{wsg(std)})	4.625	scf
Std Meter Volume	(V _{m(std)})	17.948	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws(calc)})	20.5	%	Final Moisture Content	(B _{ws})	20.5	%

Moisture Content Data							
Run Number	2	Run Start Time		10:22	Run Stop Time		11:22
Total Meter Volume	(V _m)	17.803	dcf	Barometric Press.	(P _b)	30.01	in Hg
Avg Meter Temp	(t _m) _{avg}	72	°F	Stack Static Press.	(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	330	°F	Avg Orifice Press.	(ΔH) _{avg}	0.35	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6
		g	g	g	g	ml	ml
Contents		DI	DI		Sil Gel		
Initial Value	(V _i),(W _i)	783.90	676.40	634.80	889.90		
Final Value	(V _f),(W _f)	871.30	677.00	634.60	896.40		
Net Value	(V _n),(W _n)	87.4	0.6	-0.2	6.5		
Results							
Total Volume	(V _t)	0.00	ml	Water Vol Condensed	(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	94.30	g	Water Vol Weighed	(V _{wsg(std)})	4.446	scf
Std Meter Volume	(V _{m(std)})	17.959	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	19.8	%	Final Moisture Content	(B _{ws})	19.8	%

Moisture Content Data							
Run Number	3	Run Start Time		12:10	Run Stop Time		13:20
Total Meter Volume	(V _m)	18.362	dcf	Barometric Press.	(P _b)	30.01	in Hg
Avg Meter Temp	(t _m) _{avg}	72	°F	Stack Static Press.	(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	330	°F	Avg Orifice Press.	(ΔH) _{avg}	0.35	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6
		g	g	g	g	ml	ml
Contents		DI	DI		Sil Gel		
Initial Value	(V _i),(W _i)	708.30	677.00	634.60	896.40		
Final Value	(V _f),(W _f)	801.90	678.90	635.20	905.90		
Net Value	(V _n),(W _n)	93.6	1.9	0.6	9.5		
Results							
Total Volume	(V _t)	0.00	ml	Water Vol Condensed	(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	105.60	g	Water Vol Weighed	(V _{wsg(std)})	4.979	scf
Std Meter Volume	(V _{m(std)})	18.531	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	21.2	%	Final Moisture Content	(B _{ws})	21.2	%

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	3/23/17
Sampling Location	Stack	Project #	11542
Operators	MB, AL, JC	Run #	1
Test Method	8A/CTM-013	Impinger Bucket #	2

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		DI	DI	MT	SG			
Initial Value	(Vi),(Wi)	692.5	676.2	634.6	888.3			
Final Value	(Vf),(Wf)	783.9	676.4	634.8	894.6			
Net Value	(Vn),(Wn)	91.4	0.2	0.2	6.3			

Train Prepared by: 

Train Recovered by: 

20.5% B_{ms}

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	03/24/17
Sampling Location	Stack	Project #	11542
Operators	AL	Run #	2
Test Method	SA	Impinger Bucket #	2

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		DI	DI	MT	SG			
Initial Value	(Vi),(Wi)	783.9	676.4	624.8	889.9			
Final Value	(Vf),(Wf)	871.3	708.3	634.6	896.4			
Net Value	(Vn),(Wn)	87.4	0.6	-0.2	6.5			

677.0

Train Prepared by: 

19.8% Dws

Train Recovered by: 

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	03/29/17
Sampling Location	Stack	Project #	11542
Operators	AL	Run #	3
Test Method	8A	Impinger Bucket #	2

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		DF	DF	MT	SG			
Initial Value	(Vi),(Wi)	708.3	677.0	634.6	896.4			
Final Value	(Vf),(Wf)	801.9	678.9	635.2	905.9			
Net Value	(Vn),(Wn)	93.6	1.9	0.6	9.5			

Train Prepared by: 

Train Recovered by: 

21.2% Dws

Appendix E-4: Ammonia Slip Test Data

Summaries
CTM-027 Field Data Sheets
Analytical Results

Method CTM-027 RESULTS SUMMARY

	<u>Units</u>	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>	<u>Limit</u>
Date	mm/dd/yy	3/24/2017	3/24/2017	3/24/2017		
Run Start Time	hh:mm	8:00	10:22	12:10		
Run Stop Time	hh:mm	8:51	11:32	13:19		
Meter Calibration Factor		0.956	0.956	0.956		
Meter Calibration Verification		0.947	0.936	0.934		
DH @ 0.75 SCFM		1.982	1.982	1.982		
Pitot Tube Coefficient		0.840	0.840	0.840		
Actual Nozzle Diameter	in	0.253	0.257	0.253		
<u>Stack Test Data</u>						
Initial Meter Volume	ft ³	599.487	644.729	692.310		
Final Meter Volume	ft ³	643.566	692.027	738.054		
Leak Check Volume	ft ³	0.000	0.000	0.000		
Total Meter Volume	ft ³	44.079	47.298	45.744	45.707	
Standard Meter Volume	dscf	43.181	44.968	43.613	43.921	
Total Sampling Time	min	60.0	60.0	60.0	60.0	
Average Meter Temperature	°F	59.2	75.2	73.5	69.3	
Average Stack Temperature	°F	331.8	332.9	333.2	332.6	
Barometric Pressure	in Hg	30.01	30.01	30.01	30.01	
Stack Static Pressure	in H ₂ O	-0.54	-0.54	-0.54	-0.54	
Absolute Stack Pressure	in Hg	29.97	29.97	29.97	29.97	
Average Orifice Pressure Drop	in H ₂ O	1.86	2.03	1.90	1.93	
Absolute Meter Pressure	in Hg	30.15	30.16	30.15	30.15	
Avg Square Root Pitot Pressure	(in H ₂ O) ^{1/2}	0.94	0.93	0.93	0.93	
<u>Moisture Content Data</u>						
Impinger Water Volume Gain	ml	0.0	0.0	0.0	0.0	
Impinger Water Weight Gain	g	243.9	238.0	248.2	243.4	
Standard Water Vapor Volume	scf	11.500	11.222	11.703	11.475	
Calculated Stack Moisture	%	21.0	20.0	21.2	20.7	
Saturated Stack Moisture	%	100.00	100.0	100.0	100.0	
Reported Stack Moisture Content	%	21.0	20.0	21.2	20.7	
<u>Gas Analysis Data</u>						
Carbon Dioxide Percentage	%	17.2	17.3	17.4	17.3	
Oxygen Percentage	%	3.4	3.4	3.4	3.4	
Carbon Monoxide Percentage	%	0.0	0.0	0.0	0.0	
Nitrogen Percentage	%	79.4	79.3	79.2	79.3	
Dry Gas Molecular Weight	lb/lb-mole	30.89	30.90	30.92	30.90	
Wet Stack Gas Molecular Weight	lb/lb-mole	28.18	28.33	28.19	28.23	
Calculated Fuel Factor		1.017	1.012	1.006	1.012	
Fuel F-Factor	dscf/mmBtu	9240	9240	9240	9240	
Fuel F-Factor	scf/mmBtu					
Percent Excess Air	%	19.4	19.4	19.4	19.4	
<u>Volumetric Flow Rate Data</u>						
Average Stack Gas Velocity	ft/sec	65.06	64.86	64.77	64.90	
Stack Cross-Sectional Area	ft ²	112.31	112.31	112.31		
Actual Stack Flow Rate	acfm	438424	437091	436501	437339	
Wet Standard Stack Flow Rate	wkscfh	17570	17493	17464	17509	
Dry Standard Stack Flow Rate	dscfm	231250	233322	229484	231352	
Percent of Isokinetic Rate	%	100.1	100.1	101.9	100.7	
<u>Emission Rate Data</u>						
Mass of Ammonia from Lab	ug	327	347	354	343	
Ammonia Concentration ^a	ppm	0.4	0.4	0.4	0.4	
Ammonia Conc. corrected to 7% O ₂	ppmvd@7% O ₂	0.3	0.3	0.3	0.3	

10

$$a = (\text{micrograms of ammonia in sample}/17.03)/[(V_{m(\text{std})} * 28.316)/24.056]$$

where:

17.03 = Molecular weight of Ammonia

V_{m(std)} = Volume of gas sampled, standardised to temperature and pressure (68°F, 29.92 in. Hg)

28.316 = Convert dscf to liters

24.056 = gas standard - molar gas volume at STP (68°F, 29.92 in. Hg)

CTM027 Field Data Sheets

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name GREC	Date 3/24/17
Sampling Location STACK	Project # 1542
Operators AL	Run # 1
Test Method GM-027	Sampling Type <input checked="" type="checkbox"/> Isokinetic <input type="checkbox"/> Constant Rate

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	330	°F
Avg Gas Meter Temp	(t _m)	55	°F
DH @ 0.75 SCFM	(ΔH@)	1.982	in H ₂ O
Avg Pitot Tube Diff. Pressure	(ΔP _{avg})	1.0	in H ₂ O
Stack Moisture Content	(B _{ws})	22	%
Oxygen	(O ₂)	3.0	%
Carbon Dioxide	(CO ₂)	17	%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)	2.11	
Pressures			
Barometric Pressure	(P _b)	30.01	in Hg
Stack Static Pressure	(P _{static})	-.54	in H ₂ O
Sampling Equipment Checks			
Pump to Meter Leak	Pre	0/N	Post
Orsat Leak	Pre	Y/N	Post
Nozzle in direction of flow? <input type="checkbox"/>			

Sampling Equipment			
Meter #	CEM 63 MB		
Meterbox Cal. Factor	(Y)	.956	
Filter / Nozzle #	G250-11		
Actual Nozzle Diameter	(D _{na})	.253	in
Req. Nozzle Diameter	(D _{ni})		in
Probe #	GR 265 P5		
Liner Material	GLASS		
Pitot #	AS400		
Thermocouple #	F60 TCS		

ΔV _m Vacuum Leak Check					
Pre	.002	ft ³ /min	@	15	in Hg
Post	.007	ft ³ /min	@	14	in Hg
Pitot Leak Checks					
Pre	.00	inches	@	4.7	in H ₂ O
Post	.00	inches	@	5.3	in H ₂ O

Traverse Point #	Sampling Time (θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	oven Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	in Hg
8:00 N1	0	599.347	800	.90	1.90	1.9	331	252	54	244	53	9
2	5	603.04	805	.91	1.92	1.9	330	252	56	250	53	7
3	10	606.84	810	.91	1.92	1.9	332	251	55	249	53	9
4	15	610.27	815									
W1	15	610.27	820	.90	1.90	1.9	331	249	58	254	56	9
2	20	614.59	825	.88	1.85	1.9	333	238	58	255	59	9
3	25	618.06	830	.93	1.96	2.0	333	234	59	255	59	9
	30	621.90	835									
S1	30	621.90	836	.80	1.68	1.7	328	241	60	257	59	8
2	35	625.55	841	.83	1.75	1.8	327	259	60	258	63	8
3	40	629.18	846	.82	1.90	1.7	330	260	62	257	62	8
	45	632.73	851									
E1	45	632.73	857	.87	1.84	1.8	332	252	62	255	63	8
2	50	636.36	902	.91	1.92	1.9	333	248	63	254	64	8
3	55	640.01	907	.83	1.75	1.8	333	253	63	257	65	8
	60	643.56	912									

Operator Signature

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name GREC	Date 3/24/17
Sampling Location STACK	Project # 11572
Operators AL	Run # 2
Test Method CTM-027	Sampling Type <input checked="" type="checkbox"/> Isokinetic <input type="checkbox"/> Constant Rate

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	330	°F
Avg Gas Meter Temp	(t _m)	70	°F
DH @ 0.75 SCFM	(ΔH@)	1.982	in H ₂ O
Avg Pitot Tube Diff. Pressure	(ΔP _{avg})	1.0	in H ₂ O
Stack Moisture Content	(B _{ws})	22	%
Oxygen	(O ₂)	3.0	%
Carbon Dioxide	(CO ₂)	17	%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)	2.31	
Pressures			
Barometric Pressure	(P _b)	30.0	in Hg
Stack Static Pressure	(P _{static})	-5.4	in H ₂ O
Sampling Equipment Checks			
Pump to Meter Leak	Pre	Y/N	Post
Orsat Leak	Pre	Y/N	Post
Nozzle in direction of flow?		<input checked="" type="checkbox"/>	

Sampling Equipment			
Meter #	CEM 53MB		
Meterbox Cal. Factor	(Y)	.956	
Filter / Nozzle #	G250-13		
Actual Nozzle Diameter	(D _{na})	0.257	in
Req. Nozzle Diameter	(D _{ri})	0.255	in
Probe #	P5-1		
Liner Material	GLASS		
Pitot #	15100		
Thermocouple #	TC 5		

ΔV _m Vacuum Leak Check				
Pre	.901	ft ³ /min	@	14 in Hg
Post	.003	ft ³ /min	@	15 in Hg
Pitot Leak Checks				
Pre	.00	inches	@	4.2 in H ₂ O
Post	0	inches	@	4.2 in H ₂ O

Traverse Point #	Sampling Time (θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	OEU Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum
A1	0	1022	644.729	.50	1.85	1.9	324	259	73	253	58	7
2	5	1027	648.70	.93	2.15	2.2	333	259	75	257	53	8
3	10	1032	652.65	.80	1.85	1.9	323	260	77	255	53	7
	15	1037	656.70									
P1	15	1041	656.70	.78	1.8	1.8	324	260	77	256	59	7
2	20	1046	660.33	.88	2.0	2.0	333	253	77	254	58	7
3	25	1051	664.19	.77	1.75	1.8	333	253	77	255	60	7
	30	1056	667.92									
1	30	1100	671.52	.90	2.1	2.1	330	244	75	258	64	7
2	35	1105	671.77	.95	2.2	2.2	334	256	75	257	61	8
3	40	1110	675.82	.84	1.9	1.9	334	261	75	259	63	8
	45	1115	679.77									
1	45	1117	679.87	.90	2.1	2.1	328	254	73	249	51	8
2	50	1122	683.90	.95	2.2	2.2	334	243	74	246	55	9
3	55	1127	687.7	1.0	2.3	2.3	334	244	74	247	49	9
	100	1132	691.027									

Operator Signature

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name GPEC	Date 3/24/12
Sampling Location STACK	Project # 11542
Operators AL	Run # 3
Test Method GM-027	Sampling Type <input checked="" type="checkbox"/> Isokinetic <input type="checkbox"/> Constant Rate


Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	330	°F
Avg Gas Meter Temp	(t _m)	75	°F
DH @ 0.75 SCFM	(ΔH@)	1.982	in H ₂ O
Avg Pitot Tube Diff. Pressure	(Δp _{avg})	1.0	in H ₂ O
Stack Moisture Content	(B _{ws})	22	%
Oxygen	(O ₂)	3.0	%
Carbon Dioxide	(CO ₂)	17	%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)	2.19	
Pressures			
Barometric Pressure	(P _b)	20.01	in Hg
Stack Static Pressure	(P _{static})	-0.54	in H ₂ O
Sampling Equipment Checks			
Pump to Meter Leak	Pre	Y / N	Post
Orsat Leak	Pre	Y / N	Post
Nozzle in direction of flow? <input type="checkbox"/>			

Sampling Equipment			
Meter #	CEMS 3MB		
Meterbox Cal. Factor	(Y)	0.954	
Filter / Nozzle #	G250-11		
Actual Nozzle Diameter	(D _{na})	253	in
Req. Nozzle Diameter	(D _{nl})		in
Probe #	25		
Liner Material	25		
Pitot #	AS400		
Thermocouple #	TC5		

ΔV _m Vacuum Leak Check				
Pre	.001	ft ³ /min	@	15 in Hg
Post	.002	ft ³ /min	@	15 in Hg
Pitot Leak Checks				
Pre	.00	inches	@	5.5 in H ₂ O
Post	.00	inches	@	4.6 in H ₂ O

794.17

Traverse Point #	Sampling Time (θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	in Hg
1	0	1210	692.310	.85	1.86	1.9	334	248	69	230	45	9
2	5	1215	696.27	.91	1.99	2.0	334	249	71	238	59	10
3	10	1220	700.11	.85	1.86	1.9	334	252	72	258	37	9
	15	1225	703.91									
1	15	1230	703.91	.93	2.0	2.0	330	261	72	258	63	9
2	20	1235	707.90	.94	2.1	2.1	334	260	73	257	62	10
3	25	1240	711.65	.89	1.9	1.9	334	262	75	261	65	10
	30	1245	715.46									
1	30	1247	718.46	.85	1.9	1.7	329	259	74	259	63	9
2	35	1252	719.29	.83	1.8	1.8	334	261	74	259	65	9
3	40	1257	722.98	.83	1.8	1.8	333	259	75	246	60	9
	45	1302	726.69									
1	45	1304	726.69	.75	1.6	1.6	330	260	75	260	58	8
2	50	1309	730.37	.82	1.8	1.8	334	261	76	258	57	9
3	55	1314	734.12	.96	2.1	2.1	333	261	76	247	60	10
	60	1319	738.02									

Operator Signature 

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	GREC			Date	03/24/17		
Sampling Location	Boiler stack			Project #	11542		
Operator	AL			# of Ports Used	4		
Stack Type	Circular			Meter Box Number	CEMS3MB		
Train Leak Check	<input type="checkbox"/>	PreTest	<input type="checkbox"/>	PostTest			

Moisture Content Data							
Run Number	1	Run Start Time		8:00	Run Stop Time		8:51
Total Meter Volume	(V _m)	44.079	dcf	Barometric Press.	(P _b)	30.01	in Hg
Avg Meter Temp	(t _m) _{avg}	59	°F	Stack Static Press.	(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	332	°F	Avg Orifice Press.	(ΔH) _{avg}	1.86	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	ml	ml
Contents	H2SO4	H2SO4		Sil Gel			
Initial Value	(V _i),(W _i)	692.0	678.4	601.5	905.4		
Final Value	(V _f),(W _f)	918.9	680.3	601.9	920.1		
Net Value	(V _n),(W _n)	226.9	1.9	0.4	14.7		

Results							
Total Volume	(V _t)	0.00	ml	Water Vol Condensed	(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	243.90	g	Water Vol Weighed	(V _{wsg(std)})	11.500	scf
Std Meter Volume	(V _{m(std)})	43.181	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws(calc)})	21.0	%	Final Moisture Content	(B _{ws})	21.0	%

Moisture Content Data							
Run Number	2	Run Start Time		10:22	Run Stop Time		11:32
Total Meter Volume	(V _m)	47.298	dcf	Barometric Press.	(P _b)	30.01	in Hg
Avg Meter Temp	(t _m) _{avg}	75	°F	Stack Static Press.	(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	333	°F	Avg Orifice Press.	(ΔH) _{avg}	2.03	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	ml	ml
Contents	H2SO4	H2SO4		Sil Gel			
Initial Value	(V _i),(W _i)	692.5	580.8	612.1	860.7		
Final Value	(V _f),(W _f)	909.6	585.9	612.9	875.7		
Net Value	(V _n),(W _n)	217.1	5.1	0.8	15.0		

Results							
Total Volume	(V _t)	0.00	ml	Water Vol Condensed	(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	238.00	g	Water Vol Weighed	(V _{wsg(std)})	11.222	scf
Std Meter Volume	(V _{m(std)})	44.968	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	20.0	%	Final Moisture Content	(B _{ws})	20.0	%

Moisture Content Data							
Run Number	3	Run Start Time		12:10	Run Stop Time		13:19
Total Meter Volume	(V _m)	45.744	dcf	Barometric Press.	(P _b)	30.01	in Hg
Avg Meter Temp	(t _m) _{avg}	74	°F	Stack Static Press.	(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	333	°F	Avg Orifice Press.	(ΔH) _{avg}	1.90	in H ₂ O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	ml	ml
Contents	H2SO4	H2SO4		Sil Gel			
Initial Value	(V _i),(W _i)	699.5	677.9	601.9	920.1		
Final Value	(V _f),(W _f)	926.4	683.9	604.6	932.7		
Net Value	(V _n),(W _n)	226.9	6.0	2.7	12.6		

Results							
Total Volume	(V _t)	0.00	ml	Water Vol Condensed	(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	248.20	g	Water Vol Weighed	(V _{wsg(std)})	11.703	scf
Std Meter Volume	(V _{m(std)})	43.613	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	21.2	%	Final Moisture Content	(B _{ws})	21.2	%

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GRÉC	Date	3/24/2017
Sampling Location	Baker Stack	Project #	11542
Operators	AL	Run #	1
Test Method	CTM-027	Impinger Bucket #	3

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		100 ml	100 ml	0 ml	—			
Contents		0.1 N H ₂ SO ₄	MT	SG	905.4			
Initial Value	(Vi),(Wi)	692.0	678.4	601.5	884.3	CH		
Final Value	(Vf),(Wf)	918.9	680.3	601.9	920.1			
Net Value	(Vn),(Wn)	226.9	1.9	0.4	14.7			

Train Prepared by: C. HORTON

Train Recovered by: C. HORTON

21.1 % SO₂

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	3/24/17
Sampling Location	Stack	Project #	11542
Operators	MB, AL, TC	Run #	2
Test Method	CTM-027	Impinger Bucket #	21

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		H ₂ SO ₄	H ₂ SO ₄	MT	SG			
Initial Value	(Vi),(Wi)	692.5	580.8	612.1	860.7			
Final Value	(Vf),(Wf)	709.6	585.9	612.9	875.7			
Net Value	(Vn),(Wn)	217.1	5.1	0.8	15.0			

Train Prepared by: 

20.0 g/Bms

Train Recovered by: C. Horton

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	3/24/2017
Sampling Location	Boiler Stack	Project #	11542
Operators	AL	Run #	3
Test Method	CTM-027	Impinger Bucket #	3

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		100 ml	100 ml					
Contents		0.1 N	H ₂ SO ₄	NT	SG			
Initial Value	(Vi),(Wi)	699.5	877.9	601.9	920.1			
Final Value	(Vf),(Wf)	936.4	683.9	604.6	932.7			
Net Value	(Vn),(Wn)	226.9	6.0	207	126			

Train Prepared by: C. HORTON

21.2 % SO₂

Train Recovered by: C. HORTON

Appendix E-5: HCl and HF Test Data

Summaries
Method 26A Field Data Sheets
Analytical Results

Method 5 RESULTS SUMMARY

	<u>Units</u>	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>	<u>Limit</u>
Date	mm/dd/yy	3/22/2017	3/22/2017	3/22/2017		
Run Start Time	hh:mm	14:10	18:23	17:42		
Run Stop Time	hh:mm	15:16	19:23	18:42		
Meter Calibration Factor		0.965	0.965	0.956		
Meter Calibration Verification		0.955	0.966	1.003		
DH @ 0.75 SCFM		1.920	1.920	1.982		
Pitot Tube Coefficient		0.840	0.840	0.840		
<u>Stack Test Data</u>						
Initial Meter Volume	ft ³	645.627	692.913	555.078		
Final Meter Volume	ft ³	692.141	739.048	598.687		
Leak Check Volume	ft ³	0.000	0.000	0.000		
Total Meter Volume	ft ³	46.514	46.135	43.609	45.419	
Standard Meter Volume	dscf	42.827	42.185	41.812	42.275	
Total Sampling Time	min	60.0	60.0	60.0	60.0	
Average Meter Temperature	°F	92.1	95.9	68.0	85.3	
Average Stack Temperature	°F	334.7	337.0	333.3	335.0	
Barometric Pressure	in Hg	29.71	29.71	29.86	29.76	
Stack Static Pressure	in H ₂ O	-0.54	-0.54	-0.54	-0.54	
Absolute Stack Pressure	in Hg	29.67	29.67	29.82	29.72	
Average Orifice Pressure Drop	in H ₂ O	1.90	1.90	2.00	1.93	
Absolute Meter Pressure	in Hg	29.85	29.85	30.01	29.90	
Avg Square Root Pitot Pressure	(in H ₂ O) ^{1/2}		0.90	0.92	0.91	
<u>Moisture Content Data</u>						
Impinger Water Weight Gain	g	242.6	258.6	244.4	248.5	
Standard Water Vapor Volume	scf	11.439	12.193	11.525	11.719	
Calculated Stack Moisture	%	21.1	22.4	21.6	21.7	
Saturated Stack Moisture	%	100.00	100.0	100.0	100.0	
Reported Stack Moisture Content	%	21.1	22.4	21.6	21.7	
<u>Gas Analysis Data</u>						
Carbon Dioxide Percentage	%	17.4	17.3	17.3	17.3	
Oxygen Percentage	%	3.3	3.4	3.3	3.3	
Carbon Monoxide Percentage	%	0.0	0.0	0.0	0.0	
Nitrogen Percentage	%	79.3	79.3	79.4	79.3	
Dry Gas Molecular Weight	lb/lb-mole	30.92	30.90	30.90	30.91	
Wet Stack Gas Molecular Weight	lb/lb-mole	28.19	28.01	28.11	28.11	
Calculated Fuel Factor		1.011	1.012	1.017	1.013	
Fuel F-Factor	dscf/mmBtu	9240	9240	9240	9240	
Percent Excess Air	%	18.7	19.4	18.7	18.9	
<u>Volumetric Flow Rate Data</u>						
Average Stack Gas Velocity	ft/sec	65.36	63.26	64.41	64.34	
Stack Cross-Sectional Area	ft ²	112.31	112.31	112.31		
Actual Stack Flow Rate	acfm	440452	426323	434043	433606	
Wet Standard Stack Flow Rate	wkscfh	17412	16805	17277	17165	
Dry Standard Stack Flow Rate	dscfm	229035	217275	225725	224012	
<u>Emission Rate Data</u>						
Mass of Hydrogen chloride	ug	142	191	156	163	
Mass of Hydrogen chloride	mg	0.14	0.19	0.16	0.2	
Emission Rate	lb/hr	0.10	0.13	0.11	0.11	2.22
Mass of Hydrogen fluoride	ug	66.3	63.2	69.5	66.3	
Mass of Hydrogen fluoride	mg	0.07	0.06	0.07	0.1	
Emission Rate	lb/hr	0.05	0.04	0.05	0.05	2.22
Emission Rate HCl lb/mmbtu		0.00008	0.00011	0.00009	0.00009	0.022
Emission Rate HF lb/mmbtu		0.00004	0.00004	0.00004	0.00004	

Method 26A Field Data Sheets

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name GRFC	Date 3/22/17
Sampling Location STACK	Project # 11542
Operators MB	Run # 1
Test Method 20A	Sampling Type <input checked="" type="checkbox"/> Isokinetic <input type="checkbox"/> Constant Rate <input checked="" type="checkbox"/>

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	—	°F
Avg Gas Meter Temp	(t _m)	—	°F
DH @ 0.75 SCFM	(ΔH@)	1.920	in H ₂ O
Avg Pitot Tube Diff. Pressure	(ΔP _{avg})	—	in H ₂ O
Stack Moisture Content	(B _{ws})	—	%
Oxygen	(O ₂)	—	%
Carbon Dioxide	(CO ₂)	—	%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)	—	
Pressures			
Barometric Pressure	(P _b)	29.71	in Hg
Stack Static Pressure	(P _{static})	—	in H ₂ O
Sampling Equipment Checks			
Pump to Meter Leak	Pre	<input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Post <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N
Orsat Leak	Pre	<input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Post <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N
Nozzle in direction of flow? <input type="checkbox"/>			

Sampling Equipment			
Meter #	CEMS 7MB		
Meterbox Cal. Factor	(Y)	1.920	0.965
Filter / Nozzle #	—		
Actual Nozzle Diameter	(D _{na})	—	in
Req. Nozzle Diameter	(D _{ni})	—	in
Probe #	P6-1		
Liner Material	GLASS		
Pitot #	—		
Thermocouple #	TC6-1		

ΔV _m Vacuum Leak Check				
Pre	0.009	ft ³ /min	@	215
Post	0.000	ft ³ /min	@	10
Pitot Leak Checks				
Pre	—	inches	@	—
Post	—	inches	@	—

Traverse Point #	Sampling Time (⊙)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	in Hg
A	0	1410	645.627	1.9	1.9	336	261	88	255	59	7	
	5	1415	649.49	1.9	1.9	334	260	88	254	59	7	
	10	1420	653.29	1.9	1.9	334	254	89	264	55	8	
	15	1428	657.127	1.9	1.9	334	259	91	254	61	8	
	20	1433	661.05	1.9	1.9	334	258	92	257	62	8	
	23	1438	664.95	1.9	1.9	335	259	92	253	65	8	
	30	1446	668.808	1.9	1.9	334	253	93	254	65	8	
	35	1451	672.80	1.9	1.9	335	258	93	264	63	7	
	40	1456	676.66	1.9	1.9	335	258	94	257	63	7	
	45	1501	680.53	1.9	1.9	335	259	95	262	66	7	
	50	1506	684.21	1.9	1.9	335	258	95	259	65	7	
	55	1511	688.26	1.9	1.9	335	254	95	261	63	7	
	60	1516	692.141	1.9	1.9							

Operator Signature

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name GREC	Date 3/22/17
Sampling Location STACK	Project # 11542
Operators TJC	Run # 2
Test Method MM26	Sampling Type <input type="checkbox"/> Isokinetic <input checked="" type="checkbox"/> Constant Rate

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)		°F
Avg Gas Meter Temp	(t _m)		°F
DH @ 0.75 SCFM	(ΔH@)	1.92	in H ₂ O
Avg Pitot Tube Diff. Pressure	(ΔP _{avg})		in H ₂ O
Stack Moisture Content	(B _{ws})		%
Oxygen	(O ₂)		%
Carbon Dioxide	(CO ₂)		%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)		
Pressures			
Barometric Pressure	(P _b)	29.71	in Hg
Stack Static Pressure	(P _{static})		in H ₂ O
Sampling Equipment Checks			
Pump to Meter Leak	Pre	Y / N	Post
Orsat Leak	Pre	Y / N	Post
Nozzle in direction of flow? <input type="checkbox"/>			

Sampling Equipment			
Meter #	CEMS7M13		
Meterbox Cal. Factor	(Y)	0.965	
Filter / Nozzle #	H-0520 CH 1/4		
Actual Nozzle Diameter	(D _{na})	0.253	in
Req. Nozzle Diameter	(D _{ni})		in
Probe #	P6-1		
Liner Material	Glass		
Pitot #	PR04		
Thermocouple #	TC6-1		

ΔV _m Vacuum Leak Check				
Pre	0.00	ft ³ /min	@	12 in Hg
Post	0.00	ft ³ /min	@	12 in Hg
Pitot Leak Checks				
Pre	0.0	inches	@	5.1 in H ₂ O
Post	0.00	inches	@	5.6 in H ₂ O

248-173

1818
694.531

Traverse Point #	Sampling Time (θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	in Hg
	0	1823	692.913	.82	N/A	1.9	337	253	93	264	66	9
	5	1828	695.21	.76		1.9	337	255	93	262	65	7
	10	1833	699.11	.74		1.9	337	256	93	260	64	6
	15	1838	703.03	.81		1.9	337	257	94	269	67	6
	20	1843	706.93	.80		1.9	337	255	95	266	67	6
	25	1848	710.93	.83		1.9	337	257	95	262	62	6
	30	1853	714.93	.85		1.9	337	256	95	267	61	6
	35	1858	718.94	.87		1.9	337	258	98	259	60	6
	40	1903	722.98	.80		1.9	337	256	98	262	60	6
	45	1908	726.97	.77		1.9	337	258	99	254	59	6
	50	1913	731.00	.75		1.9	337	258	99	258	59	6
	55	1918	735.13	.84		1.9	337	259	99	257	59	6
	60	1923	739.048			1.9					5	

Operator Signature

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name GZEC	Date 3/23/17
Sampling Location STACK	Project # 11542
Operators ATC	Run # 3
Test Method 26A	Sampling Type <input type="checkbox"/> Isokinetic <input checked="" type="checkbox"/> Constant Rate

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	—	°F
Avg Gas Meter Temp	(t _m)	—	°F
DH @ 0.75 SCFM	(ΔH@)	1.982	in H ₂ O
Avg Pitot Tube Diff. Pressure	(ΔP _{avg})	—	in H ₂ O
Stack Moisture Content	(B _{ws})	—	%
Oxygen	(O ₂)	—	%
Carbon Dioxide	(CO ₂)	—	%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)	—	
Pressures			
Barometric Pressure	(P _b)	29.80	in Hg
Stack Static Pressure	(P _{static})	-1.54	in H ₂ O
Sampling Equipment Checks			
Pump to Meter Leak	Pre	0 / N	Post
Orsat Leak	Pre	Y / N	Post
Nozzle in direction of flow? <input checked="" type="checkbox"/>			

Sampling Equipment			
Meter #	CFM53NB		
Meterbox Cal. Factor	(Y)	1.954	
Filter / Nozzle #	—		
Actual Nozzle Diameter	(D _{na})	—	in
Req. Nozzle Diameter	(D _{ni})	—	in
Probe #	P6-2		
Liner Material	GLASS		
Pitot #	PT-04		
Thermocouple #	TC6-2		

ΔV _m Vacuum Leak Check				
Pre	.000	ft ³ /min	@	10 in Hg
Post	0.0	ft ³ /min	@	10 in Hg
Pitot Leak Checks				
Pre	.00	inches	@	5.1 in H ₂ O
Post	0.0	inches	@	6.2 in H ₂ O

Traverse Point #	Sampling Time (θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum
A1	0	1742	555.078	.74		2.0	324	250	66		65	13
	5	1747	557.43	.87		2.0	333	255	66		52	13
	10	1752	561.06	.89		2.0	333	255	67		52	13
	15	1757	564.86	.80		2.0	333	256	68		58	13
	20	1802	568.65	.87		2.0	333	256	68		58	13
	25	1807	572.44	.84		2.0	333	256	69		60	13
	30	1817	576.18	.87		2.0	334	255	68		63	13
	35	1817	579.97	.83		2.0	333	255	68		64	13
	40	1822	583.67	.87		2.0	334	256	69		65	13
	45	1827	587.40	.89		2.0	333	256	69		65	13
	50	1832	591.14	.84		2.0	333	256	69		58	14
	55	1837	594.92	.80		2.0	333	255	69		58	14
60	1842	598.687										

Operator Signature

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	GREC			Date	03/22/17		
Sampling Location	Boiler stack			Project #	11542		
Operator	MB			# of Ports Used	1		
Stack Type	Circular			Meter Box Number	CEMS7MB		
Train Leak Check	<input type="checkbox"/>	PreTest	<input type="checkbox"/>	PostTest			

Moisture Content Data							
Run Number	1	Run Start Time		14:10	Run Stop Time		15:16
Total Meter Volume	(V _m)	46.514	dcf	Barometric Press.	(P _b)	29.71	in Hg
Avg Meter Temp	(t _m) _{avg}	92	°F	Stack Static Press.	(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	335	°F	Avg Orifice Press.	(ΔH) _{avg}	1.90	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6
		g	g	g	g	ml	ml
Contents		h2so4	h2so4		Sil Gel		
Initial Value	(V _i),(W _i)	574.70	686.40	624.50	875.80		
Final Value	(V _f),(W _f)	780.60	700.80	628.60	894.00		
Net Value	(V _n),(W _n)	205.9	14.4	4.1	18.2		
Results							
Total Volume	(V _t)	0.00	ml	Water Vol Condensed	(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	242.60	g	Water Vol Weighed	(V _{wsg(std)})	11.439	scf
Std Meter Volume	(V _{m(std)})	42.827	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws(calc)})	21.1	%	Final Moisture Content	(B _{ws})	21.1	%

Moisture Content Data							
Run Number	2	Run Start Time		18:23	Run Stop Time		19:23
Total Meter Volume	(V _m)	46.135	dcf	Barometric Press.	(P _b)	29.71	in Hg
Avg Meter Temp	(t _m) _{avg}	96	°F	Stack Static Press.	(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	337	°F	Avg Orifice Press.	(ΔH) _{avg}	1.90	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6
		g	g	g	g	ml	ml
Contents		h2so4	h2so4		Sil Gel		
Initial Value	(V _i),(W _i)	683.90	687.60	628.60	894.00		
Final Value	(V _f),(W _f)	899.10	705.60	635.30	912.70		
Net Value	(V _n),(W _n)	215.2	18.0	6.7	18.7		
Results							
Total Volume	(V _t)	0.00	ml	Water Vol Condensed	(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	258.60	g	Water Vol Weighed	(V _{wsg(std)})	12.193	scf
Std Meter Volume	(V _{m(std)})	42.185	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	22.4	%	Final Moisture Content	(B _{ws})	22.4	%

Moisture Content Data							
Run Number	3	Run Start Time		17:42	Run Stop Time		18:42
Total Meter Volume	(V _m)	43.609	dcf	Barometric Press.	(P _b)	29.86	in Hg
Avg Meter Temp	(t _m) _{avg}	68	°F	Stack Static Press.	(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	333	°F	Avg Orifice Press.	(ΔH) _{avg}	2.00	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6
		g	g	g	g	ml	ml
Contents		h2so4	h2so4		Sil Gel		
Initial Value	(V _i),(W _i)	693.80	580.90	608.30	870.90		
Final Value	(V _f),(W _f)	913.50	585.33	612.60	886.90		
Net Value	(V _n),(W _n)	219.7	4.4	4.3	16.0		
Results							
Total Volume	(V _t)	0.00	ml	Water Vol Condensed	(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	244.43	g	Water Vol Weighed	(V _{wsg(std)})	11.525	scf
Std Meter Volume	(V _{m(std)})	41.812	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	21.6	%	Final Moisture Content	(B _{ws})	21.6	%

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	03/22/17
Sampling Location	Stack	Project #	11542
Operators	AL, TC, MB	Run #	1
Test Method	26A	Impinger Bucket #	13

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		H ₂ SO ₄	H ₂ SO ₄	MT	SG			
Initial Value	(Vi),(Wi)	574.7	686.4	624.5	875.8			
Final Value	(Vf),(Wf)	780.6	700.8	628.6	894.0			
Net Value	(Vn),(Wn)	205.9	14.4	4.1	18.2			

Train Prepared by: 

Train Recovered by: 

25.3% Recovery

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GRÉC	Date	3/22/17
Sampling Location	Boiler Stack	Project #	11542
Operators	TC	Run #	2
Test Method	MM26	Impinger Bucket #	2

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		100ml	100ml	-	-			
Contents		0.1NH ₄ SO ₄	0.1NH ₄ SO ₄	MT	SG			
Initial Value	(Vi),(Wi)	683.9	687.6	628.6	894.0			
Final Value	(Vf),(Wf)	699.1	705.6	635.3	912.7			
Net Value	(Vn),(Wn)	215.2	18.0	6.7	18.7			

Train Prepared by: C. HORTON

Train Recovered by: A. LAGUNAS

22.4% BWS

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	3/23/17
Sampling Location	Boiler Stack	Project #	11542
Operators	TC	Run #	3
Test Method	MM26	Impinger Bucket #	21

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		100 ml	100 ml	MT	SG			
Contents		0.1 N H ₂ SO ₄						
Initial Value	(Vi),(Wi)	693.8	580.9	608.3	870.9			
Final Value	(Vf),(Wf)	913.5	585.3	612.6	886.9			
Net Value	(Vn),(Wn)	219.7	4.4	4.3	16.0			

Train Prepared by: C. Horton

Train Recovered by: C. Horton

21.4 % Dubs

Appendix E-7: Mercury Test Data

Summaries
Method 30B Field Data Sheets
Analytical Results

C.E.M. Solutions, Inc.**Mercury Results Summary**

Client: GREC - Gainesville
 Unit: 1
 Job #: 11542

	Units	Not Used 1	3	4	5	Average Run 1-8	Standard
Run Start Date	mm/dd/yyyy	Not Used 3/22/2017	3/24/2017	3/24/2017	3/24/2017		
Start Time	hh:mm:ss	14:10:00	8:00:00	10:22:00	12:10:00		
Run Stop Date	mm/dd/yyyy	3/22/2027	3/24/2017	3/24/2017	3/24/2017		
Stop Time	hh:mm:ss	2:48:00	9:12:00	11:32:00	13:45:00		
Fuel Factor	Fc	9240	9240	9240	9240	9240	
Total Hg Dry	µg/m ³	0.565	0.638	0.515	0.544	0.6	
Total Hg Rate	Lb/mmBtu	3.87E-07	4.39E-07	3.54E-07	3.75E-07	3.89E-07	8.00E-07

C.E.M. Solutions, Inc.**30B Average Emissions Run Summary**

Client: GREC - Gainesville
 Unit: 1
 Job #: 11542
 Run #: 1

Run Start Date: 3/22/2017
 Run Start Time: 14:10
 Run End Date: 3/22/2027
 Run End Time: 2:48

Trap A Data

Actual Spike Amount (m_{spiked})	50.000 ng	
Measured Spike (C_{rec})	0.258 ug/m3	
Spiked Hg Recovery (R)	65%	
Serial Number	OL295477	
Carbon Sec. 1 Recovered (m_{1a})	112.425 ng	
Carbon Sec. 2 Recovered (m_{2a})	0.647 ng	J
Breakthrough % (B_a)	1%	
Total Hg Collected:	0.497 ug/m3	
Dry Standard Liters Sampled (Vs)	126.913 L	
Total Collected Hg (C_a)	0.497 ug/m3	

Trap B Data

Actual Spike Amount (m_{spiked})	0.000 ng	
Measured Spike (C_{rec})	0.000 ug/m3	
Spiked Hg Recovery (R)	0%	
Serial Number	OL299325	
Carbon Sec. 1 Recovered (m_{1b})	79.775 ng	
Carbon Sec. 2 Recovered (m_{2b})	0.338 ng	ND
Breakthrough % (B_b)	0%	
Total Hg Collected:	0.633 ug/m3	
Dry Standard Liters Sampled (Vu)	126.476 L	
Total Collected Hg (C_b)	0.633 ug/m3	

30B Average Emissions

Trap A and B Total Hg Relative Deviation (RD)	12%
Average Total Hg Concentration $\mu\text{g}/\text{m}^3$ Dry (C_d)	0.565 ug/m3

Data Flags:

ND = Catch < MDL	J = Estimate. Catch over
E = Catch above	MDL but under
calibration curve	calibration curve

C.E.M. Solutions, Inc.**30B Average Emissions Run Summary**

Client: GREC - Gainesville
Unit: 1
Job #: 11542
Run #: 3

Run Start Date: 3/24/2017
Run Start Time: 8:00
Run End Date: 3/24/2017
Run End Time: 9:12

Trap A Data

Actual Spike Amount (m_{spiked})	0.000 ng	
Measured Spike (C_{rec})	0.000 ug/m3	
Spiked Hg Recovery (R)	0%	
Serial Number	OL299443	
Carbon Sec. 1 Recovered (m_{1a})	68.100 ng	
Carbon Sec. 2 Recovered (m_{2a})	1.052 ng	J
Breakthrough % (B_a)	2%	
Total Hg Collected:	0.628 ug/m3	
Dry Standard Liters Sampled (Vu)	110.080 L	
Total Collected Hg (C_a)	0.628 ug/m3	

Trap B Data

Actual Spike Amount (m_{spiked})	50.000 ng	
Measured Spike (C_{rec})	0.470 ug/m3	
Spiked Hg Recovery (R)	104%	
Serial Number	OL303250	
Carbon Sec. 1 Recovered (m_{1b})	121.200 ng	
Carbon Sec. 2 Recovered (m_{2b})	0.609 ng	J
Breakthrough % (B_b)	1%	
Total Hg Collected:	0.648 ug/m3	
Dry Standard Liters Sampled (Vs)	110.880 L	
Total Collected Hg (C_b)	0.648 ug/m3	

30B Average Emissions

Trap A and B Total Hg Relative Deviation (RD)	2%
Average Total Hg Concentration $\mu\text{g}/\text{m}^3$ Dry (C_d)	0.638 ug/m3

Data Flags:

ND = Catch < MDL	J = Estimate. Catch over
E = Catch above	MDL but under
calibration curve	calibration curve

C.E.M. Solutions, Inc.**30B Average Emissions Run Summary**

Client: GREC - Gainesville
 Unit: 1
 Job #: 11542
 Run #: 4

Run Start Date: 3/24/2017
 Run Start Time: 10:22
 Run End Date: 3/24/2017
 Run End Time: 11:32

Trap A Data

Actual Spike Amount (m_{spiked})	0.000 ng	
Measured Spike (C_{rec})	0.000 ug/m3	
Spiked Hg Recovery (R)	0%	
Serial Number	OL299334	
Carbon Sec. 1 Recovered (m_{1a})	70.325 ng	
Carbon Sec. 2 Recovered (m_{2a})	0.283 ng	ND
Breakthrough % (B_a)	0%	
Total Hg Collected:	0.541 ug/m3	
Dry Standard Liters Sampled (Vu)	130.416 L	
Total Collected Hg (C_a)	0.541 ug/m3	

Trap B Data

Actual Spike Amount (m_{spiked})	50.000 ng	
Measured Spike (C_{rec})	0.333 ug/m3	
Spiked Hg Recovery (R)	86%	
Serial Number	OL300761	
Carbon Sec. 1 Recovered (m_{1b})	112.750 ng	
Carbon Sec. 2 Recovered (m_{2b})	0.415 ng	ND
Breakthrough % (B_b)	0%	
Total Hg Collected:	0.488 ug/m3	
Dry Standard Liters Sampled (Vs)	129.472 L	
Total Collected Hg (C_b)	0.488 ug/m3	

30B Average Emissions

Trap A and B Total Hg Relative Deviation (RD)	5%
Average Total Hg Concentration $\mu\text{g}/\text{m}^3$ Dry (C_d)	0.515 ug/m3

Data Flags:

ND = Catch < MDL	J = Estimate. Catch over
E = Catch above	MDL but under
calibration curve	calibration curve

C.E.M. Solutions, Inc.**30B Average Emissions Run Summary**

Client: GREC - Gainesville
 Unit: 1
 Job #: 11542
 Run #: 5

Run Start Date: 3/24/2017
 Run Start Time: 12:10
 Run End Date: 3/24/2017
 Run End Time: 13:45

Trap A Data

Actual Spike Amount (m_{spiked})	0.000 ng	
Measured Spike (C_{rec})	0.000 ug/m3	
Spiked Hg Recovery (R)	0%	
Serial Number	OL299321	
Carbon Sec. 1 Recovered (m_{1a})	70.050 ng	
Carbon Sec. 2 Recovered (m_{2a})	0.448 ng	ND
Breakthrough % (B_a)	1%	
Total Hg Collected:	0.556 ug/m3	
Dry Standard Liters Sampled (Vu)	126.816 L	
Total Collected Hg (C_a)	0.556 ug/m3	

Trap B Data

Actual Spike Amount (m_{spiked})	50.000 ng	
Measured Spike (C_{rec})	0.371 ug/m3	
Spiked Hg Recovery (R)	94%	
Serial Number	OL300597	
Carbon Sec. 1 Recovered (m_{1b})	116.800 ng	
Carbon Sec. 2 Recovered (m_{2b})	0.549 ng	J
Breakthrough % (B_b)	0%	
Total Hg Collected:	0.532 ug/m3	
Dry Standard Liters Sampled (Vs)	126.563 L	
Total Collected Hg (C_b)	0.532 ug/m3	

30B Average Emissions

Trap A and B Total Hg Relative Deviation (RD)	2%
Average Total Hg Concentration $\mu\text{g}/\text{m}^3$ Dry (C_d)	0.544 ug/m3

Data Flags:

ND = Catch < MDL	J = Estimate. Catch over
E = Catch above	MDL but under
calibration curve	calibration curve

Method 30B Field Data Sheets

**C.E.M. SOLUTIONS
30B RUN DATA SHEET**

Company	GREC	Date	3/22/2017
Plant	Gainesville	Project #	11542
Sampling Location	Boiler Stack	Run #	1
Operator	MB/TJC	Probe #	P6-30B
Barometric Pressure	29.71	Thermocouple #	TC-P6-30B

Sampling Equipment		Train: A	
Meter #	CEMS30B-01A		
Meterbox Cal. Factor	(Y)	1.002	
Sorbent Tube #	OL295477		
Spiked Concentration	50		ng

Sampling Equipment		Train: B	
Meter #	CEMS30B-01B		
Meterbox Cal. Factor	(Y)	1.001	
Sorbent Tube #	OL299325		
Spiked Concentration	0		ng

ΔV_m		Leak Checks		Train: A	
Pre	0.0	l/min	@	12.0	in/Hg
Post	0.0	l/min	@	23.0	in/Hg

ΔV_m		Leak Checks		Train: B	
Pre	0.0	l/min	@	14.0	in/Hg
Post	0.0	l/min	@	22.0	in/Hg

Traverse Point	Clock Time	Sampling Time	Stack Temp	Trap Temp	Chiller Temp	Train: A				Train: B			
						Dry Gas Meter Reading	Flow Rate	Meter Temp	Pump Vacuum	Dry Gas Meter Reading	Flow Rate	Meter Temp	Pump Vacuum
			°F	°F	°F	liters	l/min	°F	in/Hg	liters	l/min	°F	in/Hg
A1	14:10:00	0	336	330	n/a	0.000	2.0	89	17.0	0.000	2.0	89	15.0
A2	14:15:00	5	334	334	n/a	10.600	2.0	89	17.0	10.400	2.0	89	15.0
A3	14:20:00	10	334	335	n/a	21.400	2.0	89	17.0	20.900	2.0	89	15.0
B1	14:28:00	15	334	335	n/a	32.130	2.0	90	17.0	31.577	2.0	90	15.0
B2	14:33:00	20	334	336	n/a	43.400	2.0	91	17.0	42.600	2.0	91	15.0
B3	14:38:00	25	334	337	n/a	54.100	2.0	92	17.0	53.400	2.0	92	15.0
C1	15:18:00	30	335	235	n/a	64.870	2.0	93	17.0	64.187	2.0	93	15.0
C2	15:23:00	35	335	254	n/a	76.900	2.0	93	17.0	76.300	2.0	93	15.0
C3	15:28:00	40	335	274	n/a	87.900	2.0	93	17.0	87.300	2.0	93	15.0
D1	16:33:00	45	335	216	n/a	98.870	2.0	93	17.0	98.259	2.0	93	15.0
D2	16:38:00	50	335	231	n/a	111.000	2.0	93	17.0	110.700	2.0	93	15.0
D3	16:43:00	55	338	260	n/a	122.500	2.0	93	17.0	122.100	2.0	93	15.0
	16:48:00	60				133.232				132.906			
Averages			334.9	289.8			2.00	91.5			2.00	91.5	
Maximum Value									17.0				15.0
Std. Meter Volume Collected						126.913				126.476			

**C.E.M. SOLUTIONS
30B RUN DATA SHEET**

Company	GREC	Date	3/24/2017
Plant	Gainesville	Project #	11542
Sampling Location	Boiler Stack	Run #	4
Operator	MB/TJC	Probe #	P6-30B
Barometric Pressure	30.01	Thermocouple #	TC-P6-30B

Sampling Equipment		Train: A	
Meter #	CEMS30B-01A		
Meterbox Cal. Factor	(Y)	1.002	
Sorbent Tube #	OL299334		
Spiked Concentration	0		ng

Sampling Equipment		Train: B	
Meter #	CEMS30B-01B		
Meterbox Cal. Factor	(Y)	1.001	
Sorbent Tube #	OL300761		
Spiked Concentration	50		ng

ΔV_m		Leak Checks		Train: A	
Pre	0.0	l/min	@	17.0	in/Hg
Post	0.0	l/min	@	18.0	in/Hg

ΔV_m		Leak Checks		Train: B	
Pre	0.0	l/min	@	17.0	in/Hg
Post	0.0	l/min	@	18.0	in/Hg

Traverse Point	Clock Time	Sampling Time	Stack Temp	Trap Temp	Chiller Temp	Train: A				Train: B			
						Dry Gas Meter Reading	Flow Rate	Meter Temp	Pump Vacuum	Dry Gas Meter Reading	Flow Rate	Meter Temp	Pump Vacuum
			°F	°F	°F	liters	l/min	°F	in/Hg	liters	l/min	°F	in/Hg
A1	10:22:00	0	332	166	n/a	0.000	2.0	70	12.0	0.000	2.0	71	12.0
A2	10:27:00	5	334	190	n/a	10.500	2.0	70	12.0	10.700	2.0	71	12.0
A3	10:32:00	10	333	226	n/a	20.300	2.0	71	16.0	20.700	2.0	71	14.0
B1	10:41:00	15	335	278	n/a	30.867	2.0	72	16.0	31.535	2.0	72	14.0
B2	10:46:00	20	334	291	n/a	42.400	2.0	72	16.0	42.600	2.0	72	14.0
B3	10:51:00	25	334	311	n/a	53.400	2.0	73	17.0	53.600	2.0	73	15.0
C1	11:00:00	30	325	310	n/a	64.319	2.0	74	17.0	64.442	2.0	74	15.0
C2	11:05:00	35	335	321	n/a	75.800	2.0	74	17.0	75.700	2.0	74	15.0
C3	11:10:00	40	335	321	n/a	86.600	2.0	74	17.0	86.400	2.0	74	15.0
D1	11:17:00	45	335	316	n/a	97.493	2.0	74	17.0	97.232	2.0	74	15.0
D2	11:22:00	50	335	317	n/a	109.400	2.0	74	17.0	108.800	2.0	74	15.0
D3	11:27:00	55	335	322	n/a	120.100	2.0	77	17.0	119.500	2.0	77	15.0
	11:32:00	60				130.974				130.196			
Averages			333.5	280.8			2.00	72.9			2.00	73.1	
Maximum Value									17.0				15.0
Std. Meter Volume Collected						130.416				129.472			

**C.E.M. SOLUTIONS
30B RUN DATA SHEET**

Company GREC	Date 3/24/2017
Plant Gainesville	Project # 11542
Sampling Location Boiler Stack	Run # 5
Operator MB/TJC	Probe # P6-30B
Barometric Pressure 30.01	Thermocouple # TC-P6-30B

Sampling Equipment	Train: A
Meter #	CEMS30B-01A
Meterbox Cal. Factor	(Y) 1.002
Sorbent Tube #	OL299321
Spiked Concentration	0 ng

Sampling Equipment	Train: B
Meter #	CEMS30B-01B
Meterbox Cal. Factor	(Y) 1.001
Sorbent Tube #	OL300597
Spiked Concentration	50 ng

ΔV_m	Leak Checks	Train: A
Pre	0.0 l/min	@ 23.0 in/Hg
Post	0.0 l/min	@ 21.0 in/Hg

ΔV_m	Leak Checks	Train: B
Pre	0.0 l/min	@ 23.0 in/Hg
Post	0.0 l/min	@ 21.0 in/Hg

Traverse Point	Clock Time	Sampling Time	Stack Temp	Trap Temp	Chiller Temp	Train: A				Train: B			
						Dry Gas Meter Reading	Flow Rate	Meter Temp	Pump Vacuum	Dry Gas Meter Reading	Flow Rate	Meter Temp	Pump Vacuum
			°F	°F	°F	liters	l/min	°F	in/Hg	liters	l/min	°F	in/Hg
A1	12:10:00	0	334	197	n/a	0.000	2.0	75	17.0	0.000	2.0	75	15.0
A2	12:15:00	5	334	215	n/a	11.900	2.0	76	17.0	11.600	2.0	76	15.0
A3	12:20:00	10	334	239	n/a	22.300	2.0	76	17.0	22.900	2.0	76	15.0
B1	12:30:00	15	334	290	n/a	33.945	2.0	76	17.0	33.116	2.0	76	15.0
B2	12:35:00	20	334	297	n/a	45.500	2.0	77	18.0	44.100	2.0	77	15.0
B3	12:40:00	25	334	313	n/a	46.300	2.0	77	18.0	54.700	2.0	77	15.0
C1	12:50:00	30	334	315	n/a	67.184	2.0	77	18.0	65.336	2.0	77	15.0
C2	12:55:00	35	335	319	n/a	79.300	2.0	77	18.0	77.200	2.0	77	15.0
C3	13:00:00	40	335	321	n/a	90.100	2.0	77	17.0	88.300	2.0	77	15.0
D1	13:30:00	45	335	293	n/a	101.075	2.0	78	14.0	100.577	2.0	78	13.0
D2	13:35:00	50	335	293	n/a	108.700	2.0	78	14.0	110.400	2.0	78	13.0
D3	13:40:00	55	337	293	n/a	118.300	2.0	79	14.0	119.700	2.0	79	13.0
	13:45:00	60				128.314				128.186			
Averages			334.6	282.1			2.00	76.9			2.00	76.9	
Maximum Value									18.0				15.0
Std. Meter Volume Collected						126.816				126.563			

**C.E.M. SOLUTIONS
30B RUN DATA SHEET**

Company	GREC	Date	3/22/17
Plant	GREC	Project #	11542
Sampling Location	Stack	Run #	1
Operator	MB	Probe #	P6-3013
Barometric Pressure	29.71	Thermocouple #	TC6-3013

Sampling Equipment		Train: A	
Meter #	CEMS30B-01A		
Meterbox Cal. Factor	(Y) 1.002		
Sorbent Tube #	OL295477		
Spiked Concentration	50		ng

Sampling Equipment		Train: B	
Meter #	CEMS30B-01B		
Meterbox Cal. Factor	(Y) 1.001		
Sorbent Tube #	OL299325		
Spiked Concentration			ng

ΔV _m		Leak Checks		Train: A	
Pre	0.000	l/min	@	12	in/Hg
Post	0.000	l/min	@	23	in/Hg

ΔV _m		Leak Checks		Train: B	
Pre	0.000	l/min	@	14	in/Hg
Post	0.002	l/min	@	22	in/Hg

Traverse Point	Clock Time	Sampling Time	Stack Temp °F	Trap Temp °F	Chiller Temp °F	Train: A				Train: B			
						Dry Gas Meter Reading liters	Flow Rate l/min	Meter Temp °F	Pump Vacuum in/Hg	Dry Gas Meter Reading liters	Flow Rate l/min	Meter Temp °F	Pump Vacuum in/Hg
A	1	1410	0	336	330	0.000	2.0	89	17	0.000	2.0	89	15
	2	1415	5	334	334	10.6	2.0	89	17	16.4	2.0	89	15
	3	1420	10	334	335	21.4	2.0	89	17	20.9	2.0	89	15
B	1	1428	15	334	335	32.130	2.0	90	17	31.577	2.0	90	15
	2	1433	20	334	336	43.4	2.0	91	17	42.6	2.0	91	15
	3	1438	25	334	337	54.1	2.0	92	17	53.4	2.0	92	15
C	1	1518	30	335	235	64.870	2.0	93	17	64.187	2.0	93	15
	2	1523	35	335	254	76.9	2.0	93	17	76.3	2.0	93	15
	3	1528	40	335	274	87.9	2.0	93	17	87.3	2.0	93	15
D	1	1633	45	335	216	98.870	2.0	93	17	98.259	2.0	93	15
	2	1638	50	335	231	111.0	2.0	93	17	110.7	2.0	93	15
	3	1643	55	335	260	122.5	2.0	93	17	122.1	2.0	93	15
END	1648	60				133.232				132.906			

Paused
1438
1443
Resume
1518
Paused
1533
Resume
1633

Train A Std. Meter Volume Collected: 126.915 Train B Std. Meter Volume Collected: 126.476

Operator Signature: 

17.4
3.3

C.E.M. SOLUTIONS
30B RUN DATA SHEET

Company	Gree	Date	3/24/17
Plant	Guinesville	Project #	11542
Sampling Location	STACK	Run #	3
Operator	TJC	Probe #	P6-3015
Barometric Pressure	30.01	Thermocouple #	TC P6-3015

Sampling Equipment		Train: A	
Meter #	Cems 30B-01A		
Meterbox Cal. Factor	(Y)	1.002	
Sorbent Tube #	01299443		
Spiked Concentration			ng

Sampling Equipment		Train: B	
Meter #	Cems 30B-01B		
Meterbox Cal. Factor	(Y)	1.002	
Sorbent Tube #	01303250		
Spiked Concentration	50		ng

Leak Checks		Train: A		
Pre	.00	l/min	@	17 in/Hg
Post	.00	l/min	@	17 in/Hg

Leak Checks		Train: B		
Pre	.00	l/min	@	17 in/Hg
Post	.00	l/min	@	17 in/Hg

Traverse Point	Clock Time	Sampling Time	Stack Temp °F	Trap Temp °F	Chiller Temp °F	Train: A				Train: B			
						Dry Gas Meter Reading liters	Flow Rate l/min	Meter Temp °F	Pump Vacuum in/Hg	Dry Gas Meter Reading liters	Flow Rate l/min	Meter Temp °F	Pump Vacuum in/Hg
1	800	0	333	322		0.00	2.0	58	13	0.00	2.0	59	12
2	805	5	332	331		12.1	2.0	58	13	9.6	2.0	59	12
3	810	10	333	327		20.4	2.0	58	13	17.4	2.0	59	13
		15		328									
1	822	15	334	328		29.94	2.0	58	10	26.948	2.0	59	13
2	827	20	333	329		38.8	2.0	60	10	35.9	2.0	60	13
3	832	25	334	329		47.2	2.0	60	10	45.0	2.0	60	13
1	839	30	333	331		56.012	2.0	61	10	54.270	2.0	61	13
2	844	35	334	331		64.6	2.0	61	10	63.4	2.0	61	13
3	844	40	333	333		73.1	2.0	61	10	72.5	2.0	62	13
1	857	45	324	329		81.588	2.0	63	9	81.409	2.0	62	12
2	8902	50	334	329		90.4	2.0	63	9	90.8	2.0	63	12
3	907	55	332	331		99.1	2.0	63	9	99.9	2.0	63	12
END	912	60				107.940				107.903			

Train A Std. Meter Volume Collected: 108.977 cA Train B Std. Meter Volume Collected: 107.771 cA

Operator Signature: *Thomas Camp*

110.080

110.880

17.2
3.4

C.E.M. SOLUTIONS
30B RUN DATA SHEET

Company	Gree	Date	3/24/17
Plant	Greenville	Project #	11542
Sampling Location	Stack	Run #	4
Operator	TJC	Probe #	P6-30B
Barometric Pressure	30.01	Thermocouple #	TC6-30B

Sampling Equipment		Train: A	
Meter #	Cems30B-01A		
Meterbox Cal. Factor	(Y)	1.002	
Sorbent Tube #	0L799334		
Spiked Concentration	—	ng	

Sampling Equipment		Train: B	
Meter #	Cems30B-01B		
Meterbox Cal. Factor	(Y)	1.002	
Sorbent Tube #	0L300761		
Spiked Concentration	50	ng	


ΔV_m	Leak Checks		Train: A	
Pre	.00	l/min	@	17
Post	.00	l/min	@	18
				in/Hg

ΔV_m	Leak Checks		Train: B	
Pre	.00	l/min	@	17
Post	.00	l/min	@	18
				in/Hg

Traverse Point	Clock Time	Sampling Time	Stack Temp °F	Trap Temp °F	Chiller Temp °F	Train: A				Train: B			
						Dry Gas Meter Reading liters	Flow Rate l/min	Meter Temp °F	Pump Vacuum in/Hg	Dry Gas Meter Reading liters	Flow Rate l/min	Meter Temp °F	Pump Vacuum in/Hg
A 1	1022	0	332	166		0.00	2.0	70	12	0.00	2.0	71	12
2	1027	5	334	190		10.5	2.0	70	12	10.7	2.0	71	12
3	1032	10	333	226		20.3	2.0	71	16	20.7	2.0	71	14
B 1	1041	15	335	278		30.867	2.0	72	16	31.535	2.0	72	14
2	1046	20	334	291		42.4	2.0	72	16	42.6	2.0	72	14
3	1051	25	334	311		53.4	2.0	73	17	53.6	2.0	73	15
C 1	1100	30	325	310		64.319	2.0	74	17	64.442	2.0	74	15
2	1105	35	335	321		75.8	2.0	74	17	75.7	2.0	74	15
3	1110	40	335	321		86.6	2.0	74	17	86.4	2.0	74	15
D 1	1117	45	335	316		97.443	2.0	74	17	97.323	2.0	74	15
2	1122	50	335	317		109.4	2.0	74	17	108.8	2.0	74	15
3	1127	55	335	322		120.1	2.0	77	17	119.5	2.0	77	15
END	1132	60				130.474				130.146			

Train A Std. Meter Volume Collected: 130.416

Train B Std. Meter Volume Collected: 129.472

Operator Signature: 

17.5
3.4

C.E.M. SOLUTIONS
30B RUN DATA SHEET

Company	Gree	Date	3/24/17
Plant	Guinesville	Project #	11542
Sampling Location	STACK	Run #	5
Operator	TJC	Probe #	P6-3013
Barometric Pressure	30.01	Thermocouple #	TC P6-3013

Sampling Equipment		Train: A	
Meter #	Cems 30B-01A		
Meterbox Cal. Factor	(Y) 1.002		
Sorbent Tube #	OL299321		
Spiked Concentration			ng

Sampling Equipment		Train: B	
Meter #	Cems 30B-01B		
Meterbox Cal. Factor	(Y) 1.002		
Sorbent Tube #	OL300597		
Spiked Concentration	50ng		ng

Leak Checks		Train: A		
Pre	.00	l/min	@	23
Post	0.000	l/min	@	21

Leak Checks		Train: B		
Pre	.00	l/min	@	23
Post	0.000	l/min	@	21

Traverse Point	Clock Time	Sampling Time	Stack Temp °F	Trap Temp °F	Chiller Temp °F	Train: A				Train: B			
						Dry Gas Meter Reading liters	Flow Rate l/min	Meter Temp °F	Pump Vacuum in/Hg	Dry Gas Meter Reading liters	Flow Rate l/min	Meter Temp °F	Pump Vacuum in/Hg
A 1	1210	0	334	197		0.00	2.0	75	17	0.00	2.0	75	15
A 2	1215	5	334	215		1.9	2.0	76	17	11.6	2.0	76	15
A 3	1220	10	334	239		27.3	2.0	76	17	22.9	2.0	76	15
B 1	1230	15	334	290		33.945	2.0	76	17	33.116	2.0	76	15
B 2		20	334	297		45.5	2.0	77	18	44.1	2.0	77	15
B 3		25	334	313		56.3	2.0	77	18	54.7	2.0	77	15
C 1	1250	30	334	67.18 315		67.184	2.0	77	18	65.336	2.0	77	15
C 2	1255	35	335	314		79.3	2.0	77	18	77.2	2.0	77	15
C 3	1300	40	335	321		90.1	2.0	77	17	88.3	2.0	77	15
						88.806		Pre leak check →		79.116			
D 1	1330	45	335	293		101.075	2.0	78	14	100.577	2.0	78	13
D 2	1335	50	335	293		108.7	2.0	78	14	110.4	2.0	78	13
D 3	1340	55	337	293		118.3	2.0	79	14	119.7	2.0	79	13
END	1345	60				128.314				128.186			

Train A Std. Meter Volume Collected: 126.816

Train B Std. Meter Volume Collected: 126.563

Operator Signature: 

Paused 1302 47.05
resumed 1315 93.356

91.917

79.3 77.2 17.4
22.3 22.9 3.4

Client: GREC - Gainesville
 Analyst: A. Lagunas
 Cal Date: 4/4/2017


Analyzer Serial #: 2222
 Analyzer MDL: 0.517 ng
 Analytical Bias Test Min: 10 ng
 Analytical Bias Test Max: 4000 ng
 Flow Rate: 1.50 LPM
 Oven Temp: 680 °C

Multipoint Analyzer Calibration 1

No.	Cal Std. Lot #	Conc. (µg/mL)	Volume Used (µL)	Standard (ng)	Area Count	Area/ng	Calculated (ng)	Recovery (%)
1	K2-MEB603126	0.1001	50.0	5.01	2036	406.8	5.1	102
2	K2-MEB603126	0.1001	100.0	10.01	4125	412.1	10.3	103
3	K2-MEB631041	1.0010	50.0	50.05	20680	413.2	51.8	103
4	K2-MEB631041	1.0010	100.0	100.10	38500	384.6	96.4	96
5	K2-HG650192	10.0020	20.0	200.04	80030	400.1	200.3	100
6	K2-HG650192	10.0020	50.0	500.10	200000	399.9	500.5	100
7								

Note: Recovery must be ±10%

Mean (Area/ng) **402.8**
 Std. Dev. **10.6**
 % RSD **2.6**
 Calibration Coefficient, A **0.0025**
 R-Square **0.99990**



Analysis of Independent Calibration Standard

No.	Cal Std. Lot #	Conc. (µg/mL)	Volume Used (µL)	Standard (ng)	Area Count	Area/ng	Calculated (ng)	Recovery (%)
1	J2-MEB600156	10.0000	10.0	100.00	40000	400.0	100.1	100

Note: Recovery must be ±10%

Low Sample Analysis

No.	Cal Std. Lot #	Conc. (µg/mL)	Volume Used (µL)	Standard (ng)	Area Count	Area/ng
1	K2-MEB603126	0.1001	25.0	2.50	1044	417.2

Continuing Calibration Verification Standard Analysis Table

No.	Sample ID prior to analysis	Standard Conc. (mg/mL)	Volume Used (µL)	Standard (ng)	Area Count	Area/ng	Calculated (ng)	Recovery (%)
1	INITIAL	10.0020	13.0	130.03	49170	378.2	123.1	95
2	OL303250_S1	10.0020	13.0	130.03	53600	412.2	134.1	103
3	FINAL	10.0020	13.0	130.03	55230	424.8	138.2	106
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								

Note: Recovery must be ±10%

C.E.M. Solutions, Inc.**Field Recovery Test**

Client: GREC - Gainesville

Unit: 1

Run ID	Trap ID	Sample Volume, L	Actual Spike, ng	Individual Vol. Deviation from FRT Avg	Spiked Train Vol. Deviation from Estimate	Spiked Hg Recovery (R)
1	OL295477	126.913	50.00	4%		
	OL299325	126.476	0.00	3%		
3	OL299443	110.080	0.00	-10%	8%	104%
	OL303250	110.880	50.00	-9%		
4	OL299334	130.416	0.00	7%	-7%	86%
	OL300761	129.472	50.00	6%		
5	OL299321	126.816	0.00	4%	-5%	94%
	OL300597	126.563	50.00	3%		

Average 95%

Criteria: Sample volume deviations must be within 20%
Average (R) must be between 85% and 115%

Trap ID



OL295477



R1

Sorbent Trap Chain of Custody Form

Unspiked Spiked At: 50ng
 Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Maker)

Production Lot: S-C94 Carbon Lot: RC

QA/QC Signature (Spiker)
 High Flow Coil Pre-filter 240 mm
 Static Pre-filter AGS 300 mm
 Fluffy Pre-filter 185 mm 450 mm

Spike Date: 9/23/2015 Spike Time: 1100

Type of Trap: 30B

Plant/Stack		<u>GREC Stack</u>		Notes		
STMMS ID (check box)		Primary STMMS <input type="checkbox"/>		Backup STMMS <input type="checkbox"/>		Tester <input checked="" type="checkbox"/>
Trap A or B (check box)		Trap A <input checked="" type="checkbox"/> Trap B <input type="checkbox"/>		Sampling System Manufacturer (check box)		Altech <input type="checkbox"/>
RATA Run Number (For RATA only)		<u> </u>		Apex <input checked="" type="checkbox"/> Clean Air <input type="checkbox"/> Environmental Supply <input type="checkbox"/>		M&C <input type="checkbox"/> Ohio Lumex <input type="checkbox"/>
Trap Inserted/Pre-Leak Check (CEMS Date/Time)				Pre-Leak Check (check box)		
Date	<u>3/22/17</u>	Time	<u>1400</u>	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>		
Sample Collection Start (CEMS Date/Time)				Duct Temp. (°F)		
Date	<u>3/22/17</u>	Time	<u>1410</u>	Sorbent Trap Temp. (°F)		
Sample Collection End (CEMS Date/Time)				Average Flow Rate (cc/min)		
Date		Time		Total Volume (L)		
Post-Leak Check/Trap Removed (CEMS Date/Time)				Post-Leak Check (check box)		
Date		Time		Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>		
Startup Event and/or Shutdown Event occurred (check box)				Startup Event <input type="checkbox"/> Shutdown Event <input type="checkbox"/>		
Estimated Hg Concentration (µg/dscm)			Estimated Hg in Section 1			
If thermal desorption is used for analysis, an estimated Hg mass is required for sample acceptance.						
If no estimated mass is provided, the spike mass will be used as the estimate. Results are guaranteed between 20% and 300% of the estimate.						

For Cement Kilns Indicate number of Raw Mill Off events during this sample run:

Chain Of Custody				
Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.				
	Signature	Date	Time	Security Seal
Trap inserted by		<u>3/22/17</u>		If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by		<u>3/22/17</u>	<u>1710</u>	
Trap received by lab				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by		<u>4/4/17</u>	<u>15:00</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs.

For Analysis contact us:

Ohio Lumex Co., Inc. 9263 Ravenna Road Unit A-3, Twinsburg, OH 44087 USA
 Phone 330-405-0837 Fax 330-405-0847 US Toll Free: 888-876-2611
 Impregnated Activated Carbon – Refer to MSDS
 Deactivated glass and glass wool

Best Before: September 2018



Sorbent Trap Chain of Custody Form

Unspiked **Spiked At:** _____
 Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Maker) *[Signature]*

Production Lot: U-5AD Carbon Lot: RC

QA/QC Signature (Spiker) _____

- High Flow Coil Pre-filter 240 mm
 Static Pre-filter AGS 300 mm
 Fluffy Pre-filter 185 mm 450 mm

Spike Date: _____ Spike Time: _____

Type of Trap: 30B

Plant/Stack	<u>Greer Stack</u>		Notes	
STMMS ID (check box)	Primary STMMS <input type="checkbox"/>	Backup STMMS <input type="checkbox"/>	Tester <input checked="" type="checkbox"/>	
Trap A or B (check box)	Trap A <input type="checkbox"/>	Trap B <input checked="" type="checkbox"/>	Sampling System Manufacturer (check box)	Altech <input type="checkbox"/>
RATA Run Number (For RATA only)	<u>---</u>		Apex <input type="checkbox"/>	Clean Air <input type="checkbox"/>
Trap Inserted/Pre-Leak Check (CEMS Date/Time)	Pre-Leak Check (check box)			
Date	<u>3/22/17</u>	Time	<u>1400</u>	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
Sample Collection Start (CEMS Date/Time)	Duct Temp. (°F)			
Date	<u>3/22/17</u>	Time	<u>1410</u>	Sorbent Trap Temp. (°F)
Sample Collection End (CEMS Date/Time)	Average Flow Rate (cc/min)			
Date		Time		Total Volume (L)
Post-Leak Check/Trap Removed (CEMS Date/Time)	Post-Leak Check (check box)			
Date		Time		Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>
Startup Event and/or Shutdown Event occurred (check box)	Startup Event <input type="checkbox"/>		Shutdown Event <input type="checkbox"/>	
Estimated Hg Concentration (µg/dscm)		Estimated Hg in Section 1		

If thermal desorption is used for analysis, an estimated Hg mass is required for sample acceptance.
 If no estimated mass is provided, the spike mass will be used as the estimate. Results are guaranteed between 20% and 300% of the estimate.

For Cement Kilns Indicate number of Raw Mill Off events during this sample run: _____

Chain Of Custody				
Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.				
	Signature	Date	Time	Security Seal
Trap inserted by	<i>[Signature]</i>	<u>3/22/17</u>	<u>1400</u>	If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by	<i>[Signature]</i>	<u>3/22/17</u>	<u>1710</u>	
Trap received by lab				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by	<i>[Signature]</i>	<u>4/4/12</u>	<u>15:00</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs.

For Analysis contact us:

Ohio Lumex Co., Inc. 9263 Ravenna Road Unit A-3, Twinsburg, OH 44087 USA
 Phone 330-405-0837 Fax 330-405-0847 US Toll Free: 888-876-2611
 Impregnated Activated Carbon - Refer to MSDS
 Deactivated glass and glass wool

Best Before: September 2018



27
23

Sorbent Trap Chain of Custody Form

Unspiked **Spiked At:** _____
Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Maker) *[Signature]*

QA/QC Signature (Spiker) _____

Production Lot: U-5AD Carbon Lot: RC

- High Flow Coil Pre-filter 240 mm
- Static Pre-filter AGS 300 mm
- Fluffy Pre-filter 185 mm 450 mm

Spike Date: _____ Spike Time: _____

Type of Trap: 30B

Plant/Stack		Notes	
STMMS ID (check box)		Primary STMMS <input type="checkbox"/>	Backup STMMS <input type="checkbox"/> Tester <input type="checkbox"/>
Trap A or B (check box)		Trap A <input checked="" type="checkbox"/> Trap B <input type="checkbox"/>	Sampling System Manufacturer (check box) Altech <input type="checkbox"/>
RATA Run Number (For RATA only)		Apex <input type="checkbox"/> Clean Air <input type="checkbox"/> Environmental Supply <input type="checkbox"/>	M&C <input type="checkbox"/> Ohio Lumex <input type="checkbox"/>
Trap Inserted/Pre-Leak Check (CEMS Date/Time)		Pre-Leak Check (check box)	
Date	<u>3/23/17</u>	Time	<u>1300</u>
		Pass	<input type="checkbox"/>
		Fail	<input type="checkbox"/>
Sample Collection Start (CEMS Date/Time)		Duct Temp. (°F)	
Date	<u>3/24/17</u>	Time	<u>600</u>
Sample Collection End (CEMS Date/Time)		Sorbent Trap Temp. (°F)	
Date	<u>3/24/17</u>	Time	<u>912</u>
		Average Flow Rate (cc/min)	
		Total Volume (L)	
Post-Leak Check/Trap Removed (CEMS Date/Time)		Post-Leak Check (check box)	
Date	<u>3/24/17</u>	Time	<u>920</u>
		Pass	<input type="checkbox"/>
		Fail	<input type="checkbox"/>
Startup Event and/or Shutdown Event occurred (check box)		Startup Event <input type="checkbox"/>	Shutdown Event <input type="checkbox"/>
Estimated Hg Concentration (µg/dscm)		Estimated Hg in Section 1	

If thermal desorption is used for analysis, an estimated Hg mass is required for sample acceptance.
If no estimated mass is provided, the spike mass will be used as the estimate. Results are guaranteed between 20% and 300% of the estimate.

For Cement Kilns Indicate number of Raw Mill Off events during this sample run: _____

Chain Of Custody				
Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.				
	Signature	Date	Time	Security Seal
Trap inserted by	<i>[Signature]</i>	<u>3/23/17</u>	<u>1300</u>	If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by	<i>[Signature]</i>	<u>3/24/17</u>	<u>930</u>	
Trap received by lab				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by	<i>[Signature]</i>	<u>4/4/17</u>	<u>15:30</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>


Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs.

For Analysis contact us:

Ohio Lumex Co., Inc. 9263 Ravenna Road Unit A-3, Twinsburg, OH 44087 USA
Phone 330-405-0837 Fax 330-405-0847 US Toll Free: 888-876-2611
Impregnated Activated Carbon – Refer to MSDS
Deactivated glass and glass wool

Best Before: September 2018

Trap ID



OL303250



R2/R3

Sorbent Trap Chain of Custody Form

Unspiked Spiked At: 50ng
 Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Maker)

Production Lot: S-C94 Carbon Lot: RC

QA/QC Signature (Spiker)

- High Flow Coil Pre-filter 240 mm
- Static Pre-filter AGS 300 mm
- Fluffy Pre-filter 185 mm 450 mm

Spike Date: 9/23/2015 Spike Time: 1100

Type of Trap: 30B

Plant/Stack		Notes	
STMMS ID (check box)		Primary STMMS <input type="checkbox"/>	Backup STMMS <input type="checkbox"/> Tester <input type="checkbox"/>
Trap A or B (check box)		Trap A <input type="checkbox"/> Trap B <input checked="" type="checkbox"/>	Sampling System Manufacturer (check box) Altech <input type="checkbox"/>
RATA Run Number (For RATA only)		Apex <input type="checkbox"/> Clean Air <input type="checkbox"/> Environmental Supply <input type="checkbox"/>	M&C <input type="checkbox"/> Ohio Lumex <input type="checkbox"/>
Trap Inserted/Pre-Leak Check (CEMS Date/Time)		Pre-Leak Check (check box)	
Date	<u>3/23/17</u>	Time	<u>1300</u>
		Pass <input type="checkbox"/> Fail <input type="checkbox"/>	
Sample Collection Start (CEMS Date/Time)		Duct Temp. (°F)	
Date	<u>3/24/17</u>	Time	<u>800</u>
		Sorbent Trap Temp. (°F)	
Sample Collection End (CEMS Date/Time)		Average Flow Rate (cc/min)	
Date	<u>3/24/17</u>	Time	<u>912</u>
		Total Volume (L)	
Post-Leak Check/Trap Removed (CEMS Date/Time)		Post-Leak Check (check box)	
Date	<u>3/24/17</u>	Time	<u>920</u>
		Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>	
Startup Event and/or Shutdown Event occurred (check box)		Startup Event <input type="checkbox"/> Shutdown Event <input type="checkbox"/>	
Estimated Hg Concentration (µg/dscm)		Estimated Hg in Section 1	
If thermal desorption is used for analysis, an estimated Hg mass is required for sample acceptance. If no estimated mass is provided, the spike mass will be used as the estimate. Results are guaranteed between 20% and 300% of the estimate.			

For Cement Kilns Indicate number of Raw Mill Off events during this sample run: _____

Chain Of Custody				
Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.				
	Signature	Date	Time	Security Seal
Trap inserted by		<u>3/23/17</u>	<u>1300</u>	If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by		<u>3/24/17</u>	<u>930</u>	
Trap received by lab				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by		<u>4/4/17</u>	<u>1530</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs.

For Analysis contact us:

Ohio Lumex Co., Inc. 9263 Ravenna Road Unit A-3, Twinsburg, OH 44087 USA
 Phone 330-405-0837 Fax 330-405-0847 US Toll Free: 888-876-2611
 Impregnated Activated Carbon – Refer to MSDS
 Deactivated glass and glass wool

Best Before: September 2018



Handwritten initials

Sorbent Trap Chain of Custody Form

Unspiked **Spiked At:** _____
Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Maker) *[Signature]*

Production Lot: U-5AD Carbon Lot: RC

QA/QC Signature (Spiker) _____
 High Flow Coil Pre-filter 240 mm
 Static Pre-filter AGS 300 mm
 Fluffy Pre-filter 185 mm 450 mm

Spike Date: _____ Spike Time: _____

Type of Trap: 30B

Plant/Stack		Notes	
STMMS ID (check box)	Primary STMMS <input type="checkbox"/>	Backup STMMS <input type="checkbox"/>	Tester <input type="checkbox"/>
Trap A or B (check box)	Trap A <input checked="" type="checkbox"/> Trap B <input type="checkbox"/>	Sampling System Manufacturer (check box) Altech <input type="checkbox"/>	
RATA Run Number (For RATA only)		Apex <input type="checkbox"/> Clean Air <input type="checkbox"/> Environmental Supply <input type="checkbox"/>	
Trap Inserted/Pre-Leak Check (CEMS Date/Time)		Pre-Leak Check (check box)	
Date	<u>3/24/17</u> Time <u>1015</u>	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>	
Sample Collection Start (CEMS Date/Time)		Duct Temp. (°F)	
Date	<u>3/24/17</u> Time <u>1822</u>	Sorbent Trap Temp. (°F)	
Sample Collection End (CEMS Date/Time)		Average Flow Rate (cc/min)	
Date	<u>3/24/17</u> Time <u>1132</u>	Total Volume (L)	
Post-Leak Check/Trap Removed (CEMS Date/Time)		Post-Leak Check (check box)	
Date	<u>3/24/17</u> Time <u>1140</u>	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>	
Startup Event and/or Shutdown Event occurred (check box)		Startup Event <input type="checkbox"/> Shutdown Event <input type="checkbox"/>	
Estimated Hg Concentration (µg/dscm)		Estimated Hg in Section 1	
<small>If thermal desorption is used for analysis, an estimated Hg mass is required for sample acceptance. If no estimated mass is provided, the spike mass will be used as the estimate. Results are guaranteed between 20% and 300% of the estimate.</small>			

For Cement Kilns Indicate number of Raw Mill Off events during this sample run: _____

Chain Of Custody				
Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.				
	Signature	Date	Time	Security Seal
Trap inserted by	<i>[Signature]</i>	<u>3/24/17</u>	<u>1015</u>	If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by	<i>[Signature]</i>	<u>3/24/17</u>	<u>1140</u>	
Trap received by lab				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by	<i>[Signature]</i>	<u>4/4/12</u>	<u>16:05</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs.

For Analysis contact us:
 Ohio Lumex Co., Inc. 9263 Ravenna Road Unit A-3, Twinsburg, OH 44087 USA
 Phone 330-405-0837 Fax 330-405-0847 US Toll Free: 888-876-2611
 Impregnated Activated Carbon – Refer to MSDS
 Deactivated glass and glass wool

Best Before: September 2018

Trap ID



OL300761



Sorbent Trap Chain of Custody Form

R3 R4

Unspiked Spiked At: 50ng
 Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Maker)

QA/QC Signature (Spiker)

Production Lot: S-C94 Carbon Lot: RC

- High Flow Coil Pre-filter 240 mm
- Static Pre-filter AGS 300 mm
- Fluffy Pre-filter 185 mm 450 mm

Spike Date: 9/23/2015 Spike Time: 1100

Type of Trap: 30B

Plant/Stack		Notes	
STMMS ID (check box)	Primary STMMS <input type="checkbox"/>	Backup STMMS <input type="checkbox"/>	Tester <input type="checkbox"/>
Trap A or B (check box)	Trap A <input type="checkbox"/>	Trap B <input checked="" type="checkbox"/>	Sampling System Manufacturer (check box) Altech <input type="checkbox"/>
RATA Run Number (For RATA only)		Apex <input type="checkbox"/> Clean Air <input type="checkbox"/> Environmental Supply <input type="checkbox"/>	
Trap Inserted/Pre-Leak Check (CEMS Date/Time)		Pre-Leak Check (check box)	
Date	<u>3/24/17</u>	Time	<u>1015</u>
		Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>	
Sample Collection Start (CEMS Date/Time)		Duct Temp. (°F)	
Date	<u>3/24/17</u>	Time	<u>1027</u>
Sample Collection End (CEMS Date/Time)		Sorbent Trap Temp. (°F)	
Date	<u>3/24/17</u>	Time	<u>1132</u>
Post-Leak Check/Trap Removed (CEMS Date/Time)		Post-Leak Check (check box)	
Date	<u>3/24/17</u>	Time	<u>1140</u>
		Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>	
Startup Event and/or Shutdown Event occurred (check box)		Startup Event <input type="checkbox"/> Shutdown Event <input type="checkbox"/>	
Estimated Hg Concentration (µg/dscm)		Estimated Hg in Section 1	
If thermal desorption is used for analysis, an estimated Hg mass is required for sample acceptance. If no estimated mass is provided, the spike mass will be used as the estimate. Results are guaranteed between 20% and 300% of the estimate.			

For Cement Kilns

Indicate number of Raw Mill Off events during this sample run: _____

Chain Of Custody

Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.				
	Signature	Date	Time	Security Seal
Trap inserted by		<u>3/24/17</u>	<u>1015</u>	If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by		<u>3/24/17</u>	<u>1140</u>	
Trap received by lab				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by		<u>7/9/17</u>	<u>1615</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs.

For Analysis contact us:

Ohio Lumex Co., Inc. 9263 Ravenna Road Unit A-3, Twinsburg, OH 44087 USA
 Phone 330-405-0837 Fax 330-405-0847 US Toll Free: 888-876-2611
 Impregnated Activated Carbon – Refer to MSDS
 Deactivated glass and glass wool

Best Before: September 2018

Trap ID



OL300597



RS

Sorbent Trap Chain of Custody Form

Unspiked Spiked At: 50ng
 Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Maker)

QA/QC Signature (Spiker)

Production Lot: S-C94 Carbon Lot: RC

- High Flow Coil Pre-filter 240 mm
- Static Pre-filter AGS 300 mm
- Fluffy Pre-filter 185 mm 450 mm

Spike Date: 9/23/2015 Spike Time: 1100

Type of Trap: 30B

Plant/Stack		Notes	
STMMS ID (check box)	Primary STMMS <input type="checkbox"/>	Backup STMMS <input type="checkbox"/>	Tester <input type="checkbox"/>
Trap A or B (check box)	Trap A <input type="checkbox"/>	Trap B <input checked="" type="checkbox"/>	Sampling System Manufacturer (check box) Altech <input type="checkbox"/>
RATA Run Number (For RATA only)		Apex <input type="checkbox"/> Clean Air <input type="checkbox"/> Environmental Supply <input type="checkbox"/>	
Trap Inserted/Pre-Leak Check (CEMS Date/Time)		Pre-Leak Check (check box)	
Date	<u>3/24/17</u>	Time	<u>1155</u>
		Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>	
Sample Collection Start (CEMS Date/Time)		Duct Temp. (°F)	
Date	<u>3/24/17</u>	Time	<u>1210</u>
Sample Collection End (CEMS Date/Time)		Sorbent Trap Temp. (°F)	
Date	<u>3/24/17</u>	Time	<u>1345</u>
Post-Leak Check/Trap Removed (CEMS Date/Time)		Average Flow Rate (cc/min)	
Date	<u>3/24/17</u>	Time	<u>1350</u>
Startup Event and/or Shutdown Event occurred (check box)		Total Volume (L)	
		Startup Event <input type="checkbox"/> Shutdown Event <input type="checkbox"/>	
Estimated Hg Concentration (µg/dscm)		Estimated Hg in Section 1	
If thermal desorption is used for analysis, an estimated Hg mass is required for sample acceptance. If no estimated mass is provided, the spike mass will be used as the estimate. Results are guaranteed between 20% and 300% of the estimate.			

For Cement Kilns Indicate number of Raw Mill Off events during this sample run: _____

Chain Of Custody				
Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.				
	Signature	Date	Time	Security Seal
Trap inserted by		<u>3/24/17</u>	<u>1155</u>	If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by		<u>3/24/17</u>	<u>1350</u>	
Trap received by lab				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by		<u>4/4/17</u>	<u>16:40</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs.

For Analysis contact us:

Ohio Lumex Co., Inc. 9263 Ravenna Road Unit A-3, Twinsburg, OH 44087 USA
 Phone 330-405-0837 Fax 330-405-0847 US Toll Free: 888-876-2611
 Impregnated Activated Carbon – Refer to MSDS
 Deactivated glass and glass wool

Best Before: September 2018



RS

Sorbent Trap Chain of Custody Form

Unspiked **Spiked At:** _____
 Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Maker) 

Production Lot: U-5AD Carbon Lot: RC




QA/QC Signature (Spiker) _____
 High Flow Coil Pre-filter 240 mm
 Static Pre-filter AGS 300 mm
 Fluffy Pre-filter 185 mm 450 mm

Spike Date: _____ Spike Time: _____

Type of Trap: 30B

Plant/Stack		Notes	
STMMS ID (check box)		Primary STMMS <input type="checkbox"/>	Backup STMMS <input type="checkbox"/> Tester <input type="checkbox"/>
Trap A or B (check box)		Trap A <input checked="" type="checkbox"/> Trap B <input type="checkbox"/>	Sampling System Manufacturer (check box) Altech <input type="checkbox"/> Apex <input type="checkbox"/> Clean Air <input type="checkbox"/> Environmental Supply <input type="checkbox"/> M&C <input type="checkbox"/> Ohio Lumex <input type="checkbox"/>
RATA Run Number (For RATA only)			
Trap Inserted/Pre-Leak Check (CEMS Date/Time)		Pre-Leak Check (check box)	
Date	<u>3/24/17</u>	Time	<u>1155</u>
		Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>	
Sample Collection Start (CEMS Date/Time)		Duct Temp. (°F)	
Date	<u>3/24/17</u>	Time	<u>1210</u>
Sample Collection End (CEMS Date/Time)		Sorbent Trap Temp. (°F)	
Date	<u>3/24/17</u>	Time	<u>1345</u>
		Average Flow Rate (cc/min)	
		Total Volume (L)	
Post-Leak Check/Trap Removed (CEMS Date/Time)		Post-Leak Check (check box)	
Date	<u>3/24/17</u>	Time	<u>1350</u>
		Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/>	
Startup Event and/or Shutdown Event occurred (check box)		Startup Event <input type="checkbox"/>	Shutdown Event <input type="checkbox"/>
Estimated Hg Concentration (µg/dscm)		Estimated Hg in Section 1	
If thermal desorption is used for analysis, an estimated Hg mass is required for sample acceptance. If no estimated mass is provided, the spike mass will be used as the estimate. Results are guaranteed between 20% and 300% of the estimate.			

For Cement Kilns Indicate number of Raw Mill Off events during this sample run: _____

Chain Of Custody				
Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.				
	Signature	Date	Time	Security Seal
Trap inserted by		<u>3/24/17</u>	<u>1155</u>	If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by		<u>3/24/17</u>	<u>1350</u>	
Trap received by lab				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by		<u>4/4/17</u>	<u>16:30</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs.

For Analysis contact us:

Ohio Lumex Co., Inc. 9263 Ravenna Road Unit A-3, Twinsburg, OH 44087 USA
 Phone 330-405-0837 Fax 330-405-0847 US Toll Free: 888-876-2611
 Impregnated Activated Carbon – Refer to MSDS
 Deactivated glass and glass wool

Best Before: September 2018

Appendix E-8: Dioxins and Furans Test Data

Summaries
Method 23 Field Data Sheets
Analytical Results

Method 23 RESULTS SUMMARY

	<u>Units</u>	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>	<u>Limit</u>
Date	mm/dd/yy	3/22/2017	3/23/2017	3/23/2017		
Run Start Time	hh:mm	12:35	7:23	12:45		
Run Stop Time	hh:mm	16:56	11:07	16:15		
Meter Calibration Factor		0.956	0.956	0.956		
Meter Calibration Verification		0.928	0.929	0.940		
DH @ 0.75 SCFM		1.982	1.982	1.982		
Pitot Tube Coefficient		0.840	0.840	0.840		
Actual Nozzle Diameter	in	0.218	0.218	0.218		
<u>Stack Test Data</u>						
Initial Meter Volume	ft ³	248.129	352.123	451.170		
Final Meter Volume	ft ³	351.661	450.444	554.645		
Leak Check Volume	ft ³	0.465	0.702	0.733		
Total Meter Volume	ft ³	103.067	97.619	102.742	101.143	
Standard Meter Volume	dscf	95.370	93.800	97.705	95.625	
Total Sampling Time	min	180.0	180.0	180.0	180.0	
Average Meter Temperature	°F	87.1	65.5	71.1	74.6	
Average Stack Temperature	°F	333.7	331.6	332.0	332.4	
Barometric Pressure	in Hg	29.93	29.86	29.86	29.88	
Stack Static Pressure	in H ₂ O	-0.54	-0.54	-0.54	-0.54	
Absolute Stack Pressure	in Hg	29.89	29.82	29.82	29.84	
Average Orifice Pressure Drop	in H ₂ O	1.03	0.96	1.07	1.02	
Absolute Meter Pressure	in Hg	30.01	29.93	29.94	29.96	
Avg Square Root Pitot Pressure	(in H ₂ O) ^{1/2}	0.91	0.90	0.95	0.92	
<u>Moisture Content Data</u>						
Impinger Water Volume Gain	ml	0.0	0.0	0.0	0.0	
Impinger Water Weight Gain	g	519.1	545.4	602.2	555.6	
Standard Water Vapor Volume	scf	24.476	25.716	28.394	26.195	
Calculated Stack Moisture	%	20.4	21.5	22.5	21.5	
Saturated Stack Moisture	%	100.00	100.0	100.0	100.0	
Reported Stack Moisture Content	%	20.4	21.5	22.5	21.5	
<u>Gas Analysis Data</u>						
Carbon Dioxide Percentage	%	17.3	17.3	17.3	17.3	
Oxygen Percentage	%	3.3	3.3	3.3	3.3	
Carbon Monoxide Percentage	%	0.0	0.0	0.0	0.0	
Nitrogen Percentage	%	79.4	79.4	79.4	79.4	
Dry Gas Molecular Weight	lb/lb-mole	30.90	30.90	30.90	30.90	
Wet Stack Gas Molecular Weight	lb/lb-mole	28.27	28.12	28.00	28.13	
Calculated Fuel Factor		1.017	1.017	1.017	1.017	
Fuel F-Factor	dscf/mmBtu	9240	9240	9240	9240	
Percent Excess Air	%	18.7	18.7	18.7	18.7	
<u>Volumetric Flow Rate Data</u>						
Average Stack Gas Velocity	ft/sec	63.62	62.88	66.14	64.21	
Stack Cross-Sectional Area	ft ²	112.31	112.31	112.31		
Actual Stack Flow Rate	acfm	428719	423716	445724	432720	
Wet Standard Stack Flow Rate	wkscfh	17095	16902	17770	17255	
Dry Standard Stack Flow Rate	dscfm	226733	221082	229473	225763	
Percent of Isokinetic Rate	%	101.3	102.1	102.5	102.0	
<u>Emission Rate Data</u>						
PCDD/PCDF TEQ	pg	66.2	101.0	71.6	79.6	
Standard Meter Volume (dscm)	dscm	2.7	2.7	2.8	2.7	
PCDD/PCDF emission	ng/dscm	0.02	0.04	0.03	0.03	
PCDD/PCDF Corrected to 7% Oxygen	ng/dscm @ 7%	0.02	0.03	0.02	0.02	0.15

Method 23 Field Data Sheets

ISOKINETIC SAMPLING DATA

Plant Name	GREC - GREC	Date	3/22/2017
Sampling Location	Boiler stack	Project #	11542
Operator	AL	Run #	1
# Traverse Points	16	Test Method	23

Pitot Tube Coefficient	(C _p)	0.840	
Avg Stack Temp	(t _s)	330	°F
Avg Gas Meter Temp	(t _m)	75	°F
DH @ 0.75 SCFM	(ΔH@)	1.98	in H ₂ O
Avg Pitot Tube Diff. Pressure	(Δp _{avg})	1.00	in H ₂ O
Stack Moisture Content	(B _{ws})	22.0	%
Stack Dry Molecular Weight	(M _{ds})	30.84	lb/lb-mole
Estimated Orifice Flow Rate	(Q _m)	0.7500	acfm
DP to DH Isokinetic Factor	(K)	1.21	

Meter # CEMS3MB		
Meterbox Cal. Factor	(Y)	0.956
Nozzle # G218-15		
Actual Nozzle Diameter	(D _{na})	0.2180 in
Req. Nozzle Diameter	(D _{ni})	0.2502 in
Probe # / Length	P5	6.00 ft
Liner Material Glass		
Thermocouple ID # TC5		
Impinger Case # -		

Barometric Pressure	(P _b)	29.93	in Hg
Stack Static Pressure	(P _{static})	-0.54	in H ₂ O
Absolute Stack Pressure	(P _s)	29.89	in Hg
Absolute Meter Pressure	(P _m)	30.08	in Hg

ΔV_m	Pre	0	ft ³ /min	@	10	in Hg
Leak Check Total Volume (ft³):					0.465	ft ³
Post	0	ft ³ /min	@	7	in Hg	
ΔV_m < 0.020		ft ³ /min	<input checked="" type="checkbox"/>	Leak Check OK?		
Pitot OK?			<input checked="" type="checkbox"/>	Orsat OK?		<input checked="" type="checkbox"/>

Traverse Point #	Sampling Time (Θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp	Pump Vacuum	
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	in Hg	
A-1	0.0	12:35:00	248.129	0.800	0.968	0.970	334	233	76	62	65	3.0	
A-2	11.3	12:46:15	254.490	0.850	1.028	1.000	333	255	79	61	64	3.0	
A-3	22.5	12:57:30	260.940	0.870	1.053	1.000	333	257	82	63	65	3.0	
A-4	33.8	13:08:45	267.410	0.800	0.968	0.970	332	259	84	64	67	3.0	
B-1	45.0	14:12:00	273.816	0.830	1.004	1.000	333	258	83	60	66	3.0	
B-2	56.3	14:23:15	279.990	0.850	1.028	1.000	334	260	86	59	66	3.0	
B-3	67.5	14:34:30	286.320	0.800	0.968	0.970	334	260	88	55	67	3.0	
B-4	78.8	14:45:45	282.490	0.770	0.932	0.930	327	260	89	61	66	3.0	
C-1	90.0	15:15:00	298.977	0.930	1.125	1.100	335	259	89	58	64	3.0	
C-2	101.3	15:26:15	306.110	0.870	1.053	1.100	335	259	90	65	66	3.0	
C-3	112.5	15:37:30	312.000	0.880	1.065	1.100	335	261	91	66	64	3.0	
C-4	123.8	15:48:45	319.250	0.800	0.968	0.970	333	259	92	67	66	3.0	
D-1	135.0	16:11:00	326.189	0.720	0.871	1.100	333	260	90	65	65	3.0	
D-2	146.3	16:22:15	332.340	0.890	1.077	1.100	336	264	91	65	66	3.0	
D-3	157.5	16:33:30	338.700	0.880	1.065	1.100	336	259	92	57	60	3.0	
D-4	168.8	16:44:45	344.930	0.840	1.016	1.000	336	260	91	59	60	3.0	
Last Pt	180.0	16:56:00	351.661										
Last Pt	180.0	16:56:00	351.661					Maximum Vacuum				3.0	
Average Values				0.84			1.03	334	258	87	62	65	

ISOKINETIC SAMPLING DATA

Plant Name	GREC - GREC	Date	3/23/2017
Sampling Location	Boiler stack	Project #	11542
Operator	AL	Run #	3
# Traverse Points	16	Test Method	23

Pitot Tube Coefficient	(C _p)	0.840	
Avg Stack Temp	(t _s)	330	°F
Avg Gas Meter Temp	(t _m)	70	°F
DH @ 0.75 SCFM	(ΔH@)	1.98	in H ₂ O
Avg Pitot Tube Diff. Pressure	(ΔP _{avg})	1.00	in H ₂ O
Stack Moisture Content	(B _{ws})	22.0	%
Stack Dry Molecular Weight	(M _{ds})	30.90	lb/lb-mole
Estimated Orifice Flow Rate	(Q _m)	0.7500	acfm
DP to DH Isokinetic Factor	(K)	1.20	

Meter #			CEMS3MB								
Meterbox Cal. Factor	(Y)	0.956									
Nozzle #						G218-15					
Actual Nozzle Diameter	(D _{na})	0.2180	in								
Req. Nozzle Diameter	(D _{ni})	0.2513	in								
Probe # / Length	P5	6.00	ft								
Liner Material						Glass					
Thermocouple ID #						TC5					
Impinger Case #						-					

Barometric Pressure	(P _b)	29.86	in Hg
Stack Static Pressure	(P _{static})	-0.54	in H ₂ O
Absolute Stack Pressure	(P _s)	29.82	in Hg
Absolute Meter Pressure	(P _m)	30.01	in Hg

ΔV_m Pre	0	ft ³ /min	@	7	in Hg
Leak Check Total Volume (ft³):					0.733
ΔV_m Post	0	ft ³ /min	@	7	in Hg
ΔV_m < 0.020		ft ³ /min	<input checked="" type="checkbox"/>	Leak Check OK?	
Pitot OK?			<input checked="" type="checkbox"/>	Orsat OK?	<input checked="" type="checkbox"/>

Traverse Point #	Sampling Time (θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp	Pump Vacuum
A-1	0.0	12:45:00	451.170	0.74	0.89	0.89	332	253	67	59	61	4.0
A-2	11.3	12:56:15	457.180	0.93	1.11	1.10	332	254	69	57	61	4.0
A-3	22.5	13:07:30	463.470	0.94	1.13	1.10	332	254	70	60	63	4.0
A-4	33.8	13:18:45	469.340	0.85	1.02	1.00	332	254	72	60	64	4.0
B-1	45.0	13:40:00	476.745	0.88	1.06	1.10	332	259	71	65	66	6.0
B-2	56.3	13:51:15	483.240	1.00	1.20	1.20	332	255	72	57	58	5.0
B-3	67.5	14:02:30	489.630	0.92	1.10	1.10	332	254	73	62	59	5.0
B-4	78.8	14:13:45	496.150	0.88	1.06	1.10	333	253	72	67	65	5.0
C-1	90.0	14:36:00	503.087	0.85	1.02	1.00	331	254	71	60	62	4.0
C-2	101.3	14:47:15	509.440	0.92	1.10	1.10	332	255	73	58	57	4.0
C-3	112.5	14:58:30	515.980	0.83	1.00	1.00	333	255	73	64	61	4.0
C-4	123.8	15:09:45	522.710	0.83	1.00	1.00	331	255	72	67	65	4.0
D-1	135.0	15:30:00	528.452	0.99	1.19	1.20	333	256	70	62	60	5.0
D-2	146.3	15:41:15	534.140	0.94	1.13	1.10	333	255	71	67	64	5.0
D-3	157.5	15:52:30	540.190	1.00	1.20	1.20	331	254	71	66	60	5.0
D-4	168.8	16:03:45	546.950	0.83	1.00	1.00	331	254	71	62	64	5.0
Last Pt	180.0	16:15:00	554.645									
Final Value	180.0	16:15:00	554.645									
Average Values				0.90		1.07	332	255	71	62	62	6.0
163												

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name <u>GDFC</u>	Date <u>3/22/17</u>
Sampling Location <u>STACK</u>	Project # <u>11542</u>
Operators <u>AZ</u>	Run # <u>1</u>
Test Method <u>23</u>	Sampling Type <input checked="" type="checkbox"/> Isokinetic <input type="checkbox"/> Constant Rate

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	330	°F
Avg Gas Meter Temp	(t _m)	75	°F
DH @ 0.75 SCFM	(ΔH@)	1.982	in H ₂ O
Avg Pitot Tube Diff. Pressure	(ΔP _{avg})	1.0	in H ₂ O
Stack Moisture Content	(B _{ws})	22	%
Oxygen	(O ₂)	30	%
Carbon Dioxide	(CO ₂)	17	%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)	1.21	
Pressures			
Barometric Pressure	(P _b)	30.23	in Hg
Stack Static Pressure	(P _{static})	-.54	in H ₂ O
Sampling Equipment Checks			
Pump to Meter Leak	Pre	<input checked="" type="checkbox"/> Y / <input checked="" type="checkbox"/> N	Post
Orsat Leak	Pre	<input checked="" type="checkbox"/> Y / <input checked="" type="checkbox"/> N	Post
Nozzle in direction of flow?	<input checked="" type="checkbox"/>		

Sampling Equipment			
Meter #	<u>CFMS3MB</u>		
Meterbox Cal. Factor	(Y)	0.956	
Filter / Nozzle #	<u>3218-15</u>		
Actual Nozzle Diameter	(D _{na})	0.218	in
Req. Nozzle Diameter	(D _{ni})	0.251	in
Probe #	<u>P5</u>		
Liner Material	<u>GLASS</u>		
Pitot #	<u>15400</u>		
Thermocouple #	<u>TCS</u>		

ΔV _m Vacuum Leak Check					
Pre	.000	ft ³ /min	@	10	in Hg
Post	.000	ft ³ /min	@	7	in Hg
Pitot Leak Checks					
Pre	.00	inches	@	5.4	in H ₂ O
Post	.00	inches	@	6.2	in H ₂ O

Traverse Point #	Sampling Time (°)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	XAD Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum	XAD Temp
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	in Hg	°F
051	0	1235	248.129	.80	.968	.97	334	233	76	62	65	3	
2	11.8	1246	254.49	.85	1.02	1.0	333	255	79	61	64	3	
3	22.5	1358	260.94	.87	1.05	1.0	333	257	82	63	65	3	
4	33.8	1309	267.41	.80	.968	.97	333	259	84	64	67	3	
	45	1320	273.057										
1	45	1412	273.816	.83	1.00	1.0	333	258	83	60	66	3	
2	56.3	1423	279.49	.85	1.02	1.0	334	260	86	59	66	3	
3	67.5	1434	286.82	.80	.968	.97	334	260	85	55	67	3	
4	78.8	1445	292.49	.77	.932	.93	327	260	89	61	66	3	
	90	1457	298.849										
1	90	1515	298.977	.93	1.12	1.1	335	259	89	58	64	3	
2	101.3	1524	306.11	.87	1.05	1.1	335	257	90	65	66	3	
3	112.5	1537	312.06	.84	1.06	1.1	335	261	91	66	64	3	
4	123.2	1548	319.25	.80	.968	.97	333	259	92	67	66	3	
	135.0	1600	326.011										
1	135.0	1611	326.189	.72	1.13	1.1	333	260	90	65	65	3	
2	146.5	1622	332.84	.89	1.08	1.1	336	261	91	65	66	3	
3	157.3	1633	338.70	.88	1.06	1.1	336	259	92	57	60	3	
4	168.8	1644	344.93	.84	1.02	1.0	336	260	91	59	60	3	
	180.0	1656	351.41										

(468°F)
XAD Temp

Operator Signature

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name: GIREC	Date: 3/23/17
Sampling Location: STACK	Project #: 11542
Operators: AL	Run #: 2
Test Method: 23	Sampling Type: <input checked="" type="checkbox"/> Isokinetic <input type="checkbox"/> Constant Rate

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	330	°F
Avg Gas Meter Temp	(t _m)	40	°F
DH @ 0.75 SCFM	(ΔH@)	1.982	in H ₂ O
Avg Pitot Tube Diff. Pressure	(ΔP _{avg})	1.0	in H ₂ O
Stack Moisture Content	(B _{ws})	2.2	%
Oxygen	(O ₂)	3.0	%
Carbon Dioxide	(CO ₂)	17	%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)	1.16	
Pressures			
Barometric Pressure	(P _b)	29.86	in Hg
Stack Static Pressure	(P _{static})	-5.4	in H ₂ O
Sampling Equipment Checks			
Pump to Meter Leak	Pre	Y/N	Post Y/N
Orsat Leak	Pre	Y/N	Post Y/N
Nozzle in direction of flow? <input checked="" type="checkbox"/>			

Sampling Equipment			
Meter #	CEMS 3713		
Meterbox Cal. Factor	(Y)	1.956	
Filter / Nozzle #	G218-25		
Actual Nozzle Diameter	(D _{na})	0.215	in
Req. Nozzle Diameter	(D _{nl})	0.253	in
Probe #	P6		
Liner Material	SSR GLASS		
Pitot #	A540		
Thermocouple #	TC 4		

ΔV _m Vacuum Leak Check				
Pre	0.006	ft ³ /min	@	8 in Hg
Post	0.000	ft ³ /min	@	7 in Hg
Pitot Leak Checks				
Pre	0.06	inches	@	6.4 in H ₂ O
Post	0.0	inches	@	3.1 in H ₂ O

Traverse Point #	Sampling Time (θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum	XAD
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	°F	°F	°F	°F	°F	in Hg	
EA 1	0	723	352.123	.86	1.01	1.0	330	237	58	254	57	4	58
2	11.3	734	358.91	.78	.92	.92	330	231	60	251	55	3	59
3	22.5	746	364.56	.83	.98	.96	331	240	61	250	57	2	60
4	33.8	757	370.48	.77	.91	.91	333	230	61	256	58	4	60
	45	808	376.456										
S 1	45	822	376.637	.80	.94	.94	327	257	60	257	60	5	59
2	56.3	833	382.56	.85	1.03	1.0	333	254	62	260	67	5	63
3	67.5	845	389.01	.75	.89	.89	333	253	62	258	64	5	62
4	79.8	856	395.36	.73	.86	.86	332	254	65	253	64	5	60
	90	907	401.059										
W 1	90	927	401.416	.84	.97	.97	334	253	64	261	49	5	58
2	101.5	938	407.46	.91	1.07	1.1	333	253	67	255	48	6	66
3	112.3	949	412.67	.83	.98	.98	333	255	68	257	48	5	66
4	123.8	1001	418.78	.75	.86	.86	331	298	71	297	52	4	66
	135	1012	425.821										
N 1	135	1022	425.685	.86	1.01	1.0	330	252	70	246	58	4	65
2	146.5	1034	431.78	.84	1.00	1.0	333	253	73	256	60	5	66
3	159.3	1045	439.34	.87	1.04	1.0	333	253	72	258	65	5	67
4	168.8	1057	444.64	.77	.88	.88	332	245	73	252	66	5	67
	180	1107	450.444										

Operator Signature:

413.07

NEW K-factor

(68°)

XAD
T

C.E.M. SOLUTIONS SAMPLE DATA SHEET

Plant Name QREC	Date 2/23/17
Sampling Location 3A/C	Project # 11542
Operators RL	Run # 2
Test Method 23	Sampling Type <input checked="" type="checkbox"/> Isokinetic <input type="checkbox"/> Constant Rate

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	320	°F
Avg Gas Meter Temp	(t _m)	70	°F
DH @ 0.75 SCFM	(ΔH@)	1.982	in H ₂ O
Avg Pitot Tube Diff. Pressure	(Δp _{avg})	1.0	in H ₂ O
Stack Moisture Content	(B _{ws})	22	%
Oxygen	(O ₂)	2	%
Carbon Dioxide	(CO ₂)	17	%
Estimated Orifice Flow Rate	(Q _m)	0.75	acfm
K-Factor	(K)	1.20	

Pressures			
Barometric Pressure	(P _b)	29.82	in Hg
Stack Static Pressure	(P _{static})	-5.1	in H ₂ O

Sampling Equipment Checks			
Pump to Meter Leak	Pre	Y/N	Post
Orsat Leak	Pre	Y/N	Post
Nozzle in direction of flow? <input checked="" type="checkbox"/>			

Sampling Equipment			
Meter #	CEMS 3MB		
Meterbox Cal. Factor	(Y)	0.956	
Filter / Nozzle #	G218-15		
Actual Nozzle Diameter	(D _{na})	0.218	in
Req. Nozzle Diameter	(D _n)	0.257	in
Probe #	PL-		
Liner Material	GLASS		
Pitot #	AS400		
Thermocouple #	TCL-		

ΔV _m Vacuum Leak Check				
Pre	0.00	ft ³ /min	@	7
Post	0.00	ft ³ /min	@	7

Pitot Leak Checks				
Pre	0.1	inches	@	7.2
Post	0.0	inches	@	6.4

Traversal Point #	Sampling Time (θ)	Clock Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH)	Actual Orifice ΔH (ΔH)	Stack Temp (t _s)	Probe Temp (t _p)	Meter Outlet Temp (t _{mo})	Filter Temp	Impinger Exit Temp <68 °F	Pump Vacuum	XAD
1	0	1245	461.170	.74	.89	.89	332	253	67	239	61	4	59
2	11.3	1256	457.16	.93	1.12	1.1	332	254	69	247	61	4	57
3	22.5	1307	463.47	.94	1.13	1.1	332	254	70	256	63	4	60
4	33.8	1319	460.04	.85	1.02	1.0	332	254	72	259	64	4	60
	45	1330	476.883										
1	45	1340	476.745	.88	1.06	1.1	332	259	71	257	66	3	65
2	56.3	1361	483.24	1.0	1.2	1.2	332	255	72	239	58	5	57
3	67.3	1402	489.63	.92	1.1	1.1	332	254	73	251	59	5	56.2
4	79	1414	406.15	.88	1.1	1.1	333	253	72	245	65	5	67
	90	1425	502.895										
1	90	1436	503.087	.85	1.02	1.0	331	254	71	257	62	4	60
2	106.5	1477	509.44	.92	1.1	1.1	332	255	73	257	57	4	58
3	112.5	1458	515.98	.83	1.0	1.0	333	255	73	259	61	4	64
4	125	1500	522.71	.80	1.0	1.0	331	255	72	258	65	4	67
	135	1521	570.24										
1	135	1530	525.452	.99	1.2	1.2	333	256	70	262	60	5	62
2	144.5	1541	534.14	.94	1.1	1.1	333	255	71	257	64	5	63
3	153.3	1552	540.19	1.0	1.2	1.2	331	254	71	258	60	5	64
4	166.8	1604	546.95	.80	1.0	1.0	331	254	71	257	64	5	62
	180	1615	544.645										

Operator Signature:

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	GREC			Date	03/22/17		
Sampling Location	Boiler stack			Project #	11542		
Operator	AL			# of Ports Used	4		
Stack Type	Circular			Meter Box Number	CEMS3MB		
Train Leak Check	<input type="checkbox"/>	PreTest	<input type="checkbox"/>	PostTest			

Moisture Content Data								
Run Number	1		Run Start Time		12:35		Run Stop Time	16:56
Total Meter Volume	(V _m)	103.532	dcf	Barometric Press.		(P _b)	29.93	in Hg
Avg Meter Temp	(t _m) _{avg}	87	°F	Stack Static Press.		(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	334	°F	Avg Orifice Press.		(ΔH) _{avg}	1.03	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		g	g	g	g	g	ml	ml
Contents			DI	DI		Sil Gel		
Initial Value	(V _i),(W _i)	371.30	652.40	647.50	607.40	845.60		
Final Value	(V _f),(W _f)	856.00	653.20	645.50	607.10	881.50		
Net Value	(V _n),(W _n)	484.7	0.8	-2.0	-0.3	35.9		
Results								
Total Volume	(V _t)	0.00	ml	Water Vol Condensed		(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	519.10	g	Water Vol Weighed		(V _{wsg(std)})	24.476	scf
Std Meter Volume	(V _{m(std)})	95.370	dscf	Sat. Moisture Content		(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws(calc)})	20.4	%	Final Moisture Content		(B _{ws})	20.4	%

Moisture Content Data								
Run Number	2		Run Start Time		7:23		Run Stop Time	11:07
Total Meter Volume	(V _m)	98.321	dcf	Barometric Press.		(P _b)	29.86	in Hg
Avg Meter Temp	(t _m) _{avg}	66	°F	Stack Static Press.		(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	332	°F	Avg Orifice Press.		(ΔH) _{avg}	0.96	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		g	g	g	g	g	ml	ml
Contents			DI	DI		Sil Gel		
Initial Value	(V _i),(W _i)	373.70	653.20	645.50	607.10	909.30		
Final Value	(V _f),(W _f)	874.60	656.60	645.50	608.30	949.20		
Net Value	(V _n),(W _n)	500.9	3.4	0.0	1.2	39.9		
Results								
Total Volume	(V _t)	0.00	ml	Water Vol Condensed		(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	545.40	g	Water Vol Weighed		(V _{wsg(std)})	25.716	scf
Std Meter Volume	(V _{m(std)})	93.800	dscf	Sat. Moisture Content		(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	21.5	%	Final Moisture Content		(B _{ws})	21.5	%

Moisture Content Data								
Run Number	3		Run Start Time		12:45		Run Stop Time	16:15
Total Meter Volume	(V _m)	103.475	dcf	Barometric Press.		(P _b)	29.86	in Hg
Avg Meter Temp	(t _m) _{avg}	71	°F	Stack Static Press.		(P _{static})	-0.54	in H ₂ O
Avg Stack Temp	(t _s) _{avg}	332	°F	Avg Orifice Press.		(ΔH) _{avg}	1.07	in H ₂ O
		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		g	g	g	g	g	ml	ml
Contents			DI	DI		Sil Gel		
Initial Value	(V _i),(W _i)	353.30	669.20	625.20	606.50	917.50		
Final Value	(V _f),(W _f)	911.50	669.70	627.40	607.50	957.80		
Net Value	(V _n),(W _n)	558.2	0.5	2.2	1.0	40.3		
Results								
Total Volume	(V _t)	0.00	ml	Water Vol Condensed		(V _{wc(std)})	0.000	scf
Total Weight	(W _t)	602.20	g	Water Vol Weighed		(V _{wsg(std)})	28.394	scf
Std Meter Volume	(V _{m(std)})	97.705	dscf	Sat. Moisture Content		(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	22.5	%	Final Moisture Content		(B _{ws})	22.5	%

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	3/22/2017
Sampling Location	EFB Boiler	Project #	11542
Operators	AL	Run #	1
Test Method	23	Impinger Bucket #	3

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		Ko MT	DI	DI	MT	SG		
Initial Value	(Vi),(Wi)	371.3	652.4	647.5	607.4	845.6		
Final Value	(Vf),(Wf)	856.0	653.2	645.5	607.1	881.5		
Net Value	(Vn),(Wn)	484.7	0.8	-2.0	-0.3	35.9		

Train Prepared by: C. HORTON

Train Recovered by: C. HORTON

20.4%

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GAEC	Date	3/22/17
Sampling Location	Stock	Project #	11542
Operators	AL	Run #	2
Test Method	23	Impinger Bucket #	3

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
Contents		MT	DI	DI	MT	SG		
Initial Value	(Vi),(Wi)	373.7	653.2	645.5	607.1	999.3		
Final Value	(Vf),(Wf)	874.6	656.6	645.5	608.3	949.2		
Net Value	(Vn),(Wn)	500.9	3.4	0.0	1.2	39.9		

Train Prepared by: C. Horton

Train Recovered by: *C. Horton*

21.5 % BWS

**C.E.M. SOLUTIONS
IMPINGER TRAIN DATA SHEET**

Plant Name	GREC	Date	3/23/17
Sampling Location	Boiler Stack	Project #	11542
Operators	AL	Run #	3
Test Method	23	Impinger Bucket #	13

		Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
		(K _o)						
Contents		MT	DI	DI	MT	SG		
Initial Value	(V _i),(W _i)	353.3	669.2	625.2	606.5	917.5		
Final Value	(V _f),(W _f)	911.5	669.7	627.4	607.5	957.8		
Net Value	(V _n),(W _n)	558.2	0.5	2.2	1.0	40.3		

Train Prepared by: C. Horton

Train Recovered by: C. Horton

22.5% Dws

Appendix E-9: Method 9

Data Summary
Field Data Sheets
VE Observers Certificate



VISIBLE EMISSION OBSERVATION FORM

SOURCE INFORMATION			Date		OBSERVATION RECORD									
Facility Name: GREC			Date: 3/22/2017		Stack A				Stack B					
Source Name: Boiler Stack			Permit Number: 0010131-008-AV		Hour	Minute	0	15	30	45	0	15	30	45
Location Address: 17201 NW vs Hwy 441					14:10	0	0	0	0	0				
City: Gainesville			State: FL			1	0	0	0	0				
Unit Load: None			Zip: 32653			2	0	0	0	0				
Fuel Type: Wood			Operating Mode: Normal			3	0	0	0	0				
Control Equipment:			Permitted Rate:			4	0	0	0	0				
Describe Emission Point: Tall steel stack						5	0	0	0	0				
PLUME INFORMATION			START		END									
Describe Emissions (Smoke, Dust, Heat Trace, etc.)			None		Same									
Height of Emission Point (ft)			~200		"									
Height Relative to Observer (ft)			~184		"									
Distance from Observer (ft)			~600		"									
Direction to Source			SE		"									
Plume Type (Continuous, Intermittent, Fugitive, etc.)			Continuous		"									
Plume Color			Clear		"									
Water Droplets Present?			NO		"									
Plume Attached or Detached?			-		"									
Angle of Inclination (°)			12°		"									
Description of Background (Sky, Trees, Building, etc.)			sky		"									
Color of Background			Blue		"									
Condition of Sky (Clear, Scattered, Broken, Overcast)			Clear		"									
Wind Speed (mph)			9 mph		"									
Wind Direction (From)			NW		"									
Ambient Temp (°F)			82°F		82°F									
<div style="text-align: center;"> <p>North Direction</p> <p>140°</p> <p>Sun Location</p> <p>Observer's Position</p> <p>Emission Point</p> </div>														
KEY: SUN WIND PLUME														
Comments														
Range of Opacity Readings (%)			Minimum		0									
			Maximum		0									
Average Opacity for 24 Readings =					0.0 %									
Observer's Name (print)			Date		1500									
Observer's Signature					3/22/2017									
Organization														
Certified By														
Certification Date														



VISIBLE EMISSIONS EVALUATOR

Charles Horton

This is to certify that the above named observer has met the specifications of Federal Reference Method 9 and is qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates, Inc. of Raleigh, N.C. This certificate is valid for six months from date of issue.

444542

Certificate #

HOR964452

Student ID Number

2/1/2017

Date of Certification

Orlando, FL

Location

8/3/2017

Certification Expiration Date

TMPF12

Last Lecture

Marty Hughes

Director of Training

Appendix F: Laboratory Reports

C.E.M. Solutions, Inc.

1183 E. Overdrive Circle
Hernando, FL 34442

GREC Boiler Compliance
Project # 11542

Analytical Report
(0317-144)

EPA Method 26A

Hydrogen chloride and Hydrogen fluoride

EPA CTM-027

Ammonia

NCASI Method 8A (HPLC/IC)

Sulfuric acid mist



Enthalpy Analytical, Inc.

Phone: (919) 850 - 4392 / Fax: (919) 850 - 9012 / www.enthalpy.com
800-1 Capitola Drive Durham, NC 27713-4385

I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)

This analytical report was prepared in Portable Document Format (.PDF) and contains ??? pages.

Report Issued: xx/xx/xxxx



Summary of Results

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 1. EPA Method 26A

Client No.: 11542

Summary Table

	Catch Weight μ g	
	Compound	
<u>Sample ID</u>	Hydrogen chloride	Hydrogen fluoride
M26A-Imp12BH - Run 1	142 J	66.3 ND
M26A-Imp12BH - Run 2	191 J	63.2 ND
M26A-Imp12BH - Run 3	156 J	69.5 ND
H2SO4 Blank	68.9 ND	70.6 ND
	Concentration mg/L	
Audit Lot# 101315B	19.6	18.1

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 2. EPA CTM-027

Client No.: 11542

Summary Table - Ammonia

<u>Sample ID</u>	<u>Catch Weight μg</u>
Run 1	327
Run 2	347
Run 3	354
BLANK	4.80 ND

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 3. NCASI Method 8A (HPLC/ IC)

Client No.: 11542

Summary Table - Sulfuric acid Mist

<u>Sample ID</u>	<u>Catch Weight μg</u>
8A-Condensate Rinse - Run 1	51.2 J
8A-Condensate Rinse - Run 2	60.1 J
8A-Condensate Rinse - Run 3	51.8
DI H2O Blank	7.69 ND

Results

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 1. EPA Method 26A

Client No.: 11542

Chloride as Hydrogen Chloride

Sample ID	Filename #1	Filename #2	Analysis Method	Curve Min	Curve Max	MDL	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	DF	Liquid Vol (mL)	Conv Factor	Catch Weight (ug)	Flag	pH
M26A-Imp1,2,BH - Run 1	023-1001.D	023-1002.D	Nelson725.M	1.00	30.00	0.100	4.09	4.09	0.0	0.218	0.221	0.8	0.220	1	630	1.028	142	J	0
M26A-Imp1,2,BH - Run 2	024-1101.D	024-1102.D	Nelson725.M	1.00	30.00	0.100	4.09	4.10	0.0	0.318	0.302	2.6	0.310	1	600	1.028	191	J	0
M26A-Imp1,2,BH - Run 3	025-1201.D	025-1202.D	Nelson725.M	1.00	30.00	0.100	4.09	4.09	0.0	0.232	0.227	0.9	0.230	1	660	1.028	156	J	0
H2SO4 Blank	026-1301.D	026-1302.D	Nelson725.M	1.00	30.00	0.100				0.100	0.100	0.0	0.100	1	670	1.028	68.9	ND	0
Sample ID	Filename #1	Filename #2	Analysis Method	Curve Min	Curve Max	MDL	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	DF	Liquid Vol (mL)	Conv Factor	Conc mg/L	Flag	pH
Audit Lot#: 101315B	029-1601.D	029-1602.D	Nelson725.M	1.00	30.00	0.100	4.15	4.14	0.0	18.9	19.1	0.5	19.0	1	1000	1.028	19.6		

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 1. EPA Method 26A

Client No.: 11542

Fluoride as Hydrogen Fluoride

Sample ID	Filename #1	Filename #2	Analysis Method	Curve Min	Curve Max	MDL	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	DF	Liquid Vol (mL)	Conv Factor	Catch Weight (ug)	Flag	pH
M26A-Imp1,2,BH - Run 1	023-1001.D	023-1002.D	Nelson725.M	1.00	30.00	0.100				0.100	0.100	0.0	0.100	1	630	1.053	66.3	ND	0
M26A-Imp1,2,BH - Run 2	024-1101.D	024-1102.D	Nelson725.M	1.00	30.00	0.100				0.100	0.100	0.0	0.100	1	600	1.053	63.2	ND	0
M26A-Imp1,2,BH - Run 3	025-1201.D	025-1202.D	Nelson725.M	1.00	30.00	0.100				0.100	0.100	0.0	0.100	1	660	1.053	69.5	ND	0
H2SO4 Blank	026-1301.D	026-1302.D	Nelson725.M	1.00	30.00	0.100				0.100	0.100	0.0	0.100	1	670	1.053	70.6	ND	0

Sample ID	Filename #1	Filename #2	Analysis Method	Curve Min	Curve Max	MDL	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	DF	Liquid Vol (mL)	Conv Factor	Conc mg/L	Flag	pH
Audit Lot#: 101315B	029-1601.D	029-1602.D	Nelson725.M	1.00	30.00	0.100	2.93	2.93	0.1	17.4	17.0	1.3	17.2	1	1000	1.053	18.1		

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 1. EPA Method 26A

Client No.: 11542

Matrix Spike Recovery

Sample ID	Compound	Filename #1	Filename #2	Analysis Method	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	Flag	DF	vol mL	Mass (ug)	Recov %	
MS / M26A-Imp1,2,BH - Run 1	Chloride	027-1401.D	027-1402.D	Nelson725.M	4.08	4.08	0.0	10.4	10.3	0.3	10.4		1	5.00	51.8		
M26A-Imp1,2,BH - Run 1	Chloride	023-1001.D	023-1002.D	Nelson725.M	4.09	4.09	0.0	0.218	0.221	0.8	0.220		1	4.50	0.988		
															Mass Spiked:	50.0	102
MSD / M26A-Imp1,2,BH - Run 1	Chloride	028-1501.D	028-1502.D	Nelson725.M	4.08	4.08	0.0	10.5	10.5	0.1	10.5		1	5.00	52.5		
M26A-Imp1,2,BH - Run 1	Chloride	023-1001.D	023-1002.D	Nelson725.M	4.09	4.09	0.0	0.218	0.221	0.8	0.220		1	4.50	0.988		
															Mass Spiked:	50.0	103

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 1. EPA Method 26A

Client No.: 11542

Matrix Spike Recovery

Sample ID	Compound	Filename #1	Filename #2	Analysis Method	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	Flag	DF	vol mL	Mass (ug)	Recov %	
MS / M26A-Imp1,2,BH - Run 1	Fluoride	027-1401.D	027-1402.D	Nelson725.M	2.93	2.92	0.2	10.1	10.7	2.7	10.4		1	5.00	52.1		
M26A-Imp1,2,BH - Run 1	Fluoride	023-1001.D	023-1002.D	Nelson725.M	NA	NA	NA	0.100	0.100	NA	0.100	ND	1	4.50	0.00		
															Mass Spiked:	50.0	104
MSD / M26A-Imp1,2,BH - Run 1	Fluoride	028-1501.D	028-1502.D	Nelson725.M	2.93	2.93	0.0	10.4	10.3	0.7	10.3		1	5.00	51.7		
M26A-Imp1,2,BH - Run 1	Fluoride	023-1001.D	023-1002.D	Nelson725.M	NA	NA	NA	0.100	0.100	NA	0.100	ND	1	4.50	0.00		
															Mass Spiked:	50.0	103

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 2. EPA CTM-027

Client No.: 11542

Ammonia

Sample ID	Filename #1	Filename #2	Analysis Method	Curve Min	Curve Max	MDL	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	DF	Liquid Vol (mL)	Catch Weight (ug)	Flag	pH
CTM027-Imp1,BH - Run 1	011-1101.D	011-1102.D	Curly329.M	0.200	12.3	0.0200	4.22	4.23	0.1	0.739	0.746	0.5	0.743	1	440	327		0
CTM027-Imp2 - Run 1	014-1401.D	014-1402.D	Curly329.M	0.200	12.3	0.0200	4.19	4.19	0.0	0.0200	0.0200	0.0	0.0200	1	190	3.80	ND	0
																327		
CTM027-Imp1,BH - Run 2	012-1201.D	012-1202.D	Curly329.M	0.200	12.3	0.0200	4.23	4.22	0.1	0.817	0.821	0.3	0.819	1	420	344		0
CTM027-Imp2 - Run 2	015-1501.D	015-1502.D	Curly329.M	0.200	12.3	0.0200	4.18	4.20	0.3	0.0200	0.0217	4.0	0.0208	1	150	3.13	J	0
																347		
CTM027-Imp1,BH - Run 3	013-1301.D	013-1302.D	Curly329.M	0.200	12.3	0.0200	4.23	4.23	0.0	0.814	0.813	0.1	0.813	1	435	354		0
CTM027-Imp2 - Run 3	016-1601.D	016-1602.D	Curly329.M	0.200	12.3	0.0200	4.18	4.20	0.2	0.0200	0.0200	0.0	0.0200	1	180	3.60	ND	0
																354		
H2SO4 Blank + Impinger Rinse	017-1701.D	017-1702.D	Curly329.M	0.200	12.3	0.0200	4.19	4.20	0.1	0.0200	0.0200	0.0	0.0200	1	240	4.80	ND	0

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 2. EPA CTM-027

Client No.: 11542

Matrix Spike Recovery

Sample ID	Compound	Sequence	Filename #1	Filename #2	Analysis Method	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	Flag	DF	vol mL	Mass (ug)	Recov %
MS / CTM027-Imp1,BH - Run 1	Ammonia	Curly329.v4	018-1801.D	018-1802.D	Curly329.M	4.24	4.24	0.0	2.93	2.94	0.2	2.94		1	0.520	1.53	
CTM027-Imp1,BH - Run 1	Ammonia	Curly329.v4	011-1101.D	011-1102.D	Curly329.M	4.22	4.23	0.1	0.739	0.746	0.5	0.743		1	0.500	0.371	
																Mass Spiked: 1.89	61.2
MSD / CTM027-Imp1,BH - Run 1	Ammonia	Curly329.v4	019-1901.D	019-1902.D	Curly329.M	4.24	4.23	0.1	2.93	2.91	0.4	2.92		1	0.520	1.52	
CTM027-Imp1,BH - Run 1	Ammonia	Curly329.v4	011-1101.D	011-1102.D	Curly329.M	4.22	4.23	0.1	0.739	0.746	0.5	0.743		1	0.500	0.371	
																Mass Spiked: 1.89	60.7

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 3. NCASI Method 8A (HPLC/ IC)

Client No.: 11542

Sulfate as Sulfuric Acid

Sample ID	Filename #1	Filename #2	Analysis Method	Curve Min	Curve Max	MDL	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	DF	Liquid Vol (mL)	Conv Factor	Catch Weight (ug)	Flag	pH
8A-Condensate Rinse - Run 1	021-0501.D	021-0502.D	Gonzo230.M	0.495	50.0	0.0554	8.52	8.39	0.8	0.425	0.426	0.1	0.425	1	118	1.021	51.2	J	7
8A-Condensate Rinse - Run 2	OnlineEdited34.D	OnlineEdited35.D	Gonzo235.M	1.00	50.0	0.0554	7.27	7.26	0.0	0.470	0.450	2.2	0.460	1	128	1.021	60.1	J	7
8A-Condensate Rinse - Run 3	023-1301.D	023-1302.D	Gonzo234.M	0.495	50.0	0.0554	8.25	8.25	0.0	0.526	0.531	0.5	0.528	1	96.0	1.021	51.8		7
DI H2O Blank	024-0801.D	024-0802.D	Gonzo230.M	0.495	50.0	0.0554	NA	NA	NA	0.0554	0.0554	NA	0.0554	1	136	1.021	7.69	ND	7

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 3. NCASI Method 8A (HPLC/ IC)

Client No.: 11542

Matrix Spike Recovery

Sample ID	Compound	Filename #1	Filename #2	Analysis Method	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	Flag	DF	vol mL	Mass (ug)	Recov %
MSD / 8A-Condensate Rinse - Run 1	Sulfate	026-1001.D	026-1002.D	Gonzo230.M	8.34	8.51	1.0	2.14	2.29	3.4	2.22		1	0.520	1.15	
8A-Condensate Rinse - Run 1	Sulfate	021-0501.D	021-0502.D	Gonzo230.M	8.52	8.39	0.8	0.425	0.426	0.1	0.425		1	0.500	0.213	
													Mass Spiked:	1.00	94.0	
MS / 8A-Condensate Rinse - Run 1	Sulfate	025-0901.D	025-0902.D	Gonzo230.M	8.51	8.44	0.4	2.19	2.12	1.8	2.16		1	0.520	1.12	
8A-Condensate Rinse - Run 1	Sulfate	021-0501.D	021-0502.D	Gonzo230.M	8.52	8.39	0.8	0.425	0.426	0.1	0.425		1	0.500	0.213	
													Mass Spiked:	1.00	90.8	

Narrative Summary

Enthalpy Analytical Narrative Summary

Company	C.E.M. Solutions, Inc.
Job #	0317-144 – 1. EPA Method 26A
Client #	11542

Custody	<p>Matt Hill of Enthalpy Analytical, Inc. received the samples on 3/28/17 at 2.8 °C after being relinquished by C.E.M. Solutions, Inc. The samples were received in good condition.</p> <p>Prior to, during, and after analysis, the samples were kept under lock with access only to authorized personnel by Enthalpy Analytical, Inc.</p>
Analysis	<p>The samples were analyzed for hydrogen chloride and hydrogen fluoride using the analytical procedures in EPA Method 26A, Determination of Hydrogen Halide and Halogen Emissions from Stationary Sources Isokinetic Method (40 CFR Part 60, Appendix A).</p> <p>The samples were analyzed following the procedures in Section 11.0, Analytical Procedures. All samples and standards are prepared, stored, and analyzed using high-density polyethylene containers.</p> <p>The Metrohm 861, High Performance Liquid Chromatograph ("Nelson") was equipped with a Conductivity Detector for these analyses.</p>
Calibration	<p>The calibration curves are included in the Raw Data section of this report. The data analysis method is referenced in the Analysis Method column on the Detailed Results page.</p> <p>The first page of the curve contains all method specific parameters (i.e., curve type, origin, weight, etc.) used to quantify the samples. The calibration curve section also includes a table with the Retention Time (RetTime), Level (Lvl), Amount (corresponding units), Area, Response Factor (Amt/Area) and the analyte Name. The calibration table is used to identify (by retention time) and quantify each target compound.</p>
Chromatographic Conditions	<p>The acquisition method (METROHM.M) is included in the Raw Data section of this report.</p>
QC Notes	<p>The analyses of the field and laboratory reagent blanks contained no target compounds at concentrations greater than the detection limit.</p>

Enthalpy Analytical Narrative Summary

(continued)

QC Notes (continued)

The samples were analyzed within the four-week holding time specified by the method.

Duplicate matrix spikes were prepared using aliquots of sample **M26A-Imp1,2,BH - Run 1** and exhibited spike recovery values of the 102% and 103% for chloride and 103% and 104% for fluoride.

The analyses of the second source standards served as the laboratory control samples and exhibited spike recovery values of 99.3% and 102%.

The Stationary Source Audit Sample (SSAS) **Lot# 101315B** was received and analyzed along with these samples.

Reporting Notes

The sulfuric acid matrix samples were analyzed for chloride and fluoride but are reported as hydrogen chloride and hydrogen fluoride. The results were converted using a conversion factor of 1.028 for hydrogen chloride and 1.053 for hydrogen fluoride.

The SSAS was reported on a concentration basis (mg/L).

The results presented in this report are representative of the samples as provided to the laboratory.

These analyses met the requirements of the TNI Standard. Any deviations from the requirements of the reference method or TNI Standard have been stated above.

Enthalpy Analytical Narrative Summary

Company	C.E.M. Solutions, Inc.
Job #	0317-144 – 2. EPA CTM-027
Client #	11542

Custody	<p>Matt Hill of Enthalpy Analytical, Inc. received the samples on 3/28/17 at 2.8 °C after being relinquished by C.E.M. Solutions, Inc. The samples were received in good condition.</p> <p>Prior to, during, and after analysis, the samples were kept under lock with access only to authorized personnel by Enthalpy Analytical, Inc.</p>
Analysis	<p>The samples were analyzed for ammonia using the analytical procedures in EPA Conditional Test Method 027, Procedure for Collection and Analysis of Ammonia in Stationary Sources.</p> <p>The samples were analyzed following the procedures in Section 4.2, Sample Analysis.</p> <p>The Agilent Model 1100, High Performance Liquid Chromatograph ("Curly") was equipped with a Conductivity Detector for these analyses.</p>
Calibration	<p>The calibration curve is included in the Raw Data section of this report. The data analysis method is referenced in the Analysis Method column on the Detailed Results page.</p> <p>The first page of the curve contains all method specific parameters (i.e., curve type, origin, weight, etc.) used to quantify the samples. The calibration curve section also includes a table with the Retention Time (RetTime), Level (Lvl), Amount (corresponding units), Area, Response Factor (Amt/Area) and the analyte Name. The calibration table is used to identify (by retention time) and quantify each target compound.</p>
Chromatographic Conditions	<p>The acquisition methods (ENV_AMM_18MM.M and CATIONS.M) are included in the Raw Data section of this report.</p>
QC Notes	<p>The analyses of the field and laboratory reagent blanks contained no ammonia at concentrations greater than the LOQ.</p> <p>The analysis of the second source standard also served as the laboratory control sample and exhibited a spike recovery value of 98%.</p>

Enthalpy Analytical Narrative Summary (continued)

QC Notes (continued)

Duplicate matrix spikes were prepared using aliquots of sample *CTM027-Imp1,BH - Run 1* and exhibited spike recovery values of 61.2% and 60.7%. The matrix spikes were repeated using alternate sample aliquots with similar spike recovery results. The initial analysis of the matrix spikes have been included in this report.

The samples were analyzed within the two week holding time specified by the method.

Reporting Notes

The results presented in this report are representative of the samples as provided to the laboratory.

These analyses met the requirements of the TNI Standard. Any deviations from the requirements of the reference method or TNI Standard have been stated above.

Enthalpy Analytical Narrative Summary

Company	C.E.M. Solutions, Inc.
Job #	0317-144 – 3. NCASI Method 8A (HPLC/IC)
Client #	11542

Custody	<p>Matt Hill of Enthalpy Analytical, Inc. received the samples on 3/28/17 at 2.8 °C after being relinquished by C.E.M. Solutions, Inc. The samples were received in good condition.</p> <p>Prior to, during, and after analysis, the samples were kept under lock with access only to authorized personnel by Enthalpy Analytical, Inc.</p>
Analysis	<p>The samples were analyzed for sulfuric acid mist using the analytical procedures in NCASI Method 8A (HPLC/IC) Analysis, Determination of Sulfuric Acid Vapor or Mist and Sulfur Dioxide Emissions from Kraft Recovery Furnaces.</p> <p>The Agilent Model 1100, High Performance Liquid Chromatograph ("Gonzo") was equipped with a Conductivity Detector for these analyses.</p>
Calibration	<p>The calibration curve is included in the Raw Data section of this report. The data analysis method is referenced in the Analysis Method column on the Detailed Results page.</p> <p>The first page of the curve contains all method specific parameters (i.e., curve type, origin, weight, etc.) used to quantify the samples. The calibration curve section also includes a table with the Retention Time (RetTime), Level (Lvl), Amount (corresponding units), Area, Response Factor (Amt/Area) and the analyte Name. The calibration table is used to identify (by retention time) and quantify each target compound.</p>
Chromatographic Conditions	<p>The acquisition method (ANIONS!.M) is included in the Raw Data section of this report.</p>
QC Notes	<p>The analyses of the field and laboratory reagent blanks contained no sulfuric acid at concentrations greater than the detection limit.</p> <p>Duplicate matrix spikes were prepared using aliquots of sample 8A-Condensate Rinse - Run 1. The matrix spikes were analyzed in the same manner as the samples and exhibited spike recovery values of 94.0% and 90.8%. All sample preparation and analytical holding times specified in the method were met.</p>



Enthalpy Analytical Narrative Summary (continued)

QC Notes (continued)

The analyses of the second source standard served as the laboratory control samples and exhibited spike recovery values within 10% of the expected value.

Reporting Notes

The samples were analyzed for sulfate but were reported as sulfuric acid mist. The sulfuric acid mist results were calculated using a conversion factor of 1.021 to account for the additional mass.

The results presented in this report are representative of the samples as provided to the laboratory.

These analyses met the requirements of the TNI Standard. Any deviations from the requirements of the reference method or TNI Standard have been stated above.

General Reporting Notes

The following are general reporting notes that are applicable to all Enthalpy Analytical, Inc. data reports, unless specifically noted otherwise.

- Any analysis which refers to the method as “*Type*” represents a planned deviation from the reference method. For instance a Hydrogen Sulfide assay from a Tedlar bag would be labeled as “EPA Method 16-*Type*” because Tedlar bags are not mentioned as one of the collection options in EPA Method 16.
- The acronym *MDL* represents the Minimum Detection Limit. Below this value the laboratory cannot determine the presence of the analyte of interest reliably.
- The acronym *LOQ* represents the Limit of Quantification. Below this value the laboratory cannot quantitate the analyte of interest within the criteria of the method.
- The acronym *ND* following a value indicates a non-detect or analytical result below the MDL.
- The letter *J* in the Qualifier or Flag column in the results indicates that the value is between the MDL and the LOQ. The laboratory can positively identify the analyte of interest as present, but the value should be considered an estimate.
- The letter *E* in the Qualifier or Flag column indicates an analytical result exceeding 100% of the highest calibration point. The associated value should be considered as an estimate.
- The acronym *DF* represents Dilution Factor. This number represents dilution of the sample during the preparation and/or analysis process. The analytical result taken from a laboratory instrument is multiplied by the DF to determine the final undiluted sample results.
- The addition of *MS* to the Sample ID represents a Matrix Spike. An aliquot of an actual sample is spiked with a known amount of analyte so that a percent recovery value can be determined. The MS analysis indicates what effect the sample matrix may have on the target analyte, i.e. whether or not anything in the sample matrix interferes with the analysis of the analyte(s).
- The addition of *MSD* to the Sample ID represents a Matrix Spike Duplicate. Prepared in the same manner as a MS, the use of duplicate matrix spikes allows further confirmation of laboratory quality by showing the consistency of results gained by performing the same steps multiple times.
- The addition of *LD* to the Sample ID represents a Laboratory Duplicate. The analyst prepares an additional aliquot of sample for testing and the results of the duplicate analysis are compared to the initial result. The result should have a difference value of within 10% of the initial result (if the results of the original analysis are greater than the LOQ).

General Reporting Notes

(continued)

- The addition of **AD** to the Sample ID represents an Alternate Dilution. The analyst prepares an additional aliquot at a different dilution factor (usually double the initial factor). This analysis helps confirm that no additional compound is present and coeluting or sharing absorbance with the analyte of interest, as they would have a different response/absorbance than the analyte of interest.
- The Sample ID **LCS** represents a Laboratory Control Sample. Clean matrix, similar to the client sample matrix, prepared and analyzed by the laboratory using the same reagents, spiking standards and procedures used for the client samples. The LCS is used to assess the control of the laboratory's analytical system. Whenever spikes are prepared for our client projects, two spikes are retained as LCSs. The LCSs are labeled with the associated project number and kept in-house at the appropriate temperature conditions. When the project samples are received for analysis, the LCSs are analyzed to confirm that the analyte could be recovered from the media, separate from the samples which were used on the project and which may have been affected by source matrix, sample collection and/or sample transport.
- **Significant Figures:** Where the reported value is much greater than unity (1.00) in the units expressed, the number is rounded to a whole number of units, rather than to 3 significant figures. For example, a value of 10,456.45 ug catch is rounded to 10,456 ug. There are five significant digits displayed, but no confidence should be placed on more than two significant digits.
- **Manual Integration:** The data systems used for processing will flag manually integrated peaks with an "M". There are several reasons a peak may be manually integrated. These reasons will be identified by the following two letter designations on sample chromatograms, if provided in the report. The peak was *not integrated* by the software "**NI**", the peak was *integrated incorrectly* by the software "**II**" or the *wrong peak* was integrated by the software "**WP**". These codes will accompany the analyst's manual integration stamp placed next to the compound name on the chromatogram.

Sample Custody



1183 E. Overdrive Circle • Hernando, FL 34442 • Ph: (352) 489-4337 • Fax: (352) 489-4801

www.cem-solutions.com

Chain of Custody Record

Project # 11542		Project Name: GREC Boiler Compliance				# of Containers	MM26 Impinger 1 and 2 + BH	NH3 Impinger 1 + BH	NH3 Impinger 2	SAM Condenser Rinse	Audit Sample	Blank	Comments
Samplers: CRH/MB/TC/AL													
Sample ID	Date	Test Method	Comp.	Grab	Sample Location								
Run 1	3/22/2017	MM26	X		Boiler Stack	1	x						HCl and HF
Run 2	3/22/2017	MM26	X		Boiler Stack	1	x						HCl and HF
Run 3	3/23/2017	MM26	X		Boiler Stack	1	x						HCl and HF
Audit	3/23/2017	MM26		X	ERA Project #101315B	1					*		
Run 1	3/24/2017	CTM-027	X		Boiler Stack	2		x	x				
Run 2	3/24/2017	CTM-027	X		Boiler Stack	2		x	x				
Run 3	3/24/2017	CTM-027	X		Boiler Stack	2		x	x				
Run 1	3/24/2017	8A	X		Boiler Stack	1				x			
Run 2	3/24/2017	8A	X		Boiler Stack	1				x			
Run 3	3/24/2017	8A	X		Boiler Stack	1				x			
Blank	3/24/2017	MM26	X		0.1N H2SO4 + DI H2O	1						x	
Blank	3/24/2017	8A	X		DI H2O	1						x	
Blank	3/24/2017	CTM-027	X		0.1N H2SO4 + Impinger rinse	1						x	
Relinquished by:	Date:	Time:	Received By:			Relinquished By:	Date:	Time:	Received By:				
<i>[Signature]</i>	3/27/17	9:40	<i>[Signature]</i>			<i>[Signature]</i>	3/28/17	9:05	<i>[Signature]</i>				
Relinquished by:	Date:	Time:	Received By:			Relinquished By:	Date:	Time:	Received By:				
<i>[Signature]</i>			<i>[Signature]</i>			<i>[Signature]</i>	3/28/17	9:05	<i>[Signature]</i>				
Received for Lab By:	Date:	Time:	Remarks:										
			CTM-027 stored on Ice										

Received in good condition.
 Samples on ice received at 2.8°C (G2)
 on wet ice
 MWH 3/28/17

Raw Data

**EPA Method 26A
Hydrogen Chloride
Hydrogen Fluoride
Raw Data**

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 1. EPA Method 26A

Client No.: 11542

Chloride -- Calibration Standards, Laboratory Blanks and Controls

Sample ID	Filename #1	Filename #2	Analysis Method	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	Standard Tag (ug/mL)	%Tag
HPLCStds420 #5	005-0201.D	005-0202.D	Nelson725.M	4.14	4.13	0.1	30.0	29.8	0.3	29.9	30.0	99.6
HPLCStds420 #4	004-0301.D	004-0302.D	Nelson725.M	4.14	4.14	0.0	15.0	15.0	0.1	15.0	15.0	100
HPLCStds420 #3	003-0401.D	003-0402.D	Nelson725.M	4.14	4.14	0.0	10.0	10.1	0.2	10.1	10.0	101
HPLCStds420 #2	002-0501.D	002-0502.D	Nelson725.M	4.15	4.15	0.0	4.99	4.95	0.4	4.97	5.00	99.4
HPLCStds420 #1	001-0601.D	001-0602.D	Nelson725.M	4.17	4.17	0.0	1.00	0.999	0.1	1.00	1.00	100
HPLCStds420 #SS	006-0701.D	006-0702.D	Nelson725.M	4.13	4.13	0.0	7.44	7.45	0.1	7.45	7.50	99.3
HPLCStds420 #NIST	007-0801.D	007-0802.D	Nelson725.M	4.15	4.14	0.1	10.2	10.1	0.0	10.1	9.99	102
HPLCStds420 #RB	008-0901.D	008-0902.D	Nelson725.M	NA	NA	NA	0.100	0.100	NA	0.100	NA	NA
HPLCStds420 #3	101-2001.D	101-2002.D	Nelson725.M	4.14	4.14	0.0	10.1	10.0	0.4	10.1	10.0	101
HPLCStds420 #5	005-3701.D	005-3702.D	Nelson725.M	4.12	4.12	0.0	30.0	30.0	0.0	30.0	30.0	99.9
HPLCStds420 #4	004-3801.D	004-3802.D	Nelson725.M	4.14	4.13	0.0	15.1	15.0	0.1	15.1	15.0	100
HPLCStds420 #3	003-3901.D	003-3902.D	Nelson725.M	4.14	4.14	0.0	10.1	10.1	0.1	10.1	10.0	101
HPLCStds420 #2	002-4001.D	002-4002.D	Nelson725.M	4.15	4.15	0.0	4.95	4.92	0.3	4.94	5.00	98.7
HPLCStds420 #1	001-4101.D	001-4102.D	Nelson725.M	4.16	4.16	0.0	1.01	0.991	1.1	1.00	1.00	100

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 1. EPA Method 26A

Client No.: 11542

Fluoride -- Calibration Standards, Laboratory Blanks and Controls


Sample ID	Filename #1	Filename #2	Analysis Method	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	Standard Tag	%Tag
HPLCStd420 #5	005-0201.D	005-0202.D	Nelson725.M	2.95	2.94	0.1	29.6	30.2	0.9	29.9	30.0	99.8
HPLCStd420 #4	004-0301.D	004-0302.D	Nelson725.M	2.93	2.93	0.0	14.9	14.8	0.1	14.9	15.0	99.0
HPLCStd420 #3	003-0401.D	003-0402.D	Nelson725.M	2.91	2.92	0.2	10.4	9.94	2.4	10.2	10.0	102
HPLCStd420 #2	002-0501.D	002-0502.D	Nelson725.M	2.92	2.91	0.2	4.85	5.22	3.6	5.04	5.00	101
HPLCStd420 #1	001-0601.D	001-0602.D	Nelson725.M	2.93	2.93	0.0	1.00	0.996	0.2	0.998	1.00	99.8
HPLCStd420 #SS	006-0701.D	006-0702.D	Nelson725.M	2.91	2.92	0.2	3.92	3.58	4.5	3.75	3.75	99.9
HPLCStd420 #NIST	007-0801.D	007-0802.D	Nelson725.M	NA	NA	NA	0.100	0.100	NA	0.100	NA	NA
HPLCStd420 #RB	008-0901.D	008-0902.D	Nelson725.M	NA	NA	NA	0.100	0.100	NA	0.100	NA	NA
HPLCStd420 #3	101-2001.D	101-2002.D	Nelson725.M	2.93	2.92	0.2	9.77	10.3	2.5	10.0	10.0	100.2
HPLCStd420 #5	005-3701.D	005-3702.D	Nelson725.M	2.95	2.95	0.1	30.2	30.0	0.3	30.1	30.0	100.4
HPLCStd420 #4	004-3801.D	004-3802.D	Nelson725.M	2.93	2.93	0.1	14.8	15.2	1.4	15.0	15.0	100.2
HPLCStd420 #3	003-3901.D	003-3902.D	Nelson725.M	2.93	2.93	0.0	9.92	9.84	0.4	9.88	10.0	98.8
HPLCStd420 #2	002-4001.D	002-4002.D	Nelson725.M	2.91	2.93	0.2	5.16	4.78	3.8	4.97	5.00	99.4
HPLCStd420 #1	001-4101.D	001-4102.D	Nelson725.M	2.93	2.91	0.4	0.973	1.06	4.2	1.02	1.00	102

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #5
Sequence Name Nelson725 ver.4
Inj Data File 005-0201.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 4:24 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 5
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.95	856.805	79.9957	29.6491	1	29.6491	ug/mL
Chloride	BB	4.14	609.265	54.0677	29.9545	1	29.9545	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #5
Sequence Name Nelson725 ver.4
Inj Data File 005-0202.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 4:38 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 5
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.94	871.624	82.8075	30.2086	1	30.2086	ug/mL
Chloride	BB	4.13	605.814	53.7591	29.7968	1	29.7968	ug/mL

Analyst Peak Integration Comments


15:24:34 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #4
Sequence Name Nelson725 ver.4
Inj Data File 004-0301.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 4:53 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 4
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.93	444.894	42.6290	14.8652	1	14.8652	ug/mL
Chloride	BB	4.14	292.651	25.5406	14.9953	1	14.9953	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #4
Sequence Name Nelson725 ver.4
Inj Data File 004-0302.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 5:08 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 4
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.93	444.044	42.6022	14.8361	1	14.8361	ug/mL
Chloride	BB	4.14	293.288	25.7294	15.0265	1	15.0265	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #3
Sequence Name Nelson725 ver.4
Inj Data File 003-0401.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 5:23 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 3
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.91	313.295	31.5081	10.4177	1	10.4177	ug/mL
Chloride	BB	4.14	192.671	16.6237	10.0476	1	10.0476	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #3
Sequence Name Nelson725 ver.4
Inj Data File 003-0402.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 5:37 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 3
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.92	298.874	28.6333	9.93758	1	9.93758	ug/mL
Chloride	BB	4.14	193.410	16.7453	10.0846	1	10.0846	ug/mL

Analyst Peak Integration Comments


15:25:02 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #2
Sequence Name Nelson725 ver.4
Inj Data File 002-0501.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 5:52 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 2
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.92	143.634	13.4610	4.85310	1	4.85310	ug/mL
Chloride	BB	4.15	92.9138	7.94562	4.99045	1	4.99045	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #2
Sequence Name Nelson725 ver.4
Inj Data File 002-0502.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 6:07 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 2
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.91	154.903	15.7726	5.21713	1	5.21713	ug/mL
Chloride	BB	4.15	92.0512	7.81881	4.94618	1	4.94618	ug/mL

Analyst Peak Integration Comments


15:25:26 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #1
Sequence Name Nelson725 ver.4
Inj Data File 001-0601.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 6:22 PM
File Modified 4/6/2017 3:51 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 1
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:51 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.93	23.1789	1.90740	0.99997	1	0.99997	ug/mL
Chloride	MM	4.17	15.9241	1.29662	1.00072	1	1.00072	ug/mL

Analyst Peak Integration Comments


15:26:12 04/06/17 Scott Wilson II
15:51:09 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #1
Sequence Name Nelson725 ver.4
Inj Data File 001-0602.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 6:36 PM
File Modified 4/6/2017 3:51 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 1
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:51 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.93	22.9843	1.89464	0.99574	1	0.99574	ug/mL
Chloride	MM	4.17	15.8506	1.31343	0.99853	1	0.99853	ug/mL

Analyst Peak Integration Comments


15:26:55 04/06/17 Scott Wilson II
15:51:22 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #SS
Sequence Name Nelson725 ver.4
Inj Data File 006-0701.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 6:51 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Control
Vial Number 6
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.91	114.549	11.6891	3.91706	1	3.91706	ug/mL
Chloride	BB	4.13	140.942	12.6661	7.44082	1	7.44082	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #SS
Sequence Name Nelson725 ver.4
Inj Data File 006-0702.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 7:06 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Control
Vial Number 6
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.92	103.942	9.64631	3.57696	1	3.57696	ug/mL
Chloride	BB	4.13	141.142	12.7300	7.45097	1	7.45097	ug/mL

Analyst Peak Integration Comments


15:34:52 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #NIST
Sequence Name Nelson725 ver.4
Inj Data File 007-0801.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 7:21 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Control
Vial Number 7
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride	BB	4.15	194.742	16.6210	10.1513	1	10.1513	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #NIST
Sequence Name Nelson725 ver.4
Inj Data File 007-0802.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 7:35 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Control
Vial Number 7
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride	BB	4.14	194.655	16.4914	10.1469	1	10.1469	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStds420 #RB
Sequence Name Nelson725 ver.4
Inj Data File 008-0901.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 7:50 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Control
Vial Number 8
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride		(4.16)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #RB
Sequence Name Nelson725 ver.4
Inj Data File 008-0902.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 8:05 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Control
Vial Number 8
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride		(4.16)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R1.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 023-1001.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 8:20 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 23
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride	MM	4.09	3.47077	0.37087	0.21781	1	0.21781	ug/mL

Analyst Peak Integration Comments


15:35:25 04/06/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R1.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 023-1002.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 8:34 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 23
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride	MM	4.09	3.52659	0.36958	0.22131	1	0.22131	ug/mL

Analyst Peak Integration Comments


15:35:38 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R2.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 024-1101.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 8:49 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 24
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride	MM	4.09	5.06114	0.52610	0.31761	1	0.31761	ug/mL

Analyst Peak Integration Comments


15:36:17 04/06/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R2.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 024-1102.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 9:04 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 24
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride	MM	4.10	4.80809	0.49737	0.30173	1	0.30173	ug/mL

Analyst Peak Integration Comments


15:36:30 04/06/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R3.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 025-1201.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 9:19 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 25
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride	MM	4.09	3.69093	0.39016	0.23162	1	0.23162	ug/mL

Analyst Peak Integration Comments


15:36:45 04/06/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R3.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 025-1202.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 9:33 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 25
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride	MM	4.09	3.62387	0.39033	0.22741	1	0.22741	ug/mL

Analyst Peak Integration Comments


15:36:56 04/06/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.BLANK.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 026-1301.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 9:48 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 26
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride		(4.16)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.BLANK.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 026-1302.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 10:03 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 26
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride		(2.92)				1		ug/mL
Chloride		(4.16)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MS-R1.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 027-1401.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 10:18 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 27
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MF	2.93	304.785	29.4320	10.1342	1	10.1342	ug/mL
Chloride	BB	4.08	199.637	21.5927	10.3961	1	10.3961	ug/mL

Analyst Peak Integration Comments


15:37:49 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MS-R1.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 027-1402.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 10:32 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 27
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MF	2.92	321.710	32.3808	10.6986	1	10.6986	ug/mL
Chloride	BB	4.08	198.523	21.1726	10.3405	1	10.3405	ug/mL

Analyst Peak Integration Comments


15:37:35 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MSD-R1.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 028-1501.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 10:47 PM
File Modified 4/6/2017 3:47 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 28
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MF	2.93	312.955	30.0485	10.4064	1	10.4064	ug/mL
Chloride	BB	4.08	201.422	21.6181	10.4854	1	10.4854	ug/mL

Analyst Peak Integration Comments


15:38:05 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MSD-R1.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 028-1502.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 11:02 PM
File Modified 4/6/2017 3:48 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 28
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MF	2.93	308.771	29.8801	10.2670	1	10.2670	ug/mL
Chloride	BB	4.08	202.028	21.8457	10.5157	1	10.5157	ug/mL

Analyst Peak Integration Comments


15:38:20 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.Audit 101315B.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 029-1601.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 11:17 PM
File Modified 4/6/2017 3:48 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 29
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.93	519.588	50.3961	17.4446	1	17.4446	ug/mL
Chloride	BB	4.15	373.718	31.3848	18.9240	1	18.9240	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.Audit 101315B.H2SO4
Sequence Name Nelson725 ver.4
Inj Data File 029-1602.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/5/2017 11:31 PM
File Modified 4/6/2017 3:48 PM
Instrument Nelson
Operator Scott Wilson

Sample Type Sample
Vial Number 29
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.93	506.800	47.5640	17.0000	1	17.0000	ug/mL
Chloride	BB	4.14	377.682	31.8377	19.1143	1	19.1143	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #3
Sequence Name Nelson725 ver.4
Inj Data File 101-2001.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 1:15 AM
File Modified 4/6/2017 3:48 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 101
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.93	293.765	27.5787	9.76779	1	9.76779	ug/mL
Chloride	BB	4.14	193.942	16.6210	10.1112	1	10.1112	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #3
Sequence Name Nelson725 ver.4
Inj Data File 101-2002.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 1:29 AM
File Modified 4/6/2017 3:48 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 101
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.92	308.712	30.3891	10.2650	1	10.2650	ug/mL
Chloride	BB	4.14	192.375	16.3408	10.0328	1	10.0328	ug/mL

Analyst Peak Integration Comments


15:39:33 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #5
Sequence Name Nelson725 ver.4
Inj Data File 005-3701.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 9:36 AM
File Modified 4/6/2017 3:49 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 5
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.95	871.999	79.4534	30.2228	1	30.2228	ug/mL
Chloride	BB	4.12	609.428	52.5778	29.9620	1	29.9620	ug/mL

Analyst Peak Integration Comments


15:43:21 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #5
Sequence Name Nelson725 ver.4
Inj Data File 005-3702.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 9:51 AM
File Modified 4/6/2017 3:49 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 5
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.95	867.342	77.1637	30.0467	1	30.0467	ug/mL
Chloride	BB	4.12	609.545	52.8763	29.9673	1	29.9673	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #4
Sequence Name Nelson725 ver.4
Inj Data File 004-3801.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 10:06 AM
File Modified 4/6/2017 3:49 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 4
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.93	443.495	40.9337	14.8173	1	14.8173	ug/mL
Chloride	BB	4.14	294.159	25.0939	15.0691	1	15.0691	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #4
Sequence Name Nelson725 ver.4
Inj Data File 004-3802.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 10:20 AM
File Modified 4/6/2017 3:49 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 4
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.93	455.909	43.4166	15.2430	1	15.2430	ug/mL
Chloride	BB	4.13	293.639	24.7348	15.0436	1	15.0436	ug/mL

Analyst Peak Integration Comments


15:43:35 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #3
Sequence Name Nelson725 ver.4
Inj Data File 003-3901.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 10:35 AM
File Modified 4/6/2017 3:49 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 3
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.93	298.267	27.3177	9.91738	1	9.91738	ug/mL
Chloride	BB	4.14	194.030	16.2308	10.1156	1	10.1156	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #3
Sequence Name Nelson725 ver.4
Inj Data File 003-3902.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 10:50 AM
File Modified 4/6/2017 3:49 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 3
Injection Volume 2 of 2
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.93	295.901	27.2316	9.83873	1	9.83873	ug/mL
Chloride	BB	4.14	194.452	16.3437	10.1368	1	10.1368	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #2
Sequence Name Nelson725 ver.4
Inj Data File 002-4001.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 11:05 AM
File Modified 4/6/2017 3:49 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 2
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.91	153.010	14.9277	5.15594	1	5.15594	ug/mL
Chloride	BB	4.15	92.1755	7.52665	4.95255	1	4.95255	ug/mL

Analyst Peak Integration Comments


15:44:13 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #2
Sequence Name Nelson725 ver.4
Inj Data File 002-4002.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 11:19 AM
File Modified 4/6/2017 3:49 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 2
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:47 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.93	141.349	12.7125	4.77939	1	4.77939	ug/mL
Chloride	BB	4.15	91.5569	7.56997	4.92080	1	4.92080	ug/mL

Analyst Peak Integration Comments


15:44:01 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #1
Sequence Name Nelson725 ver.4
Inj Data File 001-4101.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 11:34 AM
File Modified 4/6/2017 3:52 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 1
Injection Volume NA
Injection 1 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:52 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	BB	2.93	22.1570	1.82795	0.97284	1	0.97284	ug/mL
Chloride	MM	4.16	16.2256	1.26763	1.01255	1	1.01255	ug/mL

Analyst Peak Integration Comments


15:44:27 04/06/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd420 #1
Sequence Name Nelson725 ver.4
Inj Data File 001-4102.D
File Location HPLC/2017/Nelson/Quarter 2
Injection Date 4/6/2017 11:49 AM
File Modified 4/6/2017 3:52 PM
Instrument Nelson
Operator Scott Wilson

Sample Type
Vial Number 1
Injection Volume NA
Injection 2 of 2
Acquisition Method METROHM.M
Analysis Method Nelson725.M
Method Modified 4/6/2017 3:52 PM
Printed 4/7/2017 9:07 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Fluoride	MM	2.91	25.2596	2.48888	1.05906	1	1.05906	ug/mL
Chloride	MM	4.16	15.7957	1.22397	0.99125	1	0.99125	ug/mL

Analyst Peak Integration Comments

15:45:00 04/06/17 Scott Wilson II

=====
 Calibration Table
 =====

 General Calibration Setting

Calib. Data Modified : Thursday, April 06, 2017 3:52:29 PM
 Signals calculated separately : No

Rel. Reference Window : 5.000 %
 Abs. Reference Window : 0.000 min
 Rel. Non-ref. Window : 5.000 %
 Abs. Non-ref. Window : 0.000 min
 Uncalibrated Peaks : not reported
 Partial Calibration : Yes, identified peaks are recalibrated
 Correct All Ret. Times: No, only for identified peaks

Curve Type : Linear (some peaks differ, see below)
 Origin : Included (some peaks differ, see below)
 Weight : Equal (some peaks differ, see below)

Recalibration Settings:
 Average Response : Average all calibrations
 Average Retention Time: Floating Average New 75%

Calibration Report Options :
 Printout of recalibrations within a sequence:
 Calibration Table after Recalibration
 Normal Report after Recalibration
 If the sequence is done with bracketing:
 Results of first cycle (ending previous bracket)

 Signal Details

Signal 1: ADC1 A, ADC1 CHANNEL A

 Overview Table

RT	Sig	Lvl	Amount [ug/mL]	Area	Rsp.Factor	Ref	ISTD #	Compound
2.917	1	1	1.00000	23.39497	4.27442e-2	No	No	Fluoride
		2	5.00000	148.22427	3.37327e-2			
		3	10.00000	301.58406	3.31583e-2			
		4	15.00000	447.08547	3.35506e-2			
		5	30.00000	866.94218	3.46044e-2			
4.164	1	1	1.00000	15.94899	6.26999e-2	No	No	Chloride
		2	5.00000	92.17435	5.42450e-2			
		3	10.00000	193.64059	5.16421e-2			
		4	15.00000	293.43437	5.11188e-2			
		5	30.00000	608.51315	4.93005e-2			

More compound-specific settings


Compound: Fluoride

Curve Type : Quadratic
Origin : Connected
Calibration Level Weights:/
Level 1 : 1
Level 2 : 0.024912
Level 3 : 0.006018
Level 4 : 0.002738
Level 5 : 0.000728


Compound: Chloride

Curve Type : Quadratic
Origin : Connected
Calibration Level Weights:/
Level 1 : 1
Level 2 : 0.02994
Level 3 : 0.006784
Level 4 : 0.002954
Level 5 : 0.000687

Peak Sum Table
-----***No Entries in table***

=====Calibration Curves
=====

Fluoride at exp. RT: 2.917
ADC1 A, ADC1 CHANNEL A
Correlation: 1.00000
Residual Std. Dev.: 1.06142
Formula: $y = ax^2 + bx + c$
a: -8.65103e-2
b: 31.75104
c: -8.26960
x: Amount[ug/mL]
y: Area
Calibration Level Weights:
Level 1 : 1
Level 2 : 0.024912
Level 3 : 0.006018
Level 4 : 0.002738
Level 5 : 0.000728



Chloride at exp. RT: 4.164
ADC1 A, ADC1 CHANNEL A
Correlation: 0.99997
Residual Std. Dev.: 1.63998
Formula: $y = ax^2 + bx + c$
a: 4.81128e-2
b: 19.00248
c: -3.11546
x: Amount[ug/mL]
y: Area
Calibration Level Weights:
Level 1 : 1
Level 2 : 0.02994
Level 3 : 0.006784
Level 4 : 0.002954
Level 5 : 0.000687

=====

Method Information

Method: C:\Chem32\1\DATA\Nelson637\Nelson637.M
Modified: 12/27/2016 at 10:29:53 AM

Column: Metrosep A Supp 5
Mobile Phase: 4.8mM Na2CO3/1.5mM NaHCO3
Flow Rate: 0.70mL/min
Suppressed Ion Conductivity

Method Audit Trail

Operator : Matthew Collier
Date : 12/27/2016 9:14:07 AM
Change Info: This method was created at 12/27/2016 9:14:07 AM and based on
method C:\Chem32\1\DATA\Nelson637\Nelson603.M

Operator : Matthew Collier
Date : 12/27/2016 9:14:11 AM
Change Info: Method saved. User comment: "averaged"

Operator : Matthew Collier
Date : 12/27/2016 9:14:22 AM
Change Info: Method C:\Chem32\1\METHODS\Nelson637 copied to result set

Operator : Matthew Collier
Date : 12/27/2016 10:29:53 AM
Change Info: Method replaced with master method C:\Chem32\1\METHODS\Nelson637

Run Time Checklist

Pre-Run Cmd/Macro: off
Data Acquisition: on
Standard Data Analysis: on
Customized Data Analysis: off
Save GLP Data: off
Post-Run Cmd/Macro: off
Save Method with Data: off

=====

Data File : c:\Chem32\2\Data\Nelson637\001-4202.D

Acq. Method: METROHM.M

The Acq. Method's Instrument Parameters for the Run were :

The Data Analysis Parameters of the used Method are :

=====
Integration Events
=====

Non signal specific Integration Events

Event	Value
Tangent Skim Mode	Standard
Tail Peak Skim Height Ratio	0.000
Front Peak Skim Height Ratio	0.000
Skim Valley Ratio	20.000
Baseline Correction	Classical
Peak to Valley Ratio	500.000

Default Integration Event Table "Event"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.040	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_FLD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.040	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_ECD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.040	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_MWD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.040	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_VWD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.040	Initial
Initial Area Reject	0.500	Initial
Initial Height Reject	1.000	Initial
Initial Shoulders	OFF	Initial
Integration	OFF	0.135
Integration	ON	1.787
Integration	OFF	2.454
Integration	ON	3.399
Integration	OFF	4.141

Detector Default Integration Event Table "Event_DAD"

Event	Value	Time
Initial Slope Sensitivity	2.000	Initial
Initial Peak Width	0.050	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	0.500	Initial
Initial Shoulders	OFF	Initial
Integration	OFF	0.094
Integration	ON	2.798
Integration	OFF	18.598

Detector Default Integration Event Table "Event_ADC"

Event	Value	Time
Initial Slope Sensitivity	1.500	Initial
Initial Peak Width	0.050	Initial
Initial Area Reject	0.100	Initial
Initial Height Reject	0.010	Initial
Initial Shoulders	OFF	Initial
Integration	OFF	0.000
Integration	ON	2.500

Method's Manual Integration Event table "ManInt_ADC1B"

Manual Integ. Event	Time1	Offset1	Time2	Offset2
Draw Baseline	6.074	0.000	7.214	0.010
Delete Peaks	7.342		8.575	

Apply Method's Manual Integration Events: No

Specify Report

Calculate: External Standard
Based on: Peak Area
Use Multiplier & Dilution Factor with ISTDs

Use Sample Data from Data File

Report mode: Classic
Destination: File (Prefix: Report)
Destination File Types: .TXT, .PDF, Unique PDF Name
Quantitative Results sorted by: Signal
Report Style: Short
Sample info on each page: No
Add Chromatogram Output: Yes
Chromatogram Output: Portrait
Size in Time direction: 80 % of Page
Size in Response direction: 29 % of Page
Uncalibrated Peaks: Do Not Report

Signal Options

Include: Axes, Compound Names, Retention Times, Baselines, Tick Marks
Font: Arial, Size: 8

Ranges: Use Ranges | Min Value | Max Value |
-----+-----+-----+

Time		0.000		15.000	
Response		0.000		55.000	

Multi Chromatograms: Overlaid, All the same Scale

=====
Calibration Table
=====

General Calibration Setting

Calib. Data Modified : Tuesday, December 27, 2016 10:26:26 AM
Signals calculated separately : No

Rel. Reference Window : 10.000 %
Abs. Reference Window : 0.000 min
Rel. Non-ref. Window : 10.000 %
Abs. Non-ref. Window : 0.000 min
Uncalibrated Peaks : not reported
Partial Calibration : Yes, identified peaks are recalibrated
Correct All Ret. Times: No, only for identified peaks

Curve Type : Quadratic
Origin : Connected
Weight : Quadratic (Resp)

Recalibration Settings:
Average Response : Average all calibrations
Average Retention Time: Floating Average New 75%

Calibration Report Options :
Printout of recalibrations within a sequence:
 Calibration Table after Recalibration
 Normal Report after Recalibration
If the sequence is done with bracketing:
 Results of first cycle (ending previous bracket)

Signal Details

Signal 1: ADC1 A, ADC1 CHANNEL A

Overview Table

RT	Sig	Lvl	Amount [ug/mL]	Area	Rsp.Factor	Ref	ISTD #	Compound
2.900	1	1	1.00000	13.20074	7.57533e-2	No	No	Fluoride
		2	5.00000	74.79366	6.68506e-2			
		3	10.00000	169.26157	5.90802e-2			
		4	15.00000	256.73203	5.84267e-2			
		5	30.00000	515.21491	5.82281e-2			
4.048	1	1	1.00000	8.39894	1.19063e-1	No	No	Chloride
		2	5.00000	51.04410	9.79545e-2			
		3	10.00000	106.87830	9.35644e-2			
		4	15.00000	165.01843	9.08989e-2			
		5	30.00000	347.50523	8.63296e-2			

Identification Details Table

RT	From	To	Sig	+-	Pk Usage	Compound
2.900	2.755	3.045	1	0.0000	Main	Fluoride
4.048	3.845	4.250	1	0.0000	Main	Chloride

Peak Sum Table

No Entries in table

Component Details Table

RT	Sig	Grp	Lvl	Amount [ug/mL]	Low Limit	High Limit	Compound
2.900	1		1	1.00000	0.00000	0.00000	Fluoride
			2	5.00000			
			3	10.00000			
			4	15.00000			
			5	30.00000			
4.048	1		1	1.00000	0.00000	0.00000	Chloride
			2	5.00000			
			3	10.00000			

4 15.00000
5 30.00000

=====
Sample related custom fields
=====

Custom Field	Type	Mand.	Default Value

None defined			

=====
Compound related custom fields
=====

Custom Field	Type	Mand.	Default Value

None defined			

**EPA CTM-027
Ammonia
Raw Data**

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 2. EPA CTM-027

Client No.: 11542

Ammonia -- Calibration Standards, Laboratory Blanks and Controls


Sample ID	Sequence	Filename #1	Filename #2	Analysis Method	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	Standard Tag	%Tag
HPLCStd415 #1	Curly329.v4	001-0201.D	001-0202.D	Curly329.M	4.22	4.22	0.0	0.188	0.187	0.1	0.187	0.200	93.9
HPLCStd415 #2	Curly329.v4	002-0301.D	002-0302.D	Curly329.M	4.23	4.23	0.0	1.07	1.06	0.2	1.07	0.990	108
HPLCStd415 #3	Curly329.v4	003-0401.D	003-0402.D	Curly329.M	4.23	4.22	0.1	2.01	2.02	0.3	2.02	1.96	103
HPLCStd415 #4	Curly329.v4	004-0501.D	004-0502.D	Curly329.M	4.24	4.24	0.0	4.70	4.76	0.6	4.73	4.76	99.3
HPLCStd415 #5	Curly329.v4	005-0601.D	005-0602.D	Curly329.M	4.24	4.25	0.0	6.43	6.37	0.4	6.40	6.54	97.8
HPLCStd415 #6	Curly329.v4	006-0701.D	006-0702.D	Curly329.M	4.25	4.24	0.1	8.83	8.78	0.3	8.80	9.09	96.9
HPLCStd415 #7	Curly329.v4	007-0801.D	007-0802.D	Curly329.M	4.24	4.24	0.0	12.7	12.9	1.1	12.8	12.3	104
HPLCStd415 #SS	Curly329.v4	008-0901.D	008-0902.D	Curly329.M	4.24	4.24	0.0	3.91	3.90	0.1	3.91	3.98	98.0
HPLCStd415 #RB	Curly329.v4	009-1001.D	009-1002.D	Curly329.M	4.23	4.23	0.1	0.0259	0.0258	0.1	0.0259	NA	NA
HPLCStd415 #4	Curly329.v4	004-2001.D	004-2002.D	Curly329.M	4.24	4.24	0.0	4.75	4.77	0.3	4.76	4.76	100

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #1
Sequence Name Curly329 ver.4
Inj Data File 001-0201.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 5:04 PM
File Modified 3/31/2017 9:07 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 1
Injection Volume 35
Injection 1 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	BB	4.22	47.3344	3.15116	0.18767	1	0.18767	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #1
Sequence Name Curly329 ver.4
Inj Data File 001-0202.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 5:13 PM
File Modified 3/31/2017 9:07 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 1
Injection Volume 35
Injection 2 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	BB	4.22	47.2239	3.15192	0.18723	1	0.18723	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #2
Sequence Name Curly329 ver.4
Inj Data File 002-0301.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 5:21 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 2
Injection Volume 35
Injection 1 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.23	219.523	13.1828	1.06911	1	1.06911	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #2
Sequence Name Curly329 ver.4
Inj Data File 002-0302.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 5:29 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 2
Injection Volume 35
Injection 2 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	MM	4.23	218.517	12.8650	1.06381	1	1.06381	µg/ml

Analyst Peak Integration Comments


09:00:06 03/31/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #3
Sequence Name Curly329 ver.4
Inj Data File 003-0401.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 5:37 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 3
Injection Volume 35
Injection 1 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.23	393.064	21.9366	2.01111	1	2.01111	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #3
Sequence Name Curly329 ver.4
Inj Data File 003-0402.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 5:46 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 3
Injection Volume 35
Injection 2 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	MM	4.22	395.412	21.9462	2.02425	1	2.02425	µg/ml

Analyst Peak Integration Comments


09:00:26 03/31/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #4
Sequence Name Curly329 ver.4
Inj Data File 004-0501.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 5:54 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 4
Injection Volume 35
Injection 1 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	832.815	41.8450	4.70099	1	4.70099	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #4
Sequence Name Curly329 ver.4
Inj Data File 004-0502.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 6:02 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 4
Injection Volume 35
Injection 2 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	840.937	41.7319	4.75594	1	4.75594	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #5
Sequence Name Curly329 ver.4
Inj Data File 005-0601.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 6:10 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 5
Injection Volume 35
Injection 1 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	1071.62	50.7253	6.42825	1	6.42825	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #5
Sequence Name Curly329 ver.4
Inj Data File 005-0602.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 6:19 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 5
Injection Volume 35
Injection 2 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.25	1064.50	51.5357	6.37292	1	6.37292	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #6
Sequence Name Curly329 ver.4
Inj Data File 006-0701.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 6:27 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 6
Injection Volume 35
Injection 1 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.25	1347.19	63.4438	8.83140	1	8.83140	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #6
Sequence Name Curly329 ver.4
Inj Data File 006-0702.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 6:35 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 6
Injection Volume 35
Injection 2 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	1341.80	64.0425	8.77808	1	8.77808	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #7
Sequence Name Curly329 ver.4
Inj Data File 007-0801.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 6:43 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 7
Injection Volume 35
Injection 1 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	1649.80	78.2852	12.6570	1	12.6570	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #7
Sequence Name Curly329 ver.4
Inj Data File 007-0802.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 6:51 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 7
Injection Volume 35
Injection 2 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	1664.93	77.0257	12.9287	1	12.9287	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #SS
Sequence Name Curly329 ver.4
Inj Data File 008-0901.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 7:00 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Control
Vial Number 8
Injection Volume 35
Injection 1 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	711.928	36.5096	3.90904	1	3.90904	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #SS
Sequence Name Curly329 ver.4
Inj Data File 008-0902.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 7:08 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Control
Vial Number 8
Injection Volume 35
Injection 2 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	710.960	36.9911	3.90288	1	3.90288	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #RB
Sequence Name Curly329 ver.4
Inj Data File 009-1001.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 7:16 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Control
Vial Number 9
Injection Volume 35
Injection 1 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	MM	4.23	6.52742	0.50442	0.02588	1	0.02588	µg/ml

Analyst Peak Integration Comments


09:03:51 03/31/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #RB
Sequence Name Curly329 ver.4
Inj Data File 009-1002.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 7:24 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Control
Vial Number 9
Injection Volume 35
Injection 2 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	MM	4.23	6.51948	0.51438	0.02585	1	0.02585	µg/ml

Analyst Peak Integration Comments


09:04:02 03/31/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R1.IMP 1
Sequence Name Curly329 ver.4
Inj Data File 011-1101.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 7:33 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 11
Injection Volume 20
Injection 1 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.22	156.369	10.5991	0.73930	1	0.73930	µg/ml

Analyst Peak Integration Comments


09:04:19 03/31/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R1.IMP 1
Sequence Name Curly329 ver.4
Inj Data File 011-1102.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 7:49 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 11
Injection Volume 20
Injection 2 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.23	157.710	10.5623	0.74624	1	0.74624	µg/ml

Analyst Peak Integration Comments


09:04:36 03/31/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R2.IMP 1
Sequence Name Curly329 ver.4
Inj Data File 012-1201.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 8:04 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 12
Injection Volume 20
Injection 1 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.23	171.375	11.0547	0.81708	1	0.81708	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R2.IMP 1
Sequence Name Curly329 ver.4
Inj Data File 012-1202.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 8:20 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 12
Injection Volume 20
Injection 2 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.22	172.168	11.3605	0.82120	1	0.82120	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R3.IMP 1
Sequence Name Curly329 ver.4
Inj Data File 013-1301.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 8:35 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 13
Injection Volume 20
Injection 1 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.23	170.748	11.2479	0.81383	1	0.81383	µg/ml

Analyst Peak Integration Comments


09:05:02 03/31/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R3.IMP 1
Sequence Name Curly329 ver.4
Inj Data File 013-1302.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 8:51 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 13
Injection Volume 20
Injection 2 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.23	170.535	11.2368	0.81272	1	0.81272	µg/ml

Analyst Peak Integration Comments


09:05:17 03/31/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R1.IMP 2
Sequence Name Curly329 ver.4
Inj Data File 014-1401.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 9:06 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 14
Injection Volume 20
Injection 1 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.19	3.56857	0.25761	0.01415	1	0.01415	µg/ml

Analyst Peak Integration Comments


09:05:37 03/31/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R1.IMP 2
Sequence Name Curly329 ver.4
Inj Data File 014-1402.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 9:22 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 14
Injection Volume 20
Injection 2 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.19	2.94591	0.23304	0.01168	1	0.01168	µg/ml

Analyst Peak Integration Comments


09:05:50 03/31/17 Scott Wilson II

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R2.IMP 2
Sequence Name Curly329 ver.4
Inj Data File 015-1501.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 9:37 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 15
Injection Volume 20
Injection 1 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.18	3.74186	0.26084	0.01484	1	0.01484	µg/ml

Analyst Peak Integration Comments


09:06:07 03/31/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R2.IMP 2
Sequence Name Curly329 ver.4
Inj Data File 015-1502.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 9:53 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 15
Injection Volume 20
Injection 2 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.20	5.47008	0.36610	0.02169	1	0.02169	µg/ml

Analyst Peak Integration Comments


09:06:19 03/31/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R3.IMP 2
Sequence Name Curly329 ver.4
Inj Data File 016-1601.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 10:08 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 16
Injection Volume 20
Injection 1 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.18	4.77466	0.31975	0.01893	1	0.01893	µg/ml

Analyst Peak Integration Comments


09:06:35 03/31/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R3.IMP 2
Sequence Name Curly329 ver.4
Inj Data File 016-1602.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 10:24 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 16
Injection Volume 20
Injection 2 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.20	4.58807	0.30674	0.01819	1	0.01819	µg/ml

Analyst Peak Integration Comments


09:06:54 03/31/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.BLANK.H2SO4
Sequence Name Curly329 ver.4
Inj Data File 017-1701.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 10:39 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 17
Injection Volume 20
Injection 1 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.19	3.35112	0.24663	0.01329	1	0.01329	µg/ml

Analyst Peak Integration Comments


09:07:08 03/31/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.BLANK.H2SO4
Sequence Name Curly329 ver.4
Inj Data File 017-1702.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 10:55 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 17
Injection Volume 20
Injection 2 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	FM	4.20	3.12943	0.23418	0.01241	1	0.01241	µg/ml

Analyst Peak Integration Comments


09:07:22 03/31/17 Scott Wilson NI

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MS-R1.IMP 1
Sequence Name Curly329 ver.4
Inj Data File 018-1801.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 11:10 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 18
Injection Volume 20
Injection 1 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	552.421	32.5503	2.92905	1	2.92905	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MS-R1.IMP 1
Sequence Name Curly329 ver.4
Inj Data File 018-1802.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 11:26 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 18
Injection Volume 20
Injection 2 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	554.889	32.3870	2.94372	1	2.94372	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MSD-R1.IMP 1
Sequence Name Curly329 ver.4
Inj Data File 019-1901.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 11:41 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 19
Injection Volume 20
Injection 1 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	552.379	32.2091	2.92880	1	2.92880	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MSD-R1.IMP 1
Sequence Name Curly329 ver.4
Inj Data File 019-1902.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/30/2017 11:57 PM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type Sample
Vial Number 19
Injection Volume 20
Injection 2 of 2
Acquisition Method CATIONS.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.23	548.715	32.4144	2.90706	1	2.90706	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #4
Sequence Name Curly329 ver.4
Inj Data File 004-2001.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/31/2017 12:12 AM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 4
Injection Volume 35
Injection 1 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	839.969	42.2315	4.74937	1	4.74937	µg/ml

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd415 #4
Sequence Name Curly329 ver.4
Inj Data File 004-2002.D
File Location HPLC/2017/Curly/Quarter 1
Injection Date 3/31/2017 12:20 AM
File Modified 3/31/2017 9:08 AM
Instrument Curly
Operator Scott Wilson

Sample Type
Vial Number 4
Injection Volume 35
Injection 2 of 2
Acquisition Method ENV_AMM_18MM.M
Analysis Method Curly329.M
Method Modified 3/31/2017 9:02 AM
Printed 4/3/2017 4:21 PM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Ammonia	VB	4.24	843.510	42.3323	4.77339	1	4.77339	µg/ml

```

=====
                          Calibration Table
=====

```

```

-----
                          General Calibration Setting
-----

```

Calib. Data Modified : Friday, March 31, 2017 9:02:18 AM
 Signals calculated separately : No

Rel. Reference Window : 5.000 %
 Abs. Reference Window : 0.000 min
 Rel. Non-ref. Window : 10.000 %
 Abs. Non-ref. Window : 0.000 min
 Uncalibrated Peaks : not reported
 Partial Calibration : Yes, identified peaks are recalibrated
 Correct All Ret. Times: No, only for identified peaks

Curve Type : Quadratic
 Origin : Connected
 Weight : Linear (Amnt)

Recalibration Settings:
 Average Response : Average all calibrations
 Average Retention Time: Floating Average New 75%

Calibration Report Options :

Printout of recalibrations within a sequence:
 Calibration Table after Recalibration
 Normal Report after Recalibration
 If the sequence is done with bracketing:
 Results of first cycle (ending previous bracket)

```

-----
                          Signal Details
-----

```

Signal 1: ADC1 B, ADC1, B

```

-----
                          Overview Table
-----


```

RT	Sig	Lvl	Amount [µg/ml]	Area	Rsp.Factor	Ref	ISTD #	Compound
4.243	1	1	1.99600e-1	47.27915	4.22173e-3	No	No	Ammonia
		2	9.90100e-1	219.02037	4.52058e-3			
		3	1.96080	394.23798	4.97365e-3			
		4	4.76190	836.87598	5.69009e-3			
		5	6.54210	1068.06317	6.12520e-3			
		6	9.09090	1344.49536	6.76157e-3			
		7	12.28070	1657.36414	7.40978e-3			

Peak Sum Table

No Entries in table

Calibration Curves



Ammonia at exp. RT: 4.243
ADC1 B, ADC1, B
Correlation: 0.99959
Residual Std. Dev.: 21.83544
Formula: $y = ax^2 + bx + c$
a: -5.71078
b: 201.81527
c: 10.28801
x: Amount[µg/ml]
y: Area

Calibration Level Weights:

Level 1	: 1
Level 2	: 0.201596
Level 3	: 0.101795
Level 4	: 0.041916
Level 5	: 0.03051
Level 6	: 0.021956
Level 7	: 0.016253

Method Information

Method: C:\HPLC\2014\CURLY\METHODS\ENV_AMM_18MM.M
Modified: 2/22/2017 at 7:45:44 AM

Column: Dionex IonPac CS12 (250 mm x 4 mm)
Mobile Phase: 18mN Methanesulfonic Acid
Detection: Suppressed Conductivity
Flow Rate: 1.0 mL/min
Temp: 30C

Method Audit Trail

Operator : Kyle Hoffman
Date : 5/25/2016 9:35:55 AM
Change Info: This method was created at 5/25/2016 9:35:55 AM and based on
method C:\HPLC\2014\Curly\Methods\ENV_AMM_18MM_DIUF_new.M

Operator : Kyle Hoffman
Date : 5/25/2016 9:35:56 AM
Change Info: Method saved. User comment: ""

Operator : Kyle Hoffman
Date : 5/27/2016 10:25:55 AM
Change Info: Method saved. User comment: ""

Operator : Kyle Hoffman
Date : 6/29/2016 6:47:51 PM
Change Info: Method saved. User comment: ""

Operator : Scott Wilson
Date : 8/11/2016 9:02:46 AM
Change Info: Method saved. User comment: ""

Operator : Scott Wilson
Date : 8/12/2016 9:01:05 AM
Change Info: Method saved. User comment: ""

Operator : Scott Wilson
Date : 8/16/2016 8:45:19 AM
Change Info: Method saved. User comment: ""

Operator : Scott Wilson
Date : 8/18/2016 8:05:08 AM
Change Info: Method saved. User comment: ""

Operator : Scott Wilson
Date : 8/18/2016 10:58:16 AM
Change Info: Method saved. User comment: ""

Operator : Scott Wilson
Date : 8/18/2016 1:54:18 PM
Change Info: Method saved. User comment: ""

Operator : Scott Wilson
Date : 9/15/2016 8:22:52 AM
Change Info: Method saved. User comment: ""

Operator : Scott Wilson
Date : 9/27/2016 4:56:41 PM
Change Info: Method saved. User comment: ""

method: C:\HPLC\2014\CURLY\METHODS\ENV_AMM_18MM.M

Modified on: 2/22/2017 at 7:45:44 AM

Operator : Scott Wilson

Date : 10/18/2016 1:43:58 PM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 10/19/2016 9:06:51 AM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 10/19/2016 12:29:13 PM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 10/19/2016 3:27:36 PM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 10/19/2016 3:56:24 PM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 10/20/2016 10:03:38 AM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 10/20/2016 12:59:06 PM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 10/20/2016 1:19:49 PM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 10/31/2016 4:22:59 PM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 11/1/2016 2:49:27 PM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 12/19/2016 11:31:44 AM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 2/1/2017 3:05:45 PM

Change Info: Method saved. User comment: "mobile phase switch"

Operator : Scott Wilson

Date : 2/1/2017 3:34:30 PM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 2/1/2017 4:27:13 PM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 2/16/2017 1:37:26 PM

Change Info: Method saved. User comment: ""

Operator : Scott Wilson

Date : 2/22/2017 7:45:44 AM

Change Info: Method saved. User comment: ""

Run Time Checklist

Pre-Run Cmd/Macro: off
Data Acquisition: on
Standard Data Analysis: off
Customized Data Analysis: off
Save GLP Data: off
Post-Run Cmd/Macro: off
Save Method with Data: off

=====

ANALOG DIGITAL CONVERTER

=====

Signal 1

Description: ADC1, B
Source: Signal
Unit: mS
Units/Volt: 1000.000
Peakwidth (Data Rate): 0.053 Min (5.00 Hz)
Stop Time: No Limit
Data Storage: All

Start Signal Source: External Device Will Start 35900

Timed Event Table:
<no events>

=====
Agilent 1100/1200 Binary Pump 1
=====

Control

Column Flow : 1.000 ml/min
Stoptime : 7.00 min
Posttime : Off

Solvents

Solvent A : 0.0 % ()
Solvent B : 100.0 % (18 mN MethaneSulfonic Acid)

PressureLimits

Minimum Pressure : 0 bar
Maximum Pressure : 400 bar

Auxiliary

Maximal Flow Ramp : 100.00 ml/min^2
Compressibility A : 50*10^-6/bar
Minimal Stroke A : 50 µl
Compressibility B : 115*10^-6/bar
Minimal Stroke B : Auto

Store Parameters

Store Ratio A : Yes
Store Ratio B : Yes
Store Flow : Yes
Store Pressure : Yes

Timetable is empty

=====
Agilent 1100 Autosampler 1
=====

Injection

Injection Mode : Standard
Injector volume : 35.00 µl
Optimization : Prefetch Sample Vial
5.00 min. after Injection

Auxiliary

Drawspeed : 100 µl/min
Ejectspeed : 100 µl/min
Draw position : 0.0 mm

Time

Stoptime : 14.0 min
Posttime : Off

The Data Analysis Parameters of the used Method are :

=====
Integration Events
=====

Non signal specific Integration Events

Event	Value
Tangent Skim Mode	Standard
Tail Peak Skim Height Ratio	0.000
Front Peak Skim Height Ratio	0.000
Skim Valley Ratio	0.000
Baseline Correction	Classical
Peak to Valley Ratio	0.000

Default Integration Event Table "Event"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_DAD"

Event	Value	Time
Initial Slope Sensitivity	5.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	5.000	Initial
Initial Height Reject	1.000	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_FLD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_VWD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_ECD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_MWD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_ADC"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.040	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	0.500	Initial
Initial Shoulders	OFF	Initial

Apply Method's Manual Integration Events: No

=====
Specify Report
=====

Calculate: External Standard
Based on: Peak Area
Do not use Multiplier & Dilution Factor with ISTDs

Use Sample Data from Data File
Report mode: Classic
Destination: File (Prefix: Report)
Destination File Types: .TXT
Quantitative Results sorted by: Signal
Report Style: Short
Sample info on each page: No
Add Chromatogram Output: Yes
Chromatogram Output: Portrait
Size in Time direction: 100 % of Page
Size in Response direction: 40 % of Page
Uncalibrated Peaks: Report with Calibrated Peaks

Signal Options

=====
Include: Axes, Retention Times, Baselines, Tick Marks

Font: Arial, Size: 8

Ranges: Full

Multi Chromatograms: Separated, Each in full Scale

=====
Calibration Table
=====

General Calibration Setting

Calib. Data Modified : 3/9/2013 9:10:59 AM

Signals calculated separately : No

Rel. Reference Window : 5.000 %
Abs. Reference Window : 0.000 min
Rel. Non-ref. Window : 5.000 %
Abs. Non-ref. Window : 0.000 min
Uncalibrated Peaks : not reported
Partial Calibration : Yes, identified peaks are recalibrated
Correct All Ret. Times: No, only for identified peaks

Curve Type : Quadratic
Origin : Connected
Weight : Linear (Amnt)

Recalibration Settings:
Average Response : Average all calibrations
Average Retention Time: Floating Average New 75%

Calibration Report Options :
Printout of recalibrations within a sequence:
 Calibration Table after Recalibration
 Normal Report after Recalibration
If the sequence is done with bracketing:
 Results of first cycle (ending previous bracket)

Signal Details

Signal 1: ADC1 A, Dionex ED40
Signal 2: PMP1, Pressure

Overview Table

RT	Sig	Lvl	Amount [ug/mL]	Area	Rsp.Factor	Ref	ISTD #	Compound
8.022	1	1	1.16500	34.33678	3.39286e-2	No	No	Ammonia
		2	4.49500	142.40279	3.15654e-2			
		3	15.73000	484.89142	3.24403e-2			
		4	20.36000	600.09448	3.39280e-2			
		5	31.47000	875.20233	3.59574e-2			
		6	38.87000	1033.55652	3.76080e-2			

Identification Details Table

RT	From	To	Sig	+-	Pk Usage	Compound
8.022	7.822	8.223	1	0.0000	Main	Ammonia

Peak Sum Table

No Entries in table

Component Details Table

RT	Sig	Grp	Lvl	Amount [ug/mL]	Low Limit	High Limit	Compound
8.022	1		1	1.16500	0.00000	0.00000	Ammonia
			2	4.49500			
			3	15.73000			
			4	20.36000			
			5	31.47000			
			6	38.87000			

Sample related custom fields

Custom Field	Type	Mand.	Default Value
None defined			

Compound related custom fields

Custom Field	Type	Mand.	Default Value
None defined			

Method Information

Method: C:\HPLC\2014\CURLY\METHODS\CATIONS.M
Modified: 2/23/2017 at 2:16:23 PM

Column: Dionex IonPac CS12 (250 mm x 4 mm)
Mobile Phase: 18mN Methanesulfonic Acid
Detection: Suppressed Conductivity
Flow Rate: 1.0 mL/min
Temp: 30C

Method Audit Trail

Operator : Scott Wilson
Date : 2/23/2017 2:16:15 PM
Change Info: This method was created at 2/23/2017 2:16:15 PM and based on
method C:\HPLC\2014\Curly\Methods\CATIONS.M, the original method
was overwritten.

Operator : Scott Wilson
Date : 2/23/2017 2:16:23 PM
Change Info: Method saved. User comment: "mobile phase"

Run Time Checklist

Pre-Run Cmd/Macro: off
Data Acquisition: on
Standard Data Analysis: off
Customized Data Analysis: off
Save GLP Data: off
Post-Run Cmd/Macro: off
Save Method with Data: off

=====

ANALOG DIGITAL CONVERTER

=====

Signal 1

Description: ADC1, B
Source: Signal
Unit: mS
Units/Volt: 1000.000
Peakwidth (Data Rate): 0.053 Min (5.00 Hz)
Stop Time: No Limit
Data Storage: All

Start Signal Source: External Device Will Start 35900

Timed Event Table:
<no events>

=====
Agilent 1100/1200 Binary Pump 1
=====

Control

Column Flow : 1.000 ml/min
Stoptime : 14.00 min
Posttime : Off

Solvents

Solvent A : 0.0 % (18 mN Methanesulfonic Acid)
Solvent B : 100.0 % (18 mN Methanesulfonic Acid)

PressureLimits

Minimum Pressure : 0 bar
Maximum Pressure : 400 bar

Auxiliary

Maximal Flow Ramp : 100.00 ml/min²
Compressibility A : 50*10⁻⁶/bar
Minimal Stroke A : Auto
Compressibility B : 115*10⁻⁶/bar
Minimal Stroke B : Auto

Store Parameters

Store Ratio A : Yes
Store Ratio B : Yes
Store Flow : Yes
Store Pressure : Yes

Timetable is empty

=====
Agilent 1100 Autosampler 1
=====

Injection

Injection Mode : Needle Wash
Injector volume : 20.00 µl
Wash Vial : 100
Optimization : Prefetch Sample Vial
5.00 min. after Injection

Auxiliary

Drawspeed : 100 µl/min
Ejectspeed : 100 µl/min
Draw position : 0.0 mm

Time

Stoptime : No Limit
Posttime : Off

The Data Analysis Parameters of the used Method are :

=====
Integration Events
=====

Non signal specific Integration Events

Event	Value
Tangent Skim Mode	Standard
Tail Peak Skim Height Ratio	0.000
Front Peak Skim Height Ratio	0.000
Skim Valley Ratio	0.000
Baseline Correction	Classical
Peak to Valley Ratio	0.000

Default Integration Event Table "Event"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_DAD"

Event	Value	Time
Initial Slope Sensitivity	5.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	5.000	Initial
Initial Height Reject	1.000	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_FLD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_VWD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_ECD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_MWD"

Event	Value	Time
Initial Slope Sensitivity	1.000	Initial
Initial Peak Width	0.020	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	1.700	Initial
Initial Shoulders	OFF	Initial

Detector Default Integration Event Table "Event_ADC"

Event	Value	Time
Initial Slope Sensitivity	0.300	Initial
Initial Peak Width	0.100	Initial
Initial Area Reject	1.000	Initial
Initial Height Reject	0.300	Initial
Initial Shoulders	OFF	Initial

Apply Method's Manual Integration Events: No

=====
Specify Report
=====

Calculate: External Standard
Based on: Peak Area
Do not use Multiplier & Dilution Factor with ISTDs

Use Sample Data from Data File
Report mode: Classic
Destination: File (Prefix: Report)
Destination File Types: .TXT
Quantitative Results sorted by: Signal
Report Style: Short
Sample info on each page: No
Add Chromatogram Output: Yes
Chromatogram Output: Portrait
Size in Time direction: 100 % of Page
Size in Response direction: 40 % of Page
Uncalibrated Peaks: Report with Calibrated Peaks

Signal Options

=====
Include: Axes, Retention Times, Baselines, Tick Marks

Font: Arial, Size: 8

Ranges: Full

Multi Chromatograms: Separated, Each in full Scale

=====
Calibration Table
=====

General Calibration Setting

Calib. Data Modified : 3/9/2013 1:39:57 PM
Signals calculated separately : No

Rel. Reference Window : 5.000 %
Abs. Reference Window : 0.000 min
Rel. Non-ref. Window : 5.000 %
Abs. Non-ref. Window : 0.000 min
Uncalibrated Peaks : not reported
Partial Calibration : Yes, identified peaks are recalibrated
Correct All Ret. Times: No, only for identified peaks

Curve Type : Quadratic
Origin : Connected
Weight : Linear (Amnt)

Recalibration Settings:
Average Response : Average all calibrations
Average Retention Time: Floating Average New 75%

Calibration Report Options :
Printout of recalibrations within a sequence:
 Calibration Table after Recalibration
 Normal Report after Recalibration
If the sequence is done with bracketing:
 Results of first cycle (ending previous bracket)

Signal Details

Signal 1: ADC1 A, Dionex ED40

Overview Table

RT	Sig	Lvl	Amount [ug/mL]	Area	Rsp.Factor	Ref	ISTD #	Compound
5.270	1	1	2.35000e-1	45.04745	5.21672e-3	No	No	Ammonia
		2	4.70000e-1	81.56224	5.76247e-3			
		3	1.85100	310.89604	5.95376e-3			
		4	4.49500	678.07352	6.62907e-3			
		5	6.58600	922.60376	7.13849e-3			
		6	8.58200	1151.75916	7.45121e-3			
		7	12.31000	1512.94824	8.13643e-3			

Identification Details Table

RT	From	To	Sig	+-	Pk Usage	Compound
5.270	5.139	5.402	1	0.0000	Main	Ammonia

Peak Sum Table

No Entries in table

Component Details Table

RT	Sig	Grp	Lvl	Amount [ug/mL]	Low Limit	High Limit	Compound
5.270	1		1	2.35000e-1	0.00000	0.00000	Ammonia
			2	4.70000e-1			
			3	1.85100			
			4	4.49500			
			5	6.58600			
			6	8.58200			
			7	12.31000			

Sample related custom fields

Custom Field	Type	Mand.	Default Value
None defined			

None defined

Compound related custom fields

Custom Field	Type	Mand.	Default Value
--------------	------	-------	---------------

None defined

**NCASI Method 8A
(HPLC)
Sulfuric Acid Mist
Raw Data**

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 3. NCASI Method 8A (HPLC/ IC)

Client No.: 11542

Sulfate -- Calibration Standards, Laboratory Blanks and Controls

Sample ID	Sequence	Filename #1	Filename #2	Analysis Method	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	Flag	Standard Tag	%Tag
HPLCStd422 #1	Gonzo228.v2	001-0201.D	001-0202.D	Gonzo230.M	8.95	8.94	0.1	0.542	0.546	0.4	0.544		0.495	110
HPLCStd422 #2	Gonzo228.v2	002-0301.D	002-0302.D	Gonzo230.M	8.96	8.97	0.0	1.00	1.03	1.3	1.01		1.00	101
HPLCStd422 #3	Gonzo228.v2	003-0401.D	003-0402.D	Gonzo230.M	8.94	8.94	0.0	4.65	4.73	0.9	4.69		5.00	93.8
HPLCStd422 #4	Gonzo228.v2	004-0501.D	004-0502.D	Gonzo230.M	8.95	8.96	0.0	9.62	9.62	0.0	9.62		10.0	96.2
HPLCStd422 #5	Gonzo228.v2	005-0601.D	005-0602.D	Gonzo230.M	8.95	8.95	0.0	14.5	14.5	0.0	14.5		15.0	97.0
HPLCStd422 #6	Gonzo228.v2	006-0701.D	006-0702.D	Gonzo230.M	8.96	8.96	0.0	24.8	24.8	0.0	24.8		25.0	99.2
HPLCStd422 #7	Gonzo228.v2	007-0801.D	007-0802.D	Gonzo230.M	8.96	8.95	0.0	51.3	51.2	0.1	51.3		50.0	103
HPLCStd422 #SS	Gonzo228.v2	008-0901.D	008-0902.D	Gonzo230.M	8.97	8.96	0.0	5.78	5.73	0.4	5.75		5.88	97.8
HPLCStd422 #RB	Gonzo228.v2	009-1001.D	009-1002.D	Gonzo230.M	NA	NA	NA	0.0554	0.0554	0.0	0.0554	ND	NA	NA
HPLCStd422 #5	Gonzo228b.v6	005-0201.D	005-0202.D	Gonzo230.M	8.57	8.25	1.9	14.5	14.5	0.2	14.5		15.0	96.7
HPLCStd422 #SS	Gonzo228b.v6	008-0301.D	008-0302.D	Gonzo230.M	8.23	8.20	0.2	5.56	6.09	4.5	5.82		5.88	99.0
HPLCStd422 #RB	Gonzo228b.v6	009-0401.D	009-0402.D	Gonzo230.M	NA	NA	NA	0.0554	0.0554	0.0	0.0554	ND	NA	NA
HPLCStd422 #5	Gonzo228b.v6	005-1501.D	005-1502.D	Gonzo230.M	8.34	8.26	0.5	14.5	14.4	0.3	14.5		15.0	96.4
HPLCStd422 #1	Gonzo234.v3	001-0201.D	001-0202.D	Gonzo234.M	8.24	8.24	0.0	0.585	0.538	4.2	0.562		0.495	113
HPLCStd422 #2	Gonzo234.v3	002-0301.D	002-0302.D	Gonzo234.M	8.21	8.22	0.1	0.983	1.01	1.3	0.996		1.00	99.6

Enthalpy Analytical

Company: C.E.M. Solutions, Inc.

Job No.: 0317-144 - 3. NCASI Method 8A (HPLC/ IC)

Client No.: 11542

Sulfate -- Calibration Standards, Laboratory Blanks and Controls


Sample ID	Sequence	Filename #1	Filename #2	Analysis Method	Ret Time (min)	Ret Time (min)	%diff RT	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	%diff conc	Avg Conc (ug/mL)	Flag	Standard Tag	%Tag
HPLCStd422 #3	Gonzo234.v3	003-0401.D	003-0402.D	Gonzo234.M	8.24	8.23	0.1	4.59	4.60	0.1	4.59		5.00	91.8
HPLCStd422 #4	Gonzo234.v3	004-0501.D	004-0502.D	Gonzo234.M	8.22	8.23	0.0	9.40	9.42	0.1	9.41		10.0	94.1
HPLCStd422 #5	Gonzo234.v3	005-0601.D	005-0602.D	Gonzo234.M	8.23	8.23	0.0	14.9	14.9	0.1	14.9		15.0	99.4
HPLCStd422 #6	Gonzo234.v3	006-0701.D	006-0702.D	Gonzo234.M	8.23	8.23	0.0	24.7	24.8	0.0	24.7		25.0	99.0
HPLCStd422 #7	Gonzo234.v3	007-0801.D	007-0802.D	Gonzo234.M	8.23	8.23	0.0	51.4	51.2	0.2	51.3		50.0	103
HPLCStd422 #SS	Gonzo234.v3	008-0901.D	008-0902.D	Gonzo234.M	8.24	8.23	0.1	5.73	5.70	0.2	5.71		5.88	97.1
HPLCStd422 #RB	Gonzo234.v3	009-1001.D	009-1002.D	Gonzo234.M	NA	NA	NA	0.0554	0.0554	0.0	0.0554	ND	NA	NA
HPLCStd422 #5	Gonzo234.v3	005-2201.D	005-2202.D	Gonzo234.M	8.25	8.24	0.0	15.0	15.0	0.0	15.0		15.0	100
HPLCStd422 #2	Gonzo235 2.v11	002-0301.D	002-0302.D	Gonzo235.M	7.32	7.33	0.0	1.11	1.09	1.0	1.10		1.00	110
HPLCStd422 #3	Gonzo235 2.v11	003-0401.D	003-0402.D	Gonzo235.M	7.32	7.31	0.0	4.84	4.79	0.5	4.81		5.00	96.3
HPLCStd422 #4	Gonzo235 2.v11	004-0501.D	004-0502.D	Gonzo235.M	7.31	7.31	0.0	9.62	9.65	0.1	9.63		10.0	96.3
HPLCStd422 #6	Gonzo235 2.v11	006-0701.D	006-0702.D	Gonzo235.M	7.28	7.28	0.0	24.8	24.9	0.1	24.9		25.0	99.5
HPLCStd422 #SS	Gonzo235 2.v11	008-0801.D	008-0802.D	Gonzo235.M	7.29	7.28	0.0	5.75	5.65	0.9	5.70		5.88	96.9
HPLCStd422 #RB	Gonzo235 2.v11	009-0901.D	009-0902.D	Gonzo235.M	NA	NA	NA	0.0554	0.0554	0.0	0.0554	ND	NA	NA
HPLCStd422 #4	Gonzo235b.v5	004-0101.D	004-0102.D	Gonzo235.M	7.32	7.30	0.1	9.60	9.61	0.0	9.61		10.0	96.1
HPLCStd422 #5	Gonzo235c.v3	005-0101.D	005-0102.D	Gonzo235.M	7.39	7.38	0.1	14.4	14.4	0.0	14.4		15.0	95.7
HPLCStd422 #7	Gonzo235d.v3	007-0101.D	007-0102.D	Gonzo235.M	7.35	7.37	0.1	51.3	51.1	0.2	51.2		50.0	102

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #1
Sequence Name Gonzo228 ver.2
Inj Data File 001-0201.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 5:14 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 1
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.95	33.5385	1.06362	0.54179	1	0.54179	ug/mL

Analyst Peak Integration Comments


15:21:05 04/06/17 Amelia Paolantonio NI AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #1
Sequence Name Gonzo228 ver.2
Inj Data File 001-0202.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 5:26 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 1
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.94	33.7825	1.11554	0.54568	1	0.54568	ug/mL

Analyst Peak Integration Comments


15:21:20 04/06/17 Amelia Paolantonio NI AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #2
Sequence Name Gonzo228 ver.2
Inj Data File 002-0301.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 5:37 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Calibration
Vial Number 2
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.96	62.3570	2.05468	1.00067	1	1.00067	ug/mL

Analyst Peak Integration Comments


15:21:34 04/06/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #2
Sequence Name Gonzo228 ver.2
Inj Data File 002-0302.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 5:49 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 2
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.97	64.0038	2.05334	1.02689	1	1.02689	ug/mL

Analyst Peak Integration Comments


15:21:49 04/06/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #3
Sequence Name Gonzo228 ver.2
Inj Data File 003-0401.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 6:01 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 3
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.94	291.422	9.50079	4.64808	1	4.64808	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #3
Sequence Name Gonzo228 ver.2
Inj Data File 003-0402.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 6:13 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Calibration
Vial Number 3
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.94	296.812	9.65276	4.73392	1	4.73392	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #4
Sequence Name Gonzo228 ver.2
Inj Data File 004-0501.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 6:24 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 4
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.95	603.634	19.7565	9.61945	1	9.61945	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #4
Sequence Name Gonzo228 ver.2
Inj Data File 004-0502.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 6:36 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 4
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.96	603.929	19.7893	9.62415	1	9.62415	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo228 ver.2
Inj Data File 005-0601.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 6:48 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.95	912.929	29.7774	14.5444	1	14.5444	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo228 ver.2
Inj Data File 005-0602.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 6:59 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.95	912.773	29.6764	14.5419	1	14.5419	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #6
Sequence Name Gonzo228 ver.2
Inj Data File 006-0701.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 7:11 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 6
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.96	1557.53	50.8411	24.8084	1	24.8084	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #6
Sequence Name Gonzo228 ver.2
Inj Data File 006-0702.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 7:23 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 6
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.96	1557.78	51.1146	24.8123	1	24.8123	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #7
Sequence Name Gonzo228 ver.2
Inj Data File 007-0801.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 7:35 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 7
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.96	3221.33	106.727	51.3011	1	51.3011	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #7
Sequence Name Gonzo228 ver.2
Inj Data File 007-0802.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 7:47 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 7
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.95	3217.57	106.344	51.2412	1	51.2412	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #SS
Sequence Name Gonzo228 ver.2
Inj Data File 008-0901.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 7:58 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 8
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.97	362.391	11.7341	5.77813	1	5.77813	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #SS
Sequence Name Gonzo228 ver.2
Inj Data File 008-0902.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 8:10 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 8
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.96	359.339	11.6488	5.72954	1	5.72954	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #RB
Sequence Name Gonzo228 ver.2
Inj Data File 009-1001.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 8:22 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 9
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate		(8.80)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #RB
Sequence Name Gonzo228 ver.2
Inj Data File 009-1002.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/5/2017 8:33 PM
File Modified 4/10/2017 1:30 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 9
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 1:18 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate		(8.80)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo228b ver.6
Inj Data File 005-0201.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 4:58 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	VB	8.57	911.896	31.0779	14.5279	1	14.5279	ug/mL

Analyst Peak Integration Comments


13:51:13 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo228b ver.6
Inj Data File 005-0202.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 5:10 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	VB	8.25	908.739	30.9540	14.4777	1	14.4777	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #SS
Sequence Name Gonzo228b ver.6
Inj Data File 008-0301.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 5:21 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 8
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	VB	8.23	348.624	12.0548	5.55891	1	5.55891	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #SS
Sequence Name Gonzo228b ver.6
Inj Data File 008-0302.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 5:33 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 8
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.20	381.844	11.2287	6.08788	1	6.08788	ug/mL

Analyst Peak Integration Comments


13:35:37 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #RB
Sequence Name Gonzo228b ver.6
Inj Data File 009-0401.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 5:45 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 9
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate		(8.20)				1		ug/mL

Analyst Peak Integration Comments


13:36:04 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #RB
Sequence Name Gonzo228b ver.6
Inj Data File 009-0402.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 5:56 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 9
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate		(8.20)				1		ug/mL

Analyst Peak Integration Comments


13:36:12 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R1.M8A
Sequence Name Gonzo228b ver.6
Inj Data File 021-0501.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 6:08 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 21
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.52	26.2506	0.90466	0.42465	1	0.42465	ug/mL

Analyst Peak Integration Comments


10:01:42 04/10/17 Amelia Paolantonio NI AMP

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R1.M8A
Sequence Name Gonzo228b ver.6
Inj Data File 021-0502.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 6:20 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 21
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.39	26.3244	0.92755	0.42584	1	0.42584	ug/mL

Analyst Peak Integration Comments


10:01:57 04/10/17 Amelia Paolantonio NI AMP

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.BLANK.M8A
Sequence Name Gonzo228b ver.6
Inj Data File 024-0801.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 6:55 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 24
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate		(8.20)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.BLANK.M8A
Sequence Name Gonzo228b ver.6
Inj Data File 024-0802.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 7:07 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 24
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate		(8.20)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MS-R1.M8A
Sequence Name Gonzo228b ver.6
Inj Data File 025-0901.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 7:18 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 25
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.51	137.308	4.66906	2.19412	1	2.19412	ug/mL

Analyst Peak Integration Comments


10:26:04 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MS-R1.M8A
Sequence Name Gonzo228b ver.6
Inj Data File 025-0902.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 7:30 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 25
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.44	132.460	4.63010	2.11692	1	2.11692	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MSD-R1.M8A
Sequence Name Gonzo228b ver.6
Inj Data File 026-1001.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 7:42 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 26
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.34	134.011	4.69384	2.14163	1	2.14163	ug/mL

Analyst Peak Integration Comments


10:26:23 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.MSD-R1.M8A
Sequence Name Gonzo228b ver.6
Inj Data File 026-1002.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 7:53 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 26
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.51	143.356	4.69238	2.29042	1	2.29042	ug/mL

Analyst Peak Integration Comments


10:26:43 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo228b ver.6
Inj Data File 005-1501.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 9:38 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	VB	8.34	909.927	31.2916	14.4966	1	14.4966	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo228b ver.6
Inj Data File 005-1502.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/6/2017 9:50 PM
File Modified 4/10/2017 3:13 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo230.M
Method Modified 4/10/2017 2:01 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	VB	8.26	905.359	31.3270	14.4238	1	14.4238	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStds422 #1
Sequence Name Gonzo234 ver.3
Inj Data File 001-0201.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 9:30 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 1
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.24	32.1147	1.21782	0.58533	1	0.58533	ug/mL

Analyst Peak Integration Comments


09:31:13 04/10/17 Amelia Paolantonio NI AMP
14:13:43 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #1
Sequence Name Gonzo234 ver.3
Inj Data File 001-0202.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 9:42 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 1
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.24	29.1878	1.01578	0.53824	1	0.53824	ug/mL

Analyst Peak Integration Comments


09:31:41 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #2
Sequence Name Gonzo234 ver.3
Inj Data File 002-0301.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 9:54 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Calibration
Vial Number 2
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.21	56.8321	2.04635	0.98302	1	0.98302	ug/mL

Analyst Peak Integration Comments


09:32:06 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStds422 #2
Sequence Name Gonzo234 ver.3
Inj Data File 002-0302.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 10:06 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Calibration
Vial Number 2
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.22	58.4958	2.06975	1.00979	1	1.00979	ug/mL

Analyst Peak Integration Comments


09:32:19 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #3
Sequence Name Gonzo234 ver.3
Inj Data File 003-0401.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 10:17 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 3
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.24	280.753	9.88196	4.58575	1	4.58575	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #3
Sequence Name Gonzo234 ver.3
Inj Data File 003-0402.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 10:29 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Calibration
Vial Number 3
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.23	281.523	9.93260	4.59815	1	4.59815	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #4
Sequence Name Gonzo234 ver.3
Inj Data File 004-0501.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 10:41 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 4
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.22	579.787	20.4716	9.39701	1	9.39701	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #4
Sequence Name Gonzo234 ver.3
Inj Data File 004-0502.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 10:52 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 4
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.23	580.906	20.5042	9.41502	1	9.41502	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo234 ver.3
Inj Data File 005-0601.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 11:04 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.23	923.807	32.6426	14.9321	1	14.9321	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo234 ver.3
Inj Data File 005-0602.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 11:16 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.23	921.440	32.5210	14.8940	1	14.8940	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #6
Sequence Name Gonzo234 ver.3
Inj Data File 006-0701.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 11:27 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 6
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.23	1533.37	54.0808	24.7395	1	24.7395	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #6
Sequence Name Gonzo234 ver.3
Inj Data File 006-0702.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 11:39 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 6
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.23	1534.42	54.0057	24.7565	1	24.7565	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #7
Sequence Name Gonzo234 ver.3
Inj Data File 007-0801.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/8/2017 11:51 PM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 7
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.23	3190.47	114.128	51.4011	1	51.4011	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #7
Sequence Name Gonzo234 ver.3
Inj Data File 007-0802.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/9/2017 12:02 AM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 7
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.23	3175.14	113.318	51.1546	1	51.1546	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #SS
Sequence Name Gonzo234 ver.3
Inj Data File 008-0901.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/9/2017 12:14 AM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 8
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.24	351.597	12.4511	5.72558	1	5.72558	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #SS
Sequence Name Gonzo234 ver.3
Inj Data File 008-0902.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/9/2017 12:26 AM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 8
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.23	350.107	12.3695	5.70162	1	5.70162	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #RB
Sequence Name Gonzo234 ver.3
Inj Data File 009-1001.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/9/2017 12:37 AM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 9
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate		(8.24)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #RB
Sequence Name Gonzo234 ver.3
Inj Data File 009-1002.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/9/2017 12:49 AM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 9
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate		(8.24)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R3.M8A
Sequence Name Gonzo234 ver.3
Inj Data File 023-1301.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/9/2017 1:47 AM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 23
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.25	28.3962	0.99811	0.52551	1	0.52551	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R3.M8A
Sequence Name Gonzo234 ver.3
Inj Data File 023-1302.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/9/2017 1:59 AM
File Modified 4/10/2017 3:19 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 23
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	8.25	28.7291	1.02029	0.53086	1	0.53086	ug/mL

Analyst Peak Integration Comments


09:47:31 04/10/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo234 ver.3
Inj Data File 005-2201.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/9/2017 5:17 AM
File Modified 4/10/2017 3:20 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.25	928.347	32.2493	15.0051	1	15.0051	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo234 ver.3
Inj Data File 005-2202.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/9/2017 5:29 AM
File Modified 4/10/2017 3:20 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo234.M
Method Modified 4/10/2017 2:14 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	8.24	928.902	32.1758	15.0140	1	15.0140	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #2
Sequence Name Gonzo235 2 ver.11
Inj Data File 002-0301.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 12:26 PM
File Modified 4/13/2017 10:59 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 2
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BV	7.32	64.1008	2.41874	1.10869	1	1.10869	ug/mL

Analyst Peak Integration Comments


11:16:21 04/12/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #2
Sequence Name Gonzo235 2 ver.11
Inj Data File 002-0302.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 12:38 PM
File Modified 4/13/2017 10:59 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 2
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	7.33	62.7169	2.38415	1.08660	1	1.08660	ug/mL

Analyst Peak Integration Comments


11:16:39 04/12/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #3
Sequence Name Gonzo235 2 ver.11
Inj Data File 003-0401.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 12:50 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 3
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	VB	7.32	297.634	11.1955	4.83703	1	4.83703	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #3
Sequence Name Gonzo235 2 ver.11
Inj Data File 003-0402.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 1:01 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 3
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	7.31	294.731	11.1342	4.79069	1	4.79069	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #4
Sequence Name Gonzo235 2 ver.11
Inj Data File 004-0501.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 1:13 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 4
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	7.31	597.425	22.4800	9.62317	1	9.62317	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #4
Sequence Name Gonzo235 2 ver.11
Inj Data File 004-0502.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 1:25 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 4
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	VB	7.31	598.837	22.7361	9.64572	1	9.64572	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #6
Sequence Name Gonzo235 2 ver.11
Inj Data File 006-0701.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 2:00 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 6
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	7.28	1550.85	58.9368	24.8445	1	24.8445	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #6
Sequence Name Gonzo235 2 ver.11
Inj Data File 006-0702.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 2:12 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 6
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	VB	7.28	1553.92	59.1980	24.8936	1	24.8936	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #SS
Sequence Name Gonzo235 2 ver.11
Inj Data File 008-0801.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 2:23 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 8
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	VB	7.29	354.681	13.4726	5.74778	1	5.74778	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #SS
Sequence Name Gonzo235 2 ver.11
Inj Data File 008-0802.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 2:35 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 8
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	7.28	348.428	13.3387	5.64795	1	5.64795	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #RB
Sequence Name Gonzo235 2 ver.11
Inj Data File 009-0901.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 2:47 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 9
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate		(7.40)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #RB
Sequence Name Gonzo235 2 ver.11
Inj Data File 009-0902.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 2:59 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Control
Vial Number 9
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate		(7.40)				1		ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R2.M8A
Sequence Name Gonzo235 2 ver.11
Inj Data File OnlineEdited34.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 6:18 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 31
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	7.27	26.9145	1.05028	0.46977	1	0.46977	ug/mL

Analyst Peak Integration Comments


11:35:11 04/12/17 Amelia Paolantonio NI AMP

Chromatogram Report

Enthalpy Analytical

Sample Name 0317-144.R2.M8A
Sequence Name Gonzo235 2 ver.11
Inj Data File OnlineEdited35.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 6:30 PM
File Modified 4/13/2017 11:00 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type Sample
Vial Number 31
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 10:59 AM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	7.26	25.7724	1.02266	0.44984	1	0.44984	ug/mL

Analyst Peak Integration Comments


11:35:23 04/12/17 Amelia Paolantonio NI AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #4
Sequence Name Gonzo235b ver.5
Inj Data File 004-0101.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 8:50 PM
File Modified 4/13/2017 11:01 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 4
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 11:01 AM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	VB	7.32	596.261	22.2600	9.60458	1	9.60458	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #4
Sequence Name Gonzo235b ver.5
Inj Data File 004-0102.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/11/2017 9:01 PM
File Modified 4/13/2017 11:01 AM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 4
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/13/2017 11:01 AM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	MM	7.30	596.318	22.4587	9.60550	1	9.60550	ug/mL

Analyst Peak Integration Comments


14:54:15 04/12/17 Amelia Paolantonio II AMP

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo235c ver.3
Inj Data File 005-0101.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/12/2017 11:31 AM
File Modified 4/12/2017 5:11 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/12/2017 5:11 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	7.39	893.516	33.1237	14.3502	1	14.3502	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #5
Sequence Name Gonzo235c ver.3
Inj Data File 005-0102.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/12/2017 11:43 AM
File Modified 4/12/2017 5:11 PM
Instrument Gonzo
Operator Amelia Paolantonio

Sample Type
Vial Number 5
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/12/2017 5:11 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	7.38	893.515	33.4808	14.3502	1	14.3502	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #7
Sequence Name Gonzo235d ver.3
Inj Data File 007-0101.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/12/2017 4:36 PM
File Modified 4/12/2017 5:10 PM
Instrument Gonzo
Operator Scott Wilson

Sample Type
Vial Number 7
Injection Volume 25
Injection 1 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/12/2017 5:10 PM
Printed 4/13/2017 11:23 AM




Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	7.35	3209.77	123.783	51.3291	1	51.3291	ug/mL

Chromatogram Report

Enthalpy Analytical

Sample Name HPLCStd422 #7
Sequence Name Gonzo235d ver.3
Inj Data File 007-0102.D
File Location HPLC/2017/Gonzo/Quarter 2
Injection Date 4/12/2017 4:48 PM
File Modified 4/12/2017 5:10 PM
Instrument Gonzo
Operator Scott Wilson

Sample Type
Vial Number 7
Injection Volume 25
Injection 2 of 2
Acquisition Method ANIONS!.M
Analysis Method Gonzo235.M
Method Modified 4/12/2017 5:10 PM
Printed 4/13/2017 11:23 AM



Compound	Type	RT	Area	Height	Amount	DF	SampAmt	Unit
Sulfate	BB	7.37	3197.96	123.427	51.1405	1	51.1405	ug/mL

=====
 Calibration Table
 =====

 General Calibration Setting

Calib. Data Modified : 4/10/2017 1:18:18 PM
 Signals calculated separately : No

Rel. Reference Window : 10.000 %
 Abs. Reference Window : 0.000 min
 Rel. Non-ref. Window : 10.000 %
 Abs. Non-ref. Window : 0.000 min
 Uncalibrated Peaks : not reported
 Partial Calibration : Yes, identified peaks are recalibrated
 Correct All Ret. Times: No, only for identified peaks

Curve Type : Linear (some peaks differ, see below)
 Origin : Connected (some peaks differ, see below)
 Weight : Linear (Resp) (some peaks differ, see below)

Recalibration Settings:
 Average Response : Average all calibrations
 Average Retention Time: Floating Average New 75%

Calibration Report Options :
 Printout of recalibrations within a sequence:
 Calibration Table after Recalibration
 Normal Report after Recalibration
 If the sequence is done with bracketing:
 Results of first cycle (ending previous bracket)

 Signal Details

Signal 1: ADC1 A, ADC1, A

 Overview Table

RT	Sig	Lvl	Amount [ug/mL]	Area	Rsp.Factor	Ref	ISTD #	Compound
3.027	1	1	2.47500e-1	30.75359	8.04784e-3	No	No	Fluoride
		2	5.00000e-1	59.91464	8.34521e-3			
		3	2.50000	301.39136	8.29486e-3			
		4	5.00000	594.53281	8.40996e-3			
		5	7.50000	881.81711	8.50516e-3			
		6	12.50000	1495.59534	8.35788e-3			
3.999	1	1	4.95000e-1	39.22009	1.26211e-2	No	No	Chloride
		2	1.00000	83.61354	1.19598e-2			
		3	5.00000	420.72395	1.18843e-2			
		4	10.00000	865.22369	1.15577e-2			

RT	Sig	Lvl	Amount [ug/mL]	Area	Rsp.Factor	Ref	ISTD #	Compound
		5	15.00000	1308.46045	1.14639e-2			
		6	25.00000	2264.09570	1.10419e-2			
7.463	1	1	1.60150e-2	1.00000	1.60150e-2	No	No	Sulfite as Sulfate
8.800	1	1	4.95000e-1	33.66049	1.47057e-2	No	No	Sulfate
		2	1.00000	63.18040	1.58277e-2			
		3	5.00000	294.11697	1.70000e-2			
		4	10.00000	603.78125	1.65623e-2			
		5	15.00000	912.85107	1.64320e-2			
		6	25.00000	1557.65417	1.60498e-2			
		7	50.00000	3219.44824	1.55306e-2			

More compound-specific settings

Compound: Fluoride

Curve Type : Linear
Origin : Connected
Calibration Level Weights:/
Level 1 : 1
Level 2 : 0.495
Level 3 : 0.099
Level 4 : 0.0495
Level 5 : 0.033
Level 6 : 0.0198

Compound: Chloride

Curve Type : Linear
Origin : Connected
Calibration Level Weights:/
Level 1 : 1
Level 2 : 0.495
Level 3 : 0.099
Level 4 : 0.0495
Level 5 : 0.033
Level 6 : 0.0198

Compound: Sulfite as Sulfate

Curve Type : Linear
Origin : Included
Calibration Level Weights:/
Level 1 : 1


Compound: Sulfate

Curve Type : Linear
Origin : Connected
Calibration Level Weights:/
Level 1 : 1
Level 2 : 0.495
Level 3 : 0.099
Level 4 : 0.0495
Level 5 : 0.033
Level 6 : 0.0198
Level 7 : 0.0099


Peak Sum Table

No Entries in table


=====
 Calibration Curves
 =====




Fluoride at exp. RT: 3.027
 ADC1 A, ADC1, A
 Correlation: 0.99996
 Residual Std. Dev.: 7.12704
 Formula: $y = mx + b$
 m: 118.85316
 b: 1.11670
 x: Amount[ug/mL]
 y: Area
 Calibration Level Weights:
 Level 1 : 1
 Level 2 : 0.495
 Level 3 : 0.099
 Level 4 : 0.0495
 Level 5 : 0.033
 Level 6 : 0.0198



Chloride at exp. RT: 3.999
 ADC1 A, ADC1, A
 Correlation: 0.99971
 Residual Std. Dev.: 28.85323
 Formula: $y = mx + b$
 m: 88.84809
 b: -6.35589
 x: Amount[ug/mL]
 y: Area
 Calibration Level Weights:
 Level 1 : 1
 Level 2 : 0.495
 Level 3 : 0.099
 Level 4 : 0.0495
 Level 5 : 0.033
 Level 6 : 0.0198



Sulfite as Sulfate at exp. RT: 7.463
 ADC1 A, ADC1, A
 Correlation: 1.00000
 Residual Std. Dev.: 0.00000
 Formula: $y = mx + b$
 m: 62.44146
 b: 0.00000
 x: Amount[ug/mL]
 y: Area



Sulfate at exp. RT: 8.800
ADC1 A, ADC1, A
Correlation: 0.99953
Residual Std. Dev.: 40.71689
Formula: $y = mx + b$
m: 62.80204
b: -4.87260e-1
x: Amount[ug/mL]
y: Area
Calibration Level Weights:
Level 1 : 1
Level 2 : 0.495
Level 3 : 0.099
Level 4 : 0.0495
Level 5 : 0.033
Level 6 : 0.0198
Level 7 : 0.0099

=====

=====
 Calibration Table
 =====

 General Calibration Setting

Calib. Data Modified : 4/13/2017 10:59:10 AM
 Signals calculated separately : No

Rel. Reference Window : 10.000 %
 Abs. Reference Window : 0.000 min
 Rel. Non-ref. Window : 10.000 %
 Abs. Non-ref. Window : 0.000 min
 Uncalibrated Peaks : not reported
 Partial Calibration : Yes, identified peaks are recalibrated
 Correct All Ret. Times: No, only for identified peaks

Curve Type : Linear (some peaks differ, see below)
 Origin : Connected (some peaks differ, see below)
 Weight : Linear (Resp) (some peaks differ, see below)

Recalibration Settings:
 Average Response : Average all calibrations
 Average Retention Time: Floating Average New 75%

Calibration Report Options :
 Printout of recalibrations within a sequence:
 Calibration Table after Recalibration
 Normal Report after Recalibration
 If the sequence is done with bracketing:
 Results of first cycle (ending previous bracket)

 Signal Details

Signal 1: ADC1 A, ADC1, A

 Overview Table

RT	Sig	Lvl	Amount [ug/mL]	Area	Rsp.Factor	Ref	ISTD #	Compound
2.924	1	2	5.00000e-1	55.49994	9.00902e-3	No	No	Fluoride
		3	2.50000	347.93784	7.18519e-3			
		4	5.00000	635.66467	7.86578e-3			
		5	7.50000	955.97281	7.84541e-3			
		6	12.50000	1524.34753	8.20023e-3			
3.799	1	2	1.00000	88.78718	1.12629e-2	No	No	Chloride
		3	5.00000	438.63573	1.13990e-2			
		4	10.00000	863.52417	1.15805e-2			
		5	15.00000	1289.20551	1.16351e-2			
		6	25.00000	2217.13843	1.12758e-2			

RT	Sig	Lvl	Amount [ug/mL]	Area	Rsp.Factor	Ref	ISTD #	Compound
7.400	1	2	1.00000	63.40882	1.57707e-2	No	No	Sulfate
		3	5.00000	296.18256	1.68815e-2			
		4	10.00000	598.13101	1.67187e-2			
		5	15.00000	893.51544	1.67876e-2			
		6	25.00000	1552.38635	1.61042e-2			
		7	50.00000	3203.86230	1.56062e-2			

More compound-specific settings

Compound: Fluoride

Curve Type : Linear
 Origin : Connected
 Calibration Level Weights:/
 Level 2 : 1
 Level 3 : 0.2
 Level 4 : 0.1
 Level 5 : 0.066667
 Level 6 : 0.04

Compound: Chloride

Curve Type : Linear
 Origin : Connected
 Calibration Level Weights:/
 Level 2 : 1
 Level 3 : 0.2
 Level 4 : 0.1
 Level 5 : 0.066667
 Level 6 : 0.04


Compound: Sulfate

Curve Type : Linear
 Origin : Connected
 Calibration Level Weights:/
 Level 2 : 1
 Level 3 : 0.2
 Level 4 : 0.1
 Level 5 : 0.066667
 Level 6 : 0.04
 Level 7 : 0.02


Peak Sum Table

No Entries in table


=====
 Calibration Curves
 =====



Fluoride at exp. RT: 2.924
 ADC1 A, ADC1, A
 Correlation: 0.99873
 Residual Std. Dev.: 35.27349
 Formula: $y = mx + b$
 m: 125.85635
 b: -9.11004e-1
 x: Amount[ug/mL]
 y: Area
 Calibration Level Weights:
 Level 2 : 1
 Level 3 : 0.2
 Level 4 : 0.1
 Level 5 : 0.066667
 Level 6 : 0.04



Chloride at exp. RT: 3.799
 ADC1 A, ADC1, A
 Correlation: 0.99985
 Residual Std. Dev.: 23.09739
 Formula: $y = mx + b$
 m: 87.42920
 b: 2.51173e-1
 x: Amount[ug/mL]
 y: Area
 Calibration Level Weights:
 Level 2 : 1
 Level 3 : 0.2
 Level 4 : 0.1
 Level 5 : 0.066667
 Level 6 : 0.04



Sulfate at exp. RT: 7.400
 ADC1 A, ADC1, A
 Correlation: 0.99945
 Residual Std. Dev.: 45.83420
 Formula: $y = mx + b$
 m: 62.63730
 b: -5.34463
 x: Amount[ug/mL]
 y: Area
 Calibration Level Weights:
 Level 2 : 1
 Level 3 : 0.2
 Level 4 : 0.1
 Level 5 : 0.066667
 Level 6 : 0.04
 Level 7 : 0.02

Method Information

Method: C:\HPLC\2014\Gonzo\Methods\ANIONS!.M
Modified: 1/21/2014 at 1:54:20 PM

Column: Dionex AS14A 250*4mm Anion Exchange Column
Mobile Phase: 8mm Na2CO3/1mm NaHCO3
Flow Rate: 1.2mL/min

Method Audit Trail

Operator : Amelia Paolantonio
Date : 1/21/2014 1:54:19 PM
Change Info: This method was created at 1/21/2014 1:54:19 PM and based on
method C:\HPLC\2014\GONZO\METHODS\ANIONS_SLOW.M

Operator : Amelia Paolantonio
Date : 1/21/2014 1:54:20 PM
Change Info: Method saved. User comment: ""

Run Time Checklist

Pre-Run Cmd/Macro: off
Data Acquisition: on
Standard Data Analysis: on
Customized Data Analysis: off
Save GLP Data: off
Post-Run Cmd/Macro: off
Save Method with Data: off

=====

ANALOG DIGITAL CONVERTER

=====

Signal 1

Description: ADC1 CHANNEL B
Source: Signal
Unit: mAU
Units/Volt: 1000.000
Peakwidth (Data Rate): 0.027 Min (10.00 Hz)
Stop Time: No Limit
Data Storage: All

Start Signal Source: External Device Will Start 35900

Timed Event Table:
<no events>

=====
Agilent 1100 Autosampler 1
=====

Injection

Injection Mode : Needle Wash
Injector volume : 25.00 µl
Wash Vial : 100
Optimization : Prefetch Sample Vial
9.00 min. after Injection

Auxiliary

Drawspeed : 100 µl/min
Ejectspeed : 100 µl/min
Draw position : 0.0 mm

Time

Stoptime : As Pump
Posttime : Off

**This Is The Last Page
Of This Report.**



A Waters Company

April 21, 2017

Joseph Conti
CEM Solutions
1183 E. Overdrive Circle
Hernando, FL 34442

Enclosed is your final report for ERA's Stationary Source Audit Sample (SSAS) Program. Your final report includes an evaluation of all results submitted by your laboratory to ERA.

Data Evaluation Protocols: All analytes in ERA's SSAS Program have been evaluated comparing the reported result to the acceptance limits generated using the criteria contained in the TNI SSAS Table.

For any "Not Acceptable" results, please contact your state regulator for any corrective action requirements.

Thank you for your participation in ERA's SSAS Program. If you have any questions, please contact our Proficiency Testing Department at 1-800-372-0122.

Sincerely,

A handwritten signature in black ink that reads "Patrick Larson". The signature is fluid and cursive, with a large initial "P" and "L".

Patrick Larson
Quality Officer

cc: Project File Number 101315B



A Waters Company

Recipient Type	Report Recipient	Contact	Project ID
Agency	FL DEP - NE District (SSAS) 8800 Baymeadows Way West Suite 100 Jacksonville, FL 32256 USA	Christopher Kirts christopher.kirts@dep.state.fl.us Phone: 904-256-1700	
Facility	GREC 11201 NW US Hwy 441 Gainesville, FL 32653 USA	Ali Leaphart ali.leaphart@grecbiomass.com Phone: 386-315-8019	
Lab	Enthalpy Analytical Inc 800-1 Capitola Drive Durham, NC 27713 USA	Bryan Tyler bryan.tyler@enthalpy.com Phone: 919-850-4392 Fax: 919-850-9012	
Tester	CEM Solutions 1183 E. Overdrive Circle Harnando, FL 34442 USA	Joseph Conti jconti@cem-solutions.com Phone: (352) 489-4337	



Project # : 101315B





A Waters Company

101315B Laboratory Exception Report

Bryan Tyler
Enthalpy Analytical Inc
800-1 Capitola Drive
Durham, NC 27713
919-850-4392

EPA ID:
ERA Customer Number:

Not Reported
E778021

Evaluation Checks

There are no values reported with < where the assigned value was greater than 0.

Not Acceptable Evaluations

There were no Not Acceptable evaluations for this study.





Final Report Results For Laboratory Enthalpy Analytical Inc





SSAP Evaluation Report
Project Number: **101315B**
ERA Customer Number: **E778021**
Laboratory Name: **Enthalpy Analytical Inc**

Inorganic Results





A Waters Company

101315B Evaluation Final Complete Report

Bryan Tyler
Enthalpy Analytical Inc
800-1 Capitola Drive
Durham, NC 27713
919-850-4392

EPA ID:
ERA Customer Number:

Not Reported
E778021

TNI Analyte Code	Analyte	Units	Reported Value	Assigned Value	Acceptance Limits	Performance Evaluation	Method Description	Analysis Date	Analyst Name
------------------	---------	-------	----------------	----------------	-------------------	------------------------	--------------------	---------------	--------------

SSAP Hydrogen Halides in Impinger Solution (cat# 1440, lot# 101315B) Study Dates: 10/13/15 - 04/21/17

1770	Hydrogen Chloride	mg/L	19.6	19.2	17.3 - 21.1	Acceptable	EPA 26A 2000	4/5/2017	
1775	Hydrogen Fluoride	mg/L	18.1	17.9	16.1 - 19.7	Acceptable	EPA 26A 2000	4/5/2017	





FINAL LAB REPORT

Prepared by

SGS NORTH AMERICA

Prepared for

This report is approved by

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

SGS remains committed to serving you in the most effective manner. Should you have any questions or need additional information and technical support, please do not hesitate to contact us.

The management and staff of SGS welcomes customer feedback, both positive and negative, as we continually improve our services. Please visit our web site at www.sgs.com/ultratrace and click on the 'Email Us' link or go to our survey [here](#). Thank you for choosing SGS.

Any holder of this document is advised that it is a final submission and supersedes and voids all prior reports with the same report or identification number. The information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility in conducting the work herein is to its Client and does not exonerate parties to a transaction from exercising all of their rights and obligations under such applicable transaction documents. This report may be reproduced in full only. The Company expressly disclaims any and all liability for the Client's use of or reliance upon the data contained herein. Any alteration, forgery or falsification of the content or appearance of this document which is not expressly authorized by the Company is unlawful and offenders may be prosecuted to the fullest extent of the law. Results reported relate only to the items tested.



PROJECT INFORMATION SUMMARY *(When applicable, see QC Annotations for details)*

Client Project
SGS Project #
Analytical Protocol(s)
No. Samples Submitted
Additional QC Sample(s)
No. Laboratory Method Blanks
No. OPRs / Batch CS3
Date Received
Condition Received
Temperature upon Receipt (°C)
Extraction within Holding Time
Analysis within Holding Time



QC ANNOTATIONS:

1. Please see Appendices attached for data qualifier/attribute and lab identifier descriptions which may be contained in the project.

APPENDIX A: GENERAL DATA QUALIFIERS / DATA ATTRIBUTES

B	The analyte was found in the method blank, at a concentration that was at least 10% of the concentration in the sample.
C	Two or more congeners co-elute. In EDDs, C denotes the lowest IUPAC congener in a co-elution group and additional co-eluters for the group are shown with the number of the lowest IUPAC co-eluter.
E	The reported concentration exceeds the calibration range (upper point of the calibration curve) and is an estimated value.
EMPC	Represents an Estimated Maximum Possible Concentration. EMPCs arise in cases where the signal/noise ratio is not sufficient for peak identification (the determined ion-abundance ratio is outside the allowed theoretical range), or where there is a co-eluting interference.
H/h	If the standard recovery is below the method or SOP specified value "H" is assigned. If the obtained value is less than half the specified value "h" is assigned.
J	Indicates that an analyte has a concentration below the reporting limit (lowest point of the calibration curve) and is an estimated value.
ND	Indicates a non-detect.
NR or R	Indicates a value that is not reportable.
PR	Due to interference, the associated congener is poorly resolved.
QI	Indicates the presence of a quantitative interference.
SI	Denotes "Single Ion Mode" and is utilized for PCBs where the secondary ion trace has a significantly elevated noise level due to background PFK. Responses for such peaks are calculated using an EMPC approach based solely on the primary ion area(s) and may be considered estimates.
U	The analyte was not detected. The estimated detection limit (EDL) may be reported for this analyte.
V	The labeled standard recovery was found to be outside of the method control limits.



APPENDIX B: DRBC/TMDL SPECIFIC DATA QUALIFIERS / DATA ATTRIBUTES

J	The reported result is an estimate. The value is less than the minimum calibration level but greater than the estimated detection limit (EDL).
U	The analyte was not detected in the sample at the estimated detection limit (EDL).
E	The reported concentration is an estimate. The value exceeds the upper calibration range (upper point of the calibration curve).
D	Dilution Data. Result was obtained from the analysis of a dilution.
B	Analyte found in the sample and associated method blank.
C	Co-eluting congener
Cxx	Co-elutes with the indicated congener, data is reported under the lowest IUPAC congener. 'Xx' denotes the IUPAC number with the lowest numerical designated congener.
NR	Analyte is not reportable because of problems in sample preparation or analysis.
V	Labeled standard recovery is not within method control limits.
X	Results from re-injection/repeat/second-column analysis.
EMPC	Estimated maximum possible concentration. Indicates that a peak is identified but did not meet the method specified ion-abundance ratio.

APPENDIX C: LAB IDENTIFIERS

AR	Indicates use of the archived portion of the sample extract.
CU	Indicates a sample that required additional clean-up prior to MS injection/processing.
D	Indicates a dilution of the sample extract. The number that follows the "D" indicates the dilution factor.
DE	Indicates a dilution performed with the addition of ES (extraction standard) solution.
DUP	Designation for a duplicate sample.
MS	Designation for a matrix spike.
MSD	Designation for a matrix spike duplicate.
RJ	Indicates a reinjection of the sample extract.
S	Indicates a sample split. The number that follows the "S" indicates the split factor.




SGS CERTIFICATIONS

Arkansas	88-0682
California (ELAP)	ELAP Cert #2914
CLIA	34D1013708
Connecticut	PH-0258
USDA Soil Permit	P330-14-00135
DoD	2726.01
Florida (Primary NELAP)	E87634
ISO 17025/IEC	2726.01
Louisiana	4115
Maine	#2016028
Massachusetts	M-NC919
Minnesota (Primary NELAP For Method 23)	Lab #037-999-459 Cert #981125
New Jersey	NC100
New York	11685
North Carolina DWR	481
North Dakota	R-197
Oregon	NC200002
Pennsylvania	68-03675
South Carolina	Lab #99029 Cert #99029002
Texas	T104704260-16-9
US Coast Guard	16714/159.317/SGS
Virginia	Lab #460214 Cert #8722
Washington	C913
West Virginia	293

Rev. 12-Sep-2016

A9782 - TEQ


Project ID: 11542

Sample Summary Part 1				Method 23	
Analyte	Method Blank A9782_14768	Run 1	Run 2	Run 3	
	pg	pg	pg	pg	
2,3,7,8-TCDD	(3.34)	(3.63)	(4.74)	(3.23)	
1,2,3,7,8-PeCDD	(2.98)	(4.06)	(5.67)	(4.04)	
1,2,3,4,7,8-HxCDD	(3.22)	(3.12)	(6.02)	(3.6)	
1,2,3,6,7,8-HxCDD	(3.23)	(3.34)	(6.08)	(3.69)	
1,2,3,7,8,9-HxCDD	(3.51)	(3.47)	(6.05)	(3.87)	
1,2,3,4,6,7,8-HpCDD	(4.8)	(3.99)	(5.39)	(4.8)	
OCDD	(9.1)	(9.63)	(14.6)	(11.1)	
2,3,7,8-TCDF	(3.07)	(3.63)	(4.54)	(3.2)	
1,2,3,7,8-PeCDF	(2.56)	(2.75)	(4.11)	(2.68)	
2,3,4,7,8-PeCDF	(2.59)	(2.59)	(4.06)	(2.58)	
1,2,3,4,7,8-HxCDF	(2.79)	(2.64)	(4.62)	(3.09)	
1,2,3,6,7,8-HxCDF	(2.48)	(2.35)	(4.24)	(2.86)	
2,3,4,6,7,8-HxCDF	(2.64)	(2.64)	(4.81)	(3.01)	
1,2,3,7,8,9-HxCDF	(3)	(3.17)	(5.33)	(3.44)	
1,2,3,4,6,7,8-HpCDF	(3.15)	(2.61)	(3.78)	(3.07)	
1,2,3,4,7,8,9-HpCDF	(4.21)	(3.97)	(4.33)	(4.28)	
OCDF	(9.35)	(8.59)	(12.9)	(9.05)	
WHO-2005 TEQ (ND=0; EMPC=0)	0	0	0	0	
WHO-2005 TEQ (ND=0; EMPC=EMPC)	0	0	0	0	
WHO-2005 TEQ (ND=DL/2; EMPC=0)	4.84	5.55	8.03	5.47	
WHO-2005 TEQ (ND=DL/2; EMPC=EMPC)	4.84	5.55	8.03	5.47	
WHO-2005 TEQ (ND=DL; EMPC=EMPC)	9.69	11.1	16.1	10.9	
Checkcode	688-738-KHC	346-815-FKJ	042-346-WHX	381-737-YCT	
Lab ID	MB1_14768_DF_SDS	A9782_14768_DF_001	A9782_14768_DF_002	A9782_14768_DF_003	

() = DL
[] = EMPC

A9782 - Totals

Project ID: 11542


Sample Summary Part 2				Method 23	
Analyte	Method Blank A9782_14768	Run 1	Run 2	Run 3	
	pg	pg	pg	pg	
Totals					
TCDDs	0	20.2	0	0	
PeCDDs	0	8.14	17.4	0	
HxCDDs	0	6.39	0	0	
HpCDDs	0	0	0	0	
OCDD	0	0	0	0	
TCDFs	0	0	0	0	
PeCDFs	0	0	0	0	
HxCDFs	0	0	0	0	
HpCDFs	0	0	0	0	
OCDF	0	0	0	0	
Total PCDD/Fs (ND=0; EMPC=0)	0	34.7	17.4	0	
Total PCDD/Fs (ND=0; EMPC=EMPC)	0	34.7	26.7	9.18	
Total PCDD/Fs (2378-X ND=DL; EMPC=EMPC)	66	101	128	80.7	
Total 2378s (ND=0; EMPC=0)	0	0	0	0	
Total 2378s (ND=0.5; EMPC=0)	33	33.1	50.6	35.8	
Total 2378s (ND=1; EMPC=0)	66	66.2	101	71.6	
Total 2378s (ND=0; EMPC=1)	0	0	0	0	
Total 2378s (ND=0.5; EMPC=1)	33	33.1	50.6	35.8	
Total 2378s (ND=1; EMPC=1)	66	66.2	101	71.6	
Checkcode	688-738-KHC	346-815-FKJ	042-346-WHX	381-737-YCT	
Lab ID	MB1_14768_DF_SDS	A9782_14768_DF_001	A9782_14768_DF_002	A9782_14768_DF_003	

Total 2378s = Sum of 17 2378-substituted PCDD/PCDF congeners (SARA 313)

() = DL
[] = EMPC

A9782 - Others


Project ID: 11542

Sample Summary Part 3				Method 23	
Analyte	Method Blank A9782_14768 pg	Run 1 pg	Run 2 pg	Run 3 pg	
Other PCDD/Fs (ND=0, EMPC=0)					
Other TCDD	0	20.2	0	0	
Other PeCDD	0	8.14	17.4	0	
Other HxCDD	0	6.39	0	0	
Other HpCDD	0	0	0	0	
Other TCDF	0	0	0	0	
Other PeCDF	0	0	0	0	
Other HxCDF	0	0	0	0	
Other HpCDF	0	0	0	0	
Other PCDD/Fs (ND=0, EMPC=EMPC)					
Other TCDD	0	20.2	9.34	9.18	
Other PeCDD	0	8.14	17.4	0	
Other HxCDD	0	6.39	0	0	
Other HpCDD	0	0	0	0	
Other TCDF	0	0	0	0	
Other PeCDF	0	0	0	0	
Other HxCDF	0	0	0	0	
Other HpCDF	0	0	0	0	
Checkcode	688-738-KHC	346-815-FKJ	042-346-WHX	381-737-YCT	
Lab ID	MB1_14768_DF_SDS	A9782_14768_DF_001	A9782_14768_DF_002	A9782_14768_DF_003	

() = DL
[] = EMPC


A9782 - DLs

Project ID: 11542

Sample Summary Part 5 (DLs)					Method 23
Analyte	Method Blank A9782_14768	Run 1	Run 2	Run 3	
	pg	pg	pg	pg	
2,3,7,8-TCDD	3.34	3.63	4.74	3.23	
1,2,3,7,8-PeCDD	2.98	4.06	5.67	4.04	
1,2,3,4,7,8-HxCDD	3.22	3.12	6.02	3.6	
1,2,3,6,7,8-HxCDD	3.23	3.34	6.08	3.69	
1,2,3,7,8,9-HxCDD	3.51	3.47	6.05	3.87	
1,2,3,4,6,7,8-HpCDD	4.8	3.99	5.39	4.8	
OCDD	9.1	9.63	14.6	11.1	
2,3,7,8-TCDF	3.07	3.63	4.54	3.2	
1,2,3,7,8-PeCDF	2.56	2.75	4.11	2.68	
2,3,4,7,8-PeCDF	2.59	2.59	4.06	2.58	
1,2,3,4,7,8-HxCDF	2.79	2.64	4.62	3.09	
1,2,3,6,7,8-HxCDF	2.48	2.35	4.24	2.86	
2,3,4,6,7,8-HxCDF	2.64	2.64	4.81	3.01	
1,2,3,7,8,9-HxCDF	3	3.17	5.33	3.44	
1,2,3,4,6,7,8-HpCDF	3.15	2.61	3.78	3.07	
1,2,3,4,7,8,9-HpCDF	4.21	3.97	4.33	4.28	
OCDF	9.35	8.59	12.9	9.05	
Total TCDD	3.34	3.63	4.74	3.23	
Total PeCDD	2.98	4.06	5.67	4.04	
Total HxCDD	3.31	3.3	6.03	3.71	
Total HpCDD	4.8	3.99	5.39	4.8	
Total TCDF	3.07	3.63	4.54	3.2	
Total PeCDF	2.58	2.67	4.09	2.63	
Total HxCDF	2.71	2.67	4.71	3.08	
Total HpCDF	3.63	3.22	4.04	3.62	
Checkcode	688-738-KHC	346-815-FKJ	042-346-WHX	381-737-YCT	
Lab ID	MB1_14768_DF_SDS	A9782_14768_DF_001	A9782_14768_DF_002	A9782_14768_DF_003	


WHO-2005-TEQ
Project ID: 11542
A9782

- ND=0; EMPC=0
- ND=0; EMPC=EMPC
- ND=DL/2; EMPC=0
- ND=DL/2; EMPC=EMPC
- ND=DL; EMPC=EMPC



Totals Project ID: 11542 A9782

- Total PCDD/Fs (ND=0; EMPC=0)
- Total PCDD/Fs (ND=0; EMPC=EMPC)
- Total PCDD/Fs (2378-X ND=DL; EMPC=EMPC)




Mean Recoveries of Extraction Standards (N=4)

Project ID: 11542


A9782




Mean Std. Dev.







Mean Recoveries of Sampling Standards (N=4)
Project ID: 11542
A9782

Mean Std. Dev.







Sample ID: Run 1

Method 23

Client Data		Sample Data		Laboratory Data			
Name:	C.E.M. Solutions, Inc.	Matrix:	Air	Lab Project ID:	A9782	Date Received:	28-Mar-2017
Project ID:	11542	Weight/Volume:	1	Lab Sample ID:	A9782_14768_DF_001	Date Extracted:	30-Mar-2017
Date Collected:	22-Mar-2017	Split:	2	QC Batch No:	14768	Date Analyzed:	06-Apr-2017
				Dilution:	-	Time Analyzed:	20:04:04
Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	ND	3.63			ES 2378-TCDD	86.4	
12378-PeCDD	ND	4.06			ES 12378-PeCDD	92	
123478-HxCDD	ND	3.12			ES 123478-HxCDD	87.3	
123678-HxCDD	ND	3.34			ES 123678-HxCDD	86.6	
123789-HxCDD	ND	3.47			ES 123789-HxCDD	86.8	
1234678-HpCDD	ND	3.99			ES 1234678-HpCDD	84.5	
OCDD	ND	9.63			ES OCDD	63	
2378-TCDF	ND	3.63			ES 2378-TCDF	84.4	
12378-PeCDF	ND	2.75			ES 12378-PeCDF	91.2	
23478-PeCDF	ND	2.59			ES 23478-PeCDF	94.9	
123478-HxCDF	ND	2.64			ES 123478-HxCDF	84.3	
123678-HxCDF	ND	2.35			ES 123678-HxCDF	86.4	
234678-HxCDF	ND	2.64			ES 234678-HxCDF	83.1	
123789-HxCDF	ND	3.17			ES 123789-HxCDF	86.3	
1234678-HpCDF	ND	2.61			ES 1234678-HpCDF	83.8	
1234789-HpCDF	ND	3.97			ES 1234789-HpCDF	84.9	
OCDF	ND	8.59			ES OCDF	71.5	
Totals					Standard	SS/AS Recoveries	
Total TCDD	20.2		20.2		SS 37Cl-2378-TCDD	100	
Total PeCDD	8.14		8.14		SS 12347-PeCDD	103	
Total HxCDD	6.39		6.39		SS 12346-PeCDF	97.6	
Total HpCDD	ND	3.99	ND		SS 123469-HxCDF	102	
Total TCDF	ND	3.63	ND		SS 1234689-HpCDF	103	
Total PeCDF	ND	2.67	ND		AS 1368-TCDD	79.6	
Total HxCDF	ND	2.67	ND		AS 1368-TCDF	81.2	
Total HpCDF	ND	3.22	ND				
Total PCDD/Fs	34.7		34.7				
WHO-2005 TEQs							
TEQ: ND=0	0		0				
TEQ: ND=DL/2	5.55	5.55	5.55				
TEQ: ND=DL	11.1	11.1	11.1				



5500 Business Drive
Wilmington, NC 28405, USA
www.us.sgs.com
Tel: +1 910 794-1613; Toll-Free 866 846-8290

Sample ID: Run 2

Method 23

Client Data		Sample Data		Laboratory Data			
Name:	C.E.M. Solutions, Inc.	Matrix:	Air	Lab Project ID:	A9782	Date Received:	28-Mar-2017
Project ID:	11542	Weight/Volume:	1	Lab Sample ID:	A9782_14768_DF_002	Date Extracted:	30-Mar-2017
Date Collected:	23-Mar-2017	Split:	2	QC Batch No:	14768	Date Analyzed:	06-Apr-2017
				Dilution:	-	Time Analyzed:	20:53:12
Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	ND	4.74			ES 2378-TCDD	84.3	
12378-PeCDD	ND	5.67			ES 12378-PeCDD	88.6	
123478-HxCDD	ND	6.02			ES 123478-HxCDD	86.8	
123678-HxCDD	ND	6.08			ES 123678-HxCDD	85.4	
123789-HxCDD	ND	6.05			ES 123789-HxCDD	86.2	
1234678-HpCDD	ND	5.39			ES 1234678-HpCDD	87.8	
OCDD	ND	14.6			ES OCDD	63.3	
2378-TCDF	ND	4.54			ES 2378-TCDF	88.2	
12378-PeCDF	ND	4.11			ES 12378-PeCDF	90.4	
23478-PeCDF	ND	4.06			ES 23478-PeCDF	92.4	
123478-HxCDF	ND	4.62			ES 123478-HxCDF	84.2	
123678-HxCDF	ND	4.24			ES 123678-HxCDF	87	
234678-HxCDF	ND	4.81			ES 234678-HxCDF	81.9	
123789-HxCDF	ND	5.33			ES 123789-HxCDF	86.9	
1234678-HpCDF	ND	3.78			ES 1234678-HpCDF	83.1	
1234789-HpCDF	ND	4.33			ES 1234789-HpCDF	82.2	
OCDF	ND	12.9			ES OCDF	71.5	
Totals					Standard	SS/AS Recoveries	
Total TCDD	ND		9.34		SS 37Cl-2378-TCDD	101	
Total PeCDD	17.4		17.4		SS 12347-PeCDD	103	
Total HxCDD	ND	6.03	ND		SS 12346-PeCDF	103	
Total HpCDD	ND	5.39	ND		SS 123469-HxCDF	103	
Total TCDF	ND	4.54	ND		SS 1234689-HpCDF	98.1	
Total PeCDF	ND	4.09	ND		AS 1368-TCDD	79	
Total HxCDF	ND	4.71	ND		AS 1368-TCDF	85	
Total HpCDF	ND	4.04	ND				
Total PCDD/Fs	17.4		26.7				
WHO-2005 TEQs							
TEQ: ND=0	0		0				
TEQ: ND=DL/2	8.03	8.03	8.03				
TEQ: ND=DL	16.1	16.1	16.1				




5500 Business Drive
 Wilmington, NC 28405, USA
 www.us.sgs.com

Tel: +1 910 794-1613; Toll-Free 866 846-8290

Sample ID: Run 3

Method 23

Client Data		Sample Data		Laboratory Data			
Name:	C.E.M. Solutions, Inc.	Matrix:	Air	Lab Project ID:	A9782	Date Received:	28-Mar-2017
Project ID:	11542	Weight/Volume:	1	Lab Sample ID:	A9782_14768_DF_003	Date Extracted:	30-Mar-2017
Date Collected:	23-Mar-2017	Split:	2	QC Batch No:	14768	Date Analyzed:	06-Apr-2017
				Dilution:	-	Time Analyzed:	21:42:20
Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	ND	3.23			ES 2378-TCDD	89.7	
12378-PeCDD	ND	4.04			ES 12378-PeCDD	92.2	
123478-HxCDD	ND	3.6			ES 123478-HxCDD	87.3	
123678-HxCDD	ND	3.69			ES 123678-HxCDD	84.4	
123789-HxCDD	ND	3.87			ES 123789-HxCDD	85.7	
1234678-HpCDD	ND	4.8			ES 1234678-HpCDD	83.7	
OCDD	ND	11.1			ES OCDD	65.9	
2378-TCDF	ND	3.2			ES 2378-TCDF	89.7	
12378-PeCDF	ND	2.68			ES 12378-PeCDF	95.7	
23478-PeCDF	ND	2.58			ES 23478-PeCDF	97.4	
123478-HxCDF	ND	3.09			ES 123478-HxCDF	84.5	
123678-HxCDF	ND	2.86			ES 123678-HxCDF	85.3	
234678-HxCDF	ND	3.01			ES 234678-HxCDF	83.3	
123789-HxCDF	ND	3.44			ES 123789-HxCDF	88.1	
1234678-HpCDF	ND	3.07			ES 1234678-HpCDF	80.8	
1234789-HpCDF	ND	4.28			ES 1234789-HpCDF	83.2	
OCDF	ND	9.05			ES OCDF	71.5	
Totals					Standard	SS/AS Recoveries	
Total TCDD	ND		9.18		SS 37Cl-2378-TCDD	98.8	
Total PeCDD	ND	4.04	ND		SS 12347-PeCDD	100	
Total HxCDD	ND	3.71	ND		SS 12346-PeCDF	95.7	
Total HpCDD	ND	4.8	ND		SS 123469-HxCDF	100	
					SS 1234689-HpCDF	101	
Total TCDF	ND	3.2	ND		AS 1368-TCDD	79.6	
Total PeCDF	ND	2.63	ND		AS 1368-TCDF	82	
Total HxCDF	ND	3.08	ND				
Total HpCDF	ND	3.62	ND				
Total PCDD/Fs	ND		9.18				
WHO-2005 TEQs							
TEQ: ND=0	0		0				
TEQ: ND=DL/2	5.47	5.47	5.47				
TEQ: ND=DL	10.9	10.9	10.9				




5500 Business Drive
 Wilmington, NC 28405, USA
 www.us.sgs.com
 Tel: +1 910 794-1613; Toll-Free 866 846-8290

Sample ID: Method Blank A9782_14768

Method 23

Client Data		Sample Data		Laboratory Data			
Name:	C.E.M. Solutions, Inc.	Matrix:	Air	Lab Project ID:	A9782	Date Received:	n/a
Project ID:	11542	Weight/Volume:	1	Lab Sample ID:	MB1_14768_DF_SDS	Date Extracted:	30-Mar-2017
Date Collected:	n/a	Split:	2	QC Batch No:	14768	Date Analyzed:	06-Apr-2017
				Dilution:	-	Time Analyzed:	19:14:57
Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	ND	3.34			ES 2378-TCDD	89.8	
12378-PeCDD	ND	2.98			ES 12378-PeCDD	90.5	
123478-HxCDD	ND	3.22			ES 123478-HxCDD	94.1	
123678-HxCDD	ND	3.23			ES 123678-HxCDD	91.3	
123789-HxCDD	ND	3.51			ES 123789-HxCDD	92.2	
1234678-HpCDD	ND	4.8			ES 1234678-HpCDD	92.8	
OCDD	ND	9.1			ES OCDD	70.2	
2378-TCDF	ND	3.07			ES 2378-TCDF	91	
12378-PeCDF	ND	2.56			ES 12378-PeCDF	97.7	
23478-PeCDF	ND	2.59			ES 23478-PeCDF	97.7	
123478-HxCDF	ND	2.79			ES 123478-HxCDF	91.9	
123678-HxCDF	ND	2.48			ES 123678-HxCDF	94.1	
234678-HxCDF	ND	2.64			ES 234678-HxCDF	90.9	
123789-HxCDF	ND	3			ES 123789-HxCDF	96	
1234678-HpCDF	ND	3.15			ES 1234678-HpCDF	92.1	
1234789-HpCDF	ND	4.21			ES 1234789-HpCDF	91.1	
OCDF	ND	9.35			ES OCDF	79.4	
Totals					Standard	SS/AS Recoveries	
Total TCDD	ND	3.34	ND		SS 37Cl-2378-TCDD	100	
Total PeCDD	ND	2.98	ND		SS 12347-PeCDD	105	
Total HxCDD	ND	3.31	ND		SS 12346-PeCDF	101	
Total HpCDD	ND	4.8	ND		SS 123469-HxCDF	98.1	
					SS 1234689-HpCDF	101	
Total TCDF	ND	3.07	ND		AS 1368-TCDD	78.4	
Total PeCDF	ND	2.58	ND		AS 1368-TCDF	81.6	
Total HxCDF	ND	2.71	ND				
Total HpCDF	ND	3.63	ND				
Total PCDD/Fs	ND		ND				
WHO-2005 TEQs							
TEQ: ND=0	0		0				
TEQ: ND=DL/2	4.84	4.84	4.84				
TEQ: ND=DL	9.69	9.69	9.69				



5500 Business Drive
Wilmington, NC 28405, USA
www.us.sgs.com
Tel: +1 910 794-1613; Toll-Free 866 846-8290




1183 E. Overdrive Circle • Hernando, FL 34442 • Ph: (352) 489-4337 • Fax: (352) 489-4801

www.cem-solutions.com

A9782 1/1

Chain of Custody Record

Project # 11542		Project Name: GREC Boiler Compliance				# of Containers	Filter	Acetone/DCM Rinse	Toluene Rinse	XAD Trap										Comments	
Samplers: CRH/MB/TC/AL																					
Sample ID	Date	Test Method	Comp.	Grab	Sample Location																
Run 1	3/22/2017	23	X		Boiler Stack	4	x	x	x	x											
Run 2	3/23/2017	23	X		Boiler Stack	4	x	x	x	x										B2837-005	
Run 3	3/23/2017	23	X		Boiler Stack	4	x	x	x	x										T2837-001	
																				T2837-004	
Relinquished by:		Date:	Time:	Received By:		Relinquished By:		Date:	Time:	Received By:		Relinquished By:		Date:	Time:	Received By:					
<i>Les Horvath</i>		3/27/17	9:35	<i>Gemma McCall</i>		<i>Gemma McCall</i>		03/28/17	11:30	<i>Ashley Owens</i>											
Relinquished by:		Date:	Time:	Received By:		Relinquished By:		Date:	Time:	Received By:		Relinquished By:		Date:	Time:	Received By:					
Received for Lab By:		Date:	Time:	Remarks:																	
<i>Ashley Owens</i>		3/28/17	11:30	<i>STD TAT. / Rec'd @ 6.4° - coming to temp.</i>																	

Type & Quantity of Sampling Modules Qty. XAD Traps: <u>5</u> Resin Batch No.: <u>51867</u> Qty. PUF: <u>N/A</u> PUF Batch No.: <u>N/A</u> Filter Size: <u>82.6 mm</u> Qty. Filter: <u>7</u> Filter Batch #: <u>9752443</u> Qty. Petri Dishes: <u>5</u> # of BCS3 & MB: <u>1</u> Client Specific Instructions Other Requirements # Rinse Jars: <u>0</u> # CarboPacs: <u>0</u> Spike Profile Vol. PCDD/F: 40µL Solution ID: <u>DF 59</u> Amount: <u>1.6-4 ng</u> Vial ID: <u>15-250-5</u> Expiration: <u>12/5/14</u> Vol. HR_PAH: 80 µL (40ng) Solution ID: _____ Amount: <u>0.5 ng/µL</u> Vial ID: _____ Expiration: _____ Vol. HR_PCB: 40 µL (4ng) Solution ID: _____ Amount: <u>0.1 ng/µL</u> Vial ID: _____ Expiration: _____	 Sampling Module Request Form Trap Order #: T2837 Following sample recovery, please return this form with the field samples to: 5500 Business Dr. Wilmington, NC 28405 Ph.: 910-794-1613 Fax.: 910-794-3919 Please be aware of your trap batch # QC begins when we prep your traps. The Method Blanks and BCS ₃ are prepared simultaneously with the trap and are properly stored until the trap batch returns for analysis. We recommend keeping trap batches together and if a set of traps is to be split into multiple projects, please let us know so we can prepare extra Method Blanks/BCS ₃ Spike By: <u>Hc 3/15/17</u> Witness: <u>om 3/15/17</u>	Client Information Company: <u>C.E.M. Solutions, Inc.</u> Contact: <u>Charles Horton</u> Email: <u>CHorton@CEM-solutions.com</u> Phone: <u>(352) 464-0372</u> Project Name: <u>12582-20</u> PO#: <u>12582-20</u> Order Date: <u>10-Mar-17</u> Arrival Date: <u>16-Mar-17</u> Ship To: <u>C.E.M. Solutions, Inc.</u> <u>Charles Horton</u> <u>1183 E. Overdrive Circle</u> <u>Hernando, FL 34442</u> <u>USA</u> <u>CHorton@CEM-solutions.com</u> <u>(352) 464-0372</u> <i>All PROJECTS ARE SHIPPED PRIORITY OVERNIGHT VIA FEDEX</i> Analyses <u>Rec'd 3used / 2unused = 3/28/17</u> <u>PCDD/F A9782</u> <u>A0</u> Additional Information AP Rental Traps Qty.: <u>5</u> Air Bill #: _____ # Containers: _____ Ship Date: _____
--	---	---

Appendix G: Accreditations and Certifications

Accredited Air Emission Testing Body


A2LA has accredited

C.E.M. SOLUTIONS, INC.

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this organization is accredited to perform testing activities in compliance with ASTM D7036 - Standard Practice for Competence of Air Emission Testing Bodies.



Presented this 24th day of November 2015.



President & CEO

Certificate Number 3820.01

Valid to December 31, 2017

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

CHARLES R. HORTON

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED
EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES
ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

**MANUAL GAS VOLUME MEASUREMENTS AND ISOKINETIC PARTICULATE
SAMPLING METHODS**

ISSUED THIS 26TH DAY OF NOVEMBER 2013 AND EFFECTIVE UNTIL NOVEMBER 25TH, 2018

Peter R. Westlin, QSTI/QSTO Review Board

C. David Bagwell, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board

Karen D. Kajiya-Mills, QSTI/QSTO Review Board

LeRoy Owens, QSTI/QSTO Review Board

Glenn C. England, QSTI/QSTO Review Board

APPLICATION
NO.
2008-230



SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

CHARLES R. HORTON

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

MANUAL GASEOUS POLLUTANTS SOURCE SAMPLING METHODS

ISSUED THIS 26TH DAY OF NOVEMBER 2013 AND EFFECTIVE UNTIL NOVEMBER 25TH, 2018

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board

LeRoy Owens, QSTI/QSTO Review Board

C. David Bagweff, QSTI/QSTO Review Board

Karen D. Kajiya-Mills, QSTI/QSTO Review Board

Glenn C. England, QSTI/QSTO Review Board

APPLICATION
NO.
2008-230



SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

CHARLES R. HORTON

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 26TH DAY OF NOVEMBER 2013 AND EFFECTIVE UNTIL NOVEMBER 25TH, 2018

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board

LeRoy Owens, QSTI/QSTO Review Board

C. David Bagwell, QSTI/QSTO Review Board

Karen D. Kajiya-Mills, QSTI/QSTO Review Board

Glenn C. England, QSTI/QSTO Review Board

APPLICATION
NO.
2008-230



SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

CHARLES R. HORTON

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

HAZARDOUS METALS MEASUREMENT SAMPLING METHODS

ISSUED THIS 2ND DAY OF SEPTEMBER 2014 AND EFFECTIVE UNTIL SEPTEMBER 1ST, 2019

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board

LeRoy Owens, QSTI/QSTO Review Board

C. David Bagwell, QSTI/QSTO Review Board

Karen D. Kajiy-Mills, QSTI/QSTO Review Board

Glenn C. England, QSTI/QSTO Review Board

APPLICATION
NO.
2008-230

