

From: [Embry, Regina G](#)
To: [FDEP CCR notification](#)
Subject: GRU 2019 CCR semi-annual sampling event
Date: Tuesday, May 28, 2019 11:11:00 AM

Per the requirements of the 40 CFR 257.95(g) and 40 CFR 257.105(h)(8), this email serves as notification that lithium and molybdenum have been detected at a statistically significant level above the groundwater protection standard at the Coal Combustion Residuals Landfill at Deerhaven Generating Station.. Per the requirements of 40 CFR 257.106(h)(6) and 40 CFR 257.107(h)(6), a copy of this notification has been placed in the operating record and will be posted to GRU's publicly-accessible internet site within 30 days of placement in the operating record, respectively.

Regina Embry
Principal Engineer
Gainesville Regional Utilities
Voice - (352) 393-1299
Cell - (352) 538-7143
embryrg@gru.com