

**From:** [Embry, Regina G](#)  
**To:** "FDEP CCR notification"  
**Subject:** GRU CCR Landfill Groundwater Assessment Monitoring Results Dec 2018  
**Date:** Wednesday, December 5, 2018 10:42:00 AM

---

Per the requirements of the 40 CFR 257.95(g) and 40 CFR 257.105(h)(8), this email serves as notification that lithium and molybdenum have been detected at a statistically significant level above the groundwater protection standard at the Coal Combustion Residuals Landfill at Deerhaven Generating Station.. Per the requirements of 40 CFR 257.106(h)(6) and 40 CFR 257.107(h)(6), a copy of this notification has been placed in the operating record and will be posted to GRU's publicly-accessible internet site within 30 days of placement in the operating record, respectively.

Regina Embry  
Principal Engineer  
Gainesville Regional Utilities  
Voice - (352) 393-1299  
Cell - (352) 538-7143  
Fax - (352) 334-2277  
[embryrg@gru.com](mailto:embryrg@gru.com)