

Embry, Regina G

From: Embry, Regina G
Sent: Wednesday, August 22, 2018 10:09 AM
To: 'FDEP CCR notification'
Subject: GRU CCR Landfill Groundwater Assessment Monitoring Results

Per the requirements of the 40 CFR 257.95(g) and 40 CFR 257.105(h)(8), this email serves as notification that lithium has been detected at a statistically significant level above the groundwater protection standard at the Coal Combustion Residuals Landfill at Deerhaven Generating Station. Per the requirements of 40 CFR 257.106(h)(6) and 40 CFR 257.107(h)(6), a copy of this notification has been placed in the operating record and will be posted to GRU's publicly-accessible internet site within 30 days of placement in the operating record, respectively.

Regina Embry
Principal Engineer
Gainesville Regional Utilities
Voice - (352) 393-1299
Cell - (352) 538-7143
Fax - (352) 334-2277
embryrg@gru.com